

## **INSTRUCTIONS FOR CREATING SUBFORM: 2.7-ACR-Semi-Annual**

**Follow these steps to create the form fields:**

### **STEP 1: Create a Single Select field**

**Description:** 2.7-SA-ACR-2: Check fan-belt tension, check for belt wear, and check sheaves for evidence of improper alignment or evidence of wear. Correct tension and sheave alignment.

**Options:** Yes, No

### **STEP 2: Create an Info Text field**

**Content:** GSH

### **STEP 3: Create a Single Select field**

**Contractor:** GSH

**Description:** 2.7-SA-ACR-3: Check motor starter for proper operation. Correct as needed. Clean housing, and tighten connections as needed. Clean or replace air filter.

**Options:** Yes, No

### **STEP 4: Create an Info Text field**

**Content:** TORFI/GSH

### **STEP 5: Create a Single Select field**

**Contractor:** TORFI/GSH

**Description:** 2.7-SA-ACR-4: Check control system and devices for evidence of improper operation. Clean, lubricate, adjust.

**Options:** Yes, No