

INSTRUCTIONS FOR CREATING SUBFORM: 2.3-FTST-Monthly

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: LEONARD POWERS

Description: 2.3-M-FTST-1: Perform visual test with test valve or audial tests of trap using ultrasonic detector. Check supply pressure, temperature, back pressure and condensate load to trap. If cold, check for clogged pipe/equipment, closed valve or plugged strainer/drip leg.

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: LEONARD POWERS

Description: 2.3-M-FTST-1A: Adjust equipment settings to ensure trap is performing under design conditions. Unclog and clogged pipes or equipment. Open any closed valves. Unplug any strainers or drip legs. Clean out trap if required. Inspect Float & thermostatic trap.

Options: Yes, No