

INSTRUCTIONS FOR CREATING SUBFORM: 2.16-ATT-ST-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ATT-ST-1: Verify that Perforated sheet metal liner and baffles are undamaged, remaining parallel, airspaces between baffles are free of debris, holes in perforated sheet metal liner are open and free of dust and foreign matter, no signs of rusting

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ATT-ST-1A: Vacuum dry deposits from airspaces and sheet metal liner. Remove grease laden deposits with mild detergent solution or isopropyl water base solution

Options: Yes, No

STEP 3: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ATT-ST-3: Inspect sound attenuator for signs of corrosion, defects or cracks. Record location of damage.

Options: Yes, No

STEP 4: Create a Single Select field

Contractor: GSH

Description: 2.16-A-ATT-ST-4: Check attenuator for dirt, debris, and/or damaged/loose flexible connections. Clean attenuator and tighten/replace connections as needed.

Options: Yes, No