

## INSTRUCTIONS FOR CREATING SUBFORM: 2.16-TEF-Annual

**Follow these steps to create the form fields:**

### **STEP 1: Create a Single Select field**

**Description:** 2.16-A-TEF-10: Assess field-serviceable bearings. Lubricate as necessary.

**Options:** Yes, No

### **STEP 2: Create a Single Select field**

**Description:** 2.16-A-TEF-11: Check control box for dirt, debris, and/or loose terminations. Clean and tighten electrical connections as needed.

**Options:** Yes, No

### **STEP 3: Create a Single Select field**

**Description:** 2.16-A-TEF-12: Check motor contactor for pitting or other signs of damage. Clean and tighten electrical connections as needed.

**Options:** Yes, No

### **STEP 4: Create a Single Select field**

**Description:** 2.16-A-TEF-2: Check integrity of all panels on equipment. Replace fasteners as needed to ensure proper integrity and fit/finish of equipment.

**Options:** Yes, No

### **STEP 5: Create a Single Select field**

**Description:** 2.16-A-TEF-3: Inspect exposed ductwork and external piping for insulation and vapor barrier integrity. Record location of damage.

**Options:** Yes, No

### **STEP 6: Create a Single Select field**

**Description:** 2.16-A-TEF-5: Inspect flexible connections. Clean as needed.

**Options:** Yes, No

### **STEP 7: Create a Single Select field**

**Description:** 2.16-A-TEF-8: Check fan drive for problems due to poor alignment or poor bearing seating. Adjust and lubricate as necessary.

**Options:** Yes, No

### **STEP 8: Create a Single Select field**

**Description:** 2.16-A-TEF-9: Check fan blades and fan housing. Clean as needed.

**Options:** Yes, No

### **STEP 9: Create a Single Select field**

**Description:** 2.16-A-TEF-4: Check damper for condition, setting, and operation. Adjust and lubricate as necessary.

**Options:** Yes, No