

## INSTRUCTIONS FOR CREATING SUBFORM: 5.4-DSCVA-Quinquennial

**Follow these steps to create the form fields:**

### **STEP 1: Create a Single Select field**

**Contractor:** UFCO

**Description:** 5.4-QQ-DSCVA-1: Assembly shall be inspected during cold weather to verify a minimum temperature of 40°F (4°C). Record temperature and location. Provide temporary heating to the valve or assembly if applicable.

**Options:** Yes, No

### **STEP 2: Create a Single Select field**

**Contractor:** UFCO

**Description:** 5.4-QQ-DSCVA-6: Inspect strainers, filters, and restricted orifices internally. Internal components shall be cleaned, repaired, replaced and cleared of obstructions as necessary in accordance with the manufacturer's instructions.

**Options:** Yes, No