

INSTRUCTIONS FOR CREATING SUBFORM: 5.5-SZCVA-Semi-Annual

Follow these steps to create the form fields:

STEP 1: Create a Single Select field

Contractor: UFCO

Description: 5.5-SA-SZCVA-4: Perform test of supervisory switch. A distinctive signal shall indicate movement from the valve's normal position during either the first two revolutions of a hand wheel or

Options: Yes, No

STEP 2: Create a Single Select field

Contractor: UFCO

Description: 5.5-SA-SZCVA-4A: when the stem of the valve has moved one-fifth of the distance from its normal position. The signal shall not be restored at any valve position except the normal position.

Options: Yes, No