

INSTRUCTIONS FOR CREATING SUBFORM: 5.2-FCPS-Annual

Follow these steps to create the form fields:

STEP 1: Create an Info Text field

Content: United Fire

STEP 2: Create a Single Select field

Description: 5.2-A-FCPS-2: Control equipment shall be tested to verify correct receipt of alarm, supervisory, and trouble signals (inputs), operation of evacuation signals and auxiliary functions (outputs), circuit supervision including detection of open circuits and ground faults,

Options: Yes, No

STEP 3: Create a Single Select field

Description: 5.2-A-FCPS-2A: and power supply supervision for detection of loss of ac power and disconnection of secondary batteries.

Options: Yes, No