



ABC COMPANY
Controller Report

Platform1 Report 3.10c.17.03

Name : Controller 1

Description :	Model : N5400
Type :	Address : 192.168.1.100
Port No. : 44002	Connection :
Suspend Polling : No	Security Mode : Low
Global Antipassback Group :	Alarm/Siren Duration (min) : 15
Arm Delay (sec) : 15	Disarm Delay (sec) : 15
Arming TZ : 0	General Purpose Output TZ : 0
Router :	Unit No :
Master :	Antipassback Reset Time :
Relay 1 : Door 1	Relay 2 :
Relay 3 : Door 2	Relay 4 :
Admin/Local Pin Reset Time :	AE IP : 192.168.1.254
AE Port : 44002	Subnet : 255.255.255.0
Gateway : 0.0.0.0	AE ID : 1
Use AES : No	Interlock Enabled : No
Cross-Board Interlock Group :	Card Capacity : 30000
Transaction Capacity : 80000	Logo Group : N/A
Admin/Local PIN Reset Interval (min) : N/A	Display Card Name : N/A
Display Logo : N/A	Default Time Attendance Mode : N/A
Comm 2 Baudrate (Suprema) : N/A	DRB Enabled : N/A
Display Mode : N/A	PA Messaging : N/A

Door 1 : DR1 N5400

Description :	Reader Type : N/A
Lock release time (sec) : 0	Open time (sec) : 1
Entry Zone ID : 1	Exit Zone ID : 2
Card + PIN Time Zone : 0	Card + PIN Lockout Count : 0
Lock Release Time Zone : 0	Exit Button Enabled Time Zone : 1
Antipassback Time Zone : 0	Antipassback Lockout Count : 0
Buddy Mode Time Zone : 0	Access Limit : 0
PIN 1 Time Zone : 0	PIN 2 Time Zone : 0
PIN 3 Time Zone : 0	PIN Lockout Count : 0
Time Attendance Reader : Yes	Roll Call Reader : Yes
Check Card Expiry Date : No	Software Fire Release : Yes
Roll Call Group : RC1	Active Time Zone :
Keyed Card + PIN Time Zone : 0	Interlock Enabled : No
Door Sensor Delay (0.1 sec) : 0	Lock Energize Option : By Lock Release time
Authorization Lock Release : No	Enable KeyPad : N/A
NCP Entry Zone ID : N/A	NCP Exit Zone ID : N/A
NCP Is Outer Zone : N/A	

Door 2 : DR2 N5400

Description :	Reader Type : N/A
Lock release time (sec) : 0	Open time (sec) : 1
Entry Zone ID : 1	Exit Zone ID : 2
Card + PIN Time Zone : 0	Card + PIN Lockout Count : 0
Lock Release Time Zone : 0	Exit Button Enabled Time Zone : 1
Antipassback Time Zone : 0	Antipassback Lockout Count : 0
Buddy Mode Time Zone : 0	Access Limit : 0
PIN 1 Time Zone : 0	PIN 2 Time Zone : 0
PIN 3 Time Zone : 0	PIN Lockout Count : 0
Time Attendance Reader : Yes	Roll Call Reader : Yes
Check Card Expiry Date : No	Software Fire Release : Yes
Roll Call Group : RC1	Active Time Zone :
Keyed Card + PIN Time Zone : 0	Interlock Enabled : No
Door Sensor Delay (0.1 sec) : 0	Lock Energize Option : By Lock Release time
Authorization Lock Release : No	Enable KeyPad : N/A
NCP Entry Zone ID : N/A	NCP Exit Zone ID : N/A
NCP Is Outer Zone : N/A	

Suprema Integration**Use Fingerprint:** No**Reader: 1**

Name : RDDR1 IN	Description :
Reader Type : Standard Wiegand	In/Out : In
Activated Time Zone : 1	Wiegand Format : Wiegand 26-bits
Bind to : 1	Bind to Zone : 1
Enable Access Limit : No	Bypass Access Limit : No
Use Loop Detect: No	Wiegand Group :
HID AGK : N/A	Wiegand Option : Multiple
Wiegand Group(s) Selection : 1111100000 (Refer Wiegand Listing)	Use Built-in Tamper : No
Lockdown during Tampered : No	NCP Time : N/A

Reader: 2

Name : RDDR1 OUT	Description :
Reader Type : Standard Wiegand	In/Out : Out
Activated Time Zone : 1	Wiegand Format : Wiegand 26-bits
Bind to : 1	Bind to Zone : 1
Enable Access Limit : No	Bypass Access Limit : No
Use Loop Detect: No	Wiegand Group :
HID AGK : N/A	Wiegand Option : Multiple
Wiegand Group(s) Selection : 1111100000 (Refer Wiegand Listing)	Use Built-in Tamper : No
Lockdown during Tampered : No	NCP Time : N/A

Reader: 3

Name : RDDR2 IN	Description :
Reader Type : Standard Wiegand	In/Out : In
Activated Time Zone : 1	Wiegand Format : Wiegand 26-bits
Bind to : 2	Bind to Zone : 0
Enable Access Limit : No	Bypass Access Limit : No
Use Loop Detect: No	Wiegand Group :
HID AGK : N/A	Wiegand Option : Multiple
Wiegand Group(s) Selection : 1111100000 (Refer Wiegand Listing)	Use Built-in Tamper : No
Lockdown during Tampered : No	NCP Time : N/A

Reader: 4		
Name : RDDR2 OUT	Description :	
Reader Type : Standard Wiegand	In/Out : Out	
Activated Time Zone : 1	Wiegand Format : Wiegand 26-bits	
Bind to : 2	Bind to Zone : 0	
Enable Access Limit : No	Bypass Access Limit : No	
Use Loop Detect : No	Wiegand Group :	
HID AGK : N/A	Wiegand Option : Multiple	
Wiegand Group(s) Selection : 1111100000 (Refer Wiegand Listing)	Use Built-in Tamper : No	
Lockdown during Tampered : No	NCP Time : N/A	

GateZone Index: 1		
Gate Zone ID : 1	Max In :	30000

GateZone Index: 2		
Gate Zone ID : 2	Max In :	30000

Input 1: DSD1_Controller 1	Description :	Input Type : Door Sensor
Bind to : 1	Trigger Mode : Open Trigger	Digital/ Analog : Digital
Trigger State Delay (sec) : 0.0	Normal State Delay (sec) : 0.0	

Input 2: Alarm 1	Description :	Input Type : Alarm
Bind to : 0	Trigger Mode : Close Trigger	Digital/ Analog : Digital
Trigger State Delay (sec) : 0.0	Normal State Delay (sec) : 0.0	

Input 5: DSD5_Controller 1	Description :	Input Type : Door Sensor
Bind to : 2	Trigger Mode : Open Trigger	Digital/ Analog : Digital
Trigger State Delay (sec) : 0.0	Normal State Delay (sec) : 0.0	

Input 8: Fire Trigger 1	Description :	Input Type : Fire
Bind to : 0	Trigger Mode : Open Trigger	Digital/ Analog : Analog
Trigger State Delay (sec) : 0.0	Normal State Delay (sec) : 0.0	

Event Relay: 1	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 2	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 3	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 4	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 5	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 6	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 7	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 8	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 9	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Event Relay: 10	Description :	Activated Time Zone : 1
Criteria : Undefined	Duration : 0 sec(s)	Trigger: : Off

Printed on: 10/08/2018 10:26:45

Page: 3

Controller Wiegand Listing

Set 01 : Standard Wiegand 26-bits (predefined)
Set 03 : Standard Wiegand 34-bits (predefined)
Set 05 : Standard Wiegand 37-bits (predefined)
Set 07 :
Set 09 :

Set 02 : Standard Wiegand 32-bits (predefined)
Set 04 : Standard Wiegand 35-bits (predefined)
Set 06 :
Set 08 :
Set 10 :