



Product Service

CERTIFICATE

No. Z10 16 03 19183 051

Holder of Certificate: HIMA Paul Hildebrandt GmbH
Albert-Bassermann-Str. 28
68782 Brühl
GERMANY

Factory(ies): 19183

Certification Mark:



Product: Automation Equipment, Safety Related
Modules of the Planar 4 system

Model(s): PLANAR 4 System

Parameters: The report HB87155C in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met.

Operating voltage: 24 V DC
Design: Eurocard

Tested according to: IEC 61508-1(ed.2) (SIL4)
IEC 61508-2(ed.2) (SIL4)
IEC 61508-3(ed.2) (SIL4)
IEC 61508-4(ed.2) (SIL4)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: HB87155C

Valid until: 2021-03-01

Date, 2016-03-03

(Dr.-Ing. Peerasan Supavatanakul)

Page 1 of 1

