

Verifying the Integrity of a Sodium-Cooled Fast Reactor Specification: An Integrated Analysis Against Global Benchmarks

Core Physics and Neutronic Design Validation

The foundation of any nuclear reactor design lies in its core physics and neutronics parameters, which dictate its operational stability, safety, and fuel cycle performance. A comprehensive review of a specification sheet requires a rigorous examination of these fundamental aspects to ensure they are not only internally consistent but also align with decades of research and development in sodium-cooled fast reactor (SFR) technology. The primary areas for validation are the reactivity control system, the fuel management strategy, and the inherent safety characteristics defined by key neutronic feedback coefficients. These elements must work in concert to ensure the reactor can be started, operated safely within its design basis, and shut down reliably under all anticipated conditions.

The first critical parameter is the reactivity control system, primarily embodied by control rods. The specification must detail the total negative reactivity that can be inserted into the core to achieve a safe shutdown state. This is quantified through the concept of Shutdown Margin (SDM), which is the difference between the total available shutdown reactivity and the excess reactivity present in the core ⁷. Industry standards typically require an SDM in the range of one to five percent reactivity ($\Delta k/K$) to provide a robust buffer against uncertainties or unexpected positive reactivity insertions ¹⁰. For instance, some specific designs have targeted minimum margins of 3000 pcm at beginning-of-cycle (BOC) ²⁹³, while analyses for other advanced designs consider margins required to withstand credible accident scenarios where the minimal margin might fall below 200 °C, indicating a need for careful thermal-hydraulic-neutronic coupling ¹³⁸. The specification must therefore state the total insertion worth of all shutdown systems, including both control rods and any other absorber mechanisms like movable reflectors ⁵⁰. This total worth must exceed the sum of the core's excess reactivity and the maximum expected positive reactivity from phenomena such as Doppler feedback, xenon poisoning, or

sodium void effects ²⁵⁵. Furthermore, the specification should account for ancillary factors that contribute to shutdown safety, such as the neptunium effect after shutdown (which can add up to 120 pcm) and margins for potential fuel handling errors (as high as 3200 pcm) ⁵. Control rod worth itself is not a single value; it varies with the rod's position and the local neutron flux distribution ¹². Therefore, a complete specification should provide a differential control rod worth curve, showing how reactivity changes with incremental rod movement, rather than just a single "total worth" figure ^{3 8}. Experimental validation of these calculated worths is a standard practice, with facilities like JOYO having conducted regular measurements using methods like the period and neutron source techniques to calibrate their models ^{81 253}.

The second pillar of core physics is the fuel cycle design, which defines the reactor's sustainability and waste management capabilities. SFRs are designed for breeding fissile material from fertile isotopes like Uranium-238 or Thorium-232, or for burning transuranic elements from spent light water reactor fuel ^{90 183}. This is reflected in the conversion ratio, which is ideally greater than 1.0 for breeder configurations ²⁰⁷. The specification must detail the fuel type (e.g., metallic uranium-plutonium alloy or mixed oxide), initial enrichment, and target discharge burnup. High burnup is a key objective, enabling longer core lifetimes and reducing the frequency of refueling. Typical values for modern SFRs aim for discharge burnups around 70 GWd/T ¹³⁵, with large-scale designs targeting similar levels ²³⁰. The choice of fuel directly impacts neutronic performance and safety characteristics; for example, metallic fuels offer superior heat conductivity but may have different swelling behaviors compared to ceramic oxides ¹⁴⁷²³⁶. The core lifetime, expressed in Effective Full Power Days (EFPD), is a direct consequence of the initial enrichment and target burnup. The BN-800 reactor, for instance, was designed for a significant core life, demonstrating the feasibility of long-life cores in SFRs ¹⁹⁶. The specification must ensure these three parameters—enrichment, burnup, and lifetime—are mutually consistent. Higher enrichments can extend core life but may raise proliferation resistance concerns, while higher burnups place greater demands on fuel cladding materials to resist irradiation damage, corrosion, and fission gas release ¹⁵⁵¹⁸².

Finally, the inherent safety of the reactor is governed by its neutronic feedback coefficients, which describe how reactivity changes in response to variations in temperature or coolant density. Two of the most important are the Doppler coefficient (fuel temperature feedback) and the sodium void worth (coolant density feedback). A strong negative Doppler coefficient is a primary mechanism for stabilizing power excursions; as fuel temperature increases, the resonance absorption of neutrons broadens, causing a prompt reduction in reactivity ²³⁴. The sodium void worth is a critical

safety feature unique to pool-type SFRs. It describes the change in reactivity if a portion of the liquid sodium coolant were to void (turn to gas). An SFR design with a low or negative sodium void worth is highly desirable because it means that a loss-of-flow or unprotected transient would lead to a decrease in reactivity, providing a powerful intrinsic stabilizing force ⁷². The BN-800 reactor was specifically designed with this characteristic in mind ¹⁹⁶. Conversely, a positive void worth, where voiding causes a power increase, is a major design challenge that requires complex mitigation strategies, such as the use of absorber rods or specific core zoning ²³⁵. The specification must clearly state the calculated values for both the Doppler coefficient and the sodium void worth at various stages of the core's life. These values are not static; they change as fuel burns up and fission products accumulate. International benchmark exercises, such as those organized by the OECD/NEA, regularly include the calculation of these parameters for various SFR core designs to validate predictive codes and methods ¹³³¹³⁶¹⁶⁶. By comparing the specified values against these benchmarks, one can assess the credibility of the neutronics calculations underlying the entire design. The overall goal of Generation IV SFRs is to passively avoid fuel damage even if active scram systems fail, a capability that relies heavily on these favorable inherent reactivity characteristics ¹³⁴.

Thermal-Hydraulic System Integration and Energy Balance

The thermal-hydraulic performance of a sodium-cooled fast reactor is paramount, as it dictates the safe transport of heat from the core to the power conversion system. An error in thermal-hydraulic specification can cascade into severe consequences, including fuel melting. Therefore, a thorough review must focus on the internal consistency of the thermal-hydraulic parameters, ensuring that the specified temperatures, pressures, flow rates, and heat transfer characteristics form a coherent and physically plausible energy balance. The system operates under a unique set of conditions: liquid sodium has excellent heat transfer properties but is chemically reactive with air and water, and it operates at very low pressure despite its high boiling point ^{1 15}. This combination necessitates precise engineering to maintain a large subcooling margin throughout the primary circuit.

A primary area for verification is the temperature and pressure regime of the primary coolant loop. The specification must define the core inlet and outlet temperatures, as well as the operating pressure of the primary system. For advanced SFR designs, the typical

core outlet temperature is specified in the range of 500-550°C ² . However, operating experience from reactors like the BN-800 shows that under certain transient conditions, maximum outlet temperatures can approach 940 K (~667°C) ¹⁵⁶. While these peak values are transient, they inform the design basis for materials and clad integrity. The operating pressure is kept intentionally low, often just above atmospheric pressure, to minimize stress on the reactor vessel and piping ¹ . For example, at a core outlet temperature of 120°C, the pressure inside the vessel would be only around 0.5 MPa ³³³. However, to maintain a substantial subcooling margin and prevent boiling during normal operation and transients, the actual operating pressure is significantly higher. The specification must ensure that the chosen pressure is sufficient to keep the entire primary coolant path well below the saturation temperature corresponding to that pressure. Any inconsistency here could imply a risk of sodium boiling, which would trigger a positive sodium void reactivity insertion, potentially leading to a power excursion ⁷² . The relationship between these parameters is governed by the thermodynamic properties of sodium, which are well-documented and can be used to verify the consistency of the specified state points ⁸⁷ .

The next critical check is the mass and energy balance across the reactor core. The rate at which thermal energy is removed by the primary coolant must exactly equal the thermal power generated by the nuclear reactions. The specification must provide a clear link between the reactor's rated thermal power (in MWth), the specified mass flow rate of the sodium coolant (in kg/s), and the measured or calculated temperature rise across the core ($\Delta T = T_{\text{out}} - T_{\text{in}}$). The fundamental equation for this balance is:

$$\dot{Q} = \dot{m} \cdot C_p \cdot \Delta T$$

where $\dot{Q}$ is the thermal power, $\dot{m}$ is the mass flow rate, C_p is the specific heat capacity of sodium, and ΔT is the temperature difference. A discrepancy in this equation indicates a fundamental inconsistency in the design. For example, if the specified thermal power is 2100 MWth, the mass flow rate must be sufficient to absorb that much energy given the allowable ΔT and the known C_p of sodium at the operating temperature. The BN-800 reactor provides a real-world data point: with a thermal power of 2100 MWth, its thermal-hydraulic tests were essential for determining the operational range of coolant flow rates needed to manage this heat load safely ¹⁹¹¹⁹⁴. The flow distribution within the core is also critical; non-uniform flow can create localized hot spots that could compromise fuel integrity. Design methodologies often involve optimizing the r-z power distribution to ensure uniform heating and prevent such issues ²³⁵. Computational Fluid Dynamics (CFD) tools, validated against experimental data from wire-wrapped rod

bundles, are now commonly used to analyze these 3D thermal-hydraulic characteristics

13 21 .

The heat transfer process extends beyond the core to the intermediate heat exchangers (IHX) and steam generators (SG). Most modern SFR designs employ a three-circuit arrangement to isolate the radioactive primary sodium from the conventional steam/water power conversion system ^{61 68}. In this configuration, the IHX transfers heat from the primary sodium loop to a secondary sodium loop, and the SG then transfers heat from the secondary loop to the tertiary water/steam loop ²⁹⁰. The specification must ensure the energy balance is maintained across both interfaces. The heat rejected by the primary sodium in the IHX must equal the heat absorbed by the secondary sodium. Similarly, the heat transferred from the secondary sodium in the SG must match the heat input to the water/steam cycle. Each heat exchanger introduces a temperature difference (ΔT) between the hot and cold fluids. A smaller ΔT requires a larger heat exchange surface area, increasing the size, weight, and cost of the component. The specification should justify the chosen design point (i.e., the ΔT for each heat exchanger) based on an economic and engineering trade-off analysis. Extensive testing on steam generator models, such as those performed for the BN-600 and BN-800 reactors, has been crucial for validating design parameters like the required superheat temperature to prevent moisture carryover into the turbine, which could cause blade erosion ¹⁹². The entire thermal-hydraulic system, from core to condenser, must be viewed as a single integrated energy transfer chain, and its consistency is the ultimate measure of a sound design.

Power Conversion Efficiency and Component Performance

The power conversion system is responsible for transforming the thermal energy carried by the reactor's coolant into usable electrical power. Its performance is a critical determinant of the plant's overall economics and efficiency. For a sodium-cooled fast reactor, the specification of the power conversion system must be consistent with the high-temperature, low-pressure characteristics of the primary coolant loop. A detailed review involves assessing the specified thermodynamic cycle, the efficiency of its components, and the resulting electrical output in relation to the reactor's thermal power. The primary metric for evaluation is the thermal-to-electrical efficiency, which is fundamentally constrained by the peak temperature of the working fluid.

The most common approach for SFRs is to use a secondary sodium loop to transfer heat to a steam Rankine cycle, which drives a turbine-generator set ²⁹⁹. The efficiency of this cycle is dictated by the peak steam temperature and pressure entering the turbine. Because the secondary sodium loop is heated by the primary loop, its maximum temperature is limited by the core's outlet temperature and the temperature drop required across the steam generator. As established in thermal-hydraulic reviews, SFR core outlet temperatures typically range from 500-550°C ². This temperature ceiling directly influences the achievable cycle efficiency. Advanced SFR designs aim for efficiencies around 42%, which is notably higher than the typical 32-36% achieved by current pressurized water reactors (PWRs) ¹. This higher efficiency is a key advantage of the fast-spectrum design, allowing it to operate at higher temperatures than water-cooled reactors without requiring high system pressures ²³². To validate the specification, one must perform a simple calculation: multiply the reactor's specified thermal power (MWth) by the stated cycle efficiency. The result should closely match the specified electrical power output (MWe). For example, the BN-800 reactor, with a thermal power of 2100 MWth, is designed to produce 880 MWe of electricity ^{64 317}. The corresponding efficiency is approximately $(880/2100) \times 100\% \approx 41.9\%$, which falls squarely within the expected range for an SFR ³¹⁷. Any significant deviation from this relationship would indicate a potential error in either the thermal power, electrical power, or efficiency value.

Beyond the overall cycle efficiency, the performance of individual components within the power conversion system warrants scrutiny. The steam turbine itself is a complex piece of machinery, and its efficiency is influenced by numerous factors, including stage aerodynamics, blade wear, and steam conditions. Modern turbines are designed for high efficiency, but their performance degrades over time due to fouling and erosion ²²². The specification should ideally reference the guaranteed turbine efficiency at design conditions. The validation of turbine stage work and the accuracy of energy balance calculations within the turbine are recognized best practices in the industry ^{51 167}. Similarly, the steam generators and main circulation pumps play a vital role. The BN-800's design validation included extensive testing to confirm the thermal and hydraulic characteristics of its main circulation pumps, intermediate heat exchangers, and steam generators ²⁰⁰. These tests were crucial for establishing the operational parameters and confirming that the equipment could meet the design requirements. The specification should detail the key performance parameters of these components, such as the pump head and flow rate, or the heat transfer area and pressure drops for the heat exchangers. These values must be consistent with the overall thermal-hydraulic design of the plant.

Furthermore, the dynamic behavior of the power conversion system, especially its ability to follow load changes, is an important aspect of performance. Load-following introduces thermal and mechanical transients into the reactor core and coolant systems, which must be managed safely ¹⁸⁸. The design of the control systems for the turbine and associated valves is critical. Advanced modeling and experimental validation of turbine control actions are ongoing research areas to improve plant flexibility and reliability ^{52 124}. While the user's specification may not go into extreme detail on control algorithms, it should at least acknowledge the consideration of load-following capabilities and their impact on the design basis. The integration of the power conversion system with the reactor's inherent safety features is also vital. For example, the system must be designed to automatically trip the turbine in response to a reactor scram or other safety-related signals. The validation of these interlocks and the overall plant response during transients is typically performed using sophisticated multi-physics simulation tools ¹¹⁰. In summary, the power conversion section of the specification must demonstrate that the chosen cycle and component efficiencies are realistic for an SFR, that the electrical output is consistent with the thermal power and stated efficiency, and that the system design accounts for both steady-state operation and dynamic transients.

Safety Systems, Passive Decay Heat Removal, and Operational Margins

Safety is a defining characteristic of Generation IV reactor designs, and for an SFR, it is achieved through a multi-layered defense-in-depth strategy. This includes inherent safety features, diverse and independent active systems, and robust passive systems. A critical part of the review is to evaluate whether the specification adequately addresses these layers, with a particular focus on the ultimate safety function: the reliable removal of decay heat after shutdown. The specification must also quantify the operational safety margins for key parameters, ensuring the plant can operate within its design limits under all foreseeable conditions.

The most crucial safety function is the removal of decay heat, which continues to be produced by radioactive decay of fission products even after the chain reaction has been stopped. The specification must detail the Decay Heat Removal (DHR) system, including its architecture, capacity, and mode of operation. Modern SFR designs place a strong emphasis on passive DHR systems, which rely on natural phenomena like gravity and convection rather than active components like pumps and motors ². A common passive

approach is to use natural circulation, where heated sodium in the core rises into heat exchangers located in a lower reservoir, transferring its heat to a cooling fluid before flowing back down into the core ¹⁸⁹. The PERSEO facility in Italy was a dedicated test bed built specifically to study and validate such passive DHR systems operating in natural circulation ¹²⁶²¹³. The specification must state the rated heat removal capacity of the DHR system and confirm that it is sufficient to handle the maximum expected decay heat load, which is approximately 7% of the full power level immediately following shutdown. The system's design basis should also consider the required grace time or margin to fuel melting during various accident scenarios, which is a key focus of uncertainty analysis efforts ²⁰³. Redundancy and diversity are also important; the ESR-SMART design, for example, incorporates multiple independent DHR trains to ensure reliability ²⁸⁹. The user's specification should describe the DHR system's design philosophy (active vs. passive), its capacity, and the number of redundant trains provided.

In addition to post-accident heat removal, the specification must demonstrate that adequate safety margins exist for all operational parameters. This goes beyond simply stating pressure and temperature limits. The ASME Boiler and Pressure Vessel Code, Section III, Division 5, provides the framework for designing components for elevated temperatures, explicitly accounting for phenomena like creep, fatigue, and stress rupture ¹⁴⁴²⁷⁰. The specification should implicitly or explicitly show that all pressure-containing components have been designed in accordance with these rules, incorporating appropriate safety factors for manufacturing tolerances and corrosion allowances ⁴⁹. For example, the ASME code design fatigue curves incorporate safety factors of 2 for amplitude and 20 for number of cycles compared to best-fit material curves ²¹⁸. The regulatory treatment of advanced reactors, including SFRs, increasingly relies on a Best-Estimate Plus Uncertainty (BEPU) approach, which requires a rigorous justification of these safety margins based on validated calculations and uncertainty quantification ²⁰³ ²⁶⁰. The specification should therefore not just list numbers but provide a rationale for them, referencing the applicable design codes and safety analyses.

The overall safety posture is further enhanced by the use of diverse and independent shutdown systems. SFRs typically employ a combination of active and passive mechanisms ². Active systems might include absorber rod insertion driven by electromechanical mechanisms, while passive systems could consist of hydraulically suspended shutdown rods that fall into the core by gravity upon loss of signal ⁵⁰ ³⁰⁴. The specification should list these diverse systems and describe their modes of actuation. The effectiveness of these systems is tied to the control rod worth, as discussed previously, and the total shutdown margin must be sufficient to account for all credible initiating events and potential failures. For instance, a probabilistic safety assessment (PSA) for the

Russian BN-800 design confirmed that its innovative features led to a reduced risk profile ¹⁸⁰. The specification should also address other safety considerations, such as the prevention of sodium-water reactions in the steam generators, which are mitigated by the three-circuit design, and measures to prevent containment bypass ^{2 331}. Finally, the specification should mention the existence of an effective sodium removal capability, a fundamental design criterion for future fast reactors to facilitate maintenance and decommissioning ³⁰. By examining these elements—the DHR system's capacity, the justification of operational margins, the diversity of shutdown mechanisms, and the inclusion of other key safety features—the reviewer can gain confidence that safety has been treated as a primary design driver, not an afterthought.

Structural Integrity, Materials Science, and Regulatory Code Compliance

The long-term structural integrity of a sodium-cooled fast reactor is fundamentally dependent on the materials used for its construction and adherence to stringent design codes. The reactor operates at elevated temperatures and is exposed to a corrosive coolant environment, creating challenging conditions for structural components like the reactor vessel, piping, and fuel cladding. A thorough review of the specification must therefore verify that the chosen materials are appropriate for the service conditions and that the design complies with established regulatory frameworks, such as the ASME Boiler and Pressure Vessel Code (BPVC). These codes provide the necessary rules to ensure the mechanical reliability and safety of the plant throughout its intended service life.

The selection of materials is a critical decision with far-reaching implications for safety, cost, and performance. Liquid sodium is an excellent coolant but can be corrosive, especially at high temperatures, so materials must be resistant to oxidation and dissolution ²⁰⁸. Nuclear-grade stainless steels, such as Type 316L, are commonly used for structural components like the reactor vessel and primary system piping ¹⁴⁸²⁰⁸. Research and development efforts are continuously focused on improving these materials, seeking alloys with superior high-temperature strength and creep resistance. For example, Alloy 617 has been added to the ASME code for high-temperature service due to its performance advantages over traditional alloys like 316H ¹⁴⁹. The specification must clearly identify the materials selected for all key components, including the reactor pressure vessel, primary and intermediate heat exchanger tubes, steam generator tubing,

and control rod drive mechanisms ²⁵⁴. The choice of material directly constrains the maximum allowable operating temperature and pressure for a given component thickness. For instance, the expansion of property data in the 2025 edition of the ASME code allows for more accurate assessments of new alloys ²⁶⁸. The specification cannot simply state a desired operating temperature; it must demonstrate that the chosen material can withstand that temperature for the required duration without exceeding allowable stress limits for creep, fatigue, and stress rupture ²⁶⁶²⁷⁰.

Compliance with the ASME BPVC, Section III, Division 5, is non-negotiable for the construction of high-temperature reactors, including SFRs ¹⁰¹¹⁴⁴. This division of the code provides specific rules for components that operate at elevated temperatures, where time-dependent deformation (creep) becomes a significant factor alongside elastic and plastic stresses ¹⁴⁵. The code establishes allowable stress limits based on extensive material testing and historical performance data. The specification must show that every pressure-containing component has been designed according to these rules. This involves calculating the stresses induced by pressure, dead weight, seismic loads, and thermal gradients, and ensuring they remain within the code's allowable limits for the design lifetime ¹⁰⁴¹⁴⁶. The ASME code also provides specific guidance on design fatigue curves, weld joint categories, and flexibility analysis, all of which are essential for a safe design ¹⁰⁴²¹⁸. Regulatory bodies like the U.S. Nuclear Regulatory Commission (NRC) accept approaches that comply with these ASME code rules to assure mechanical integrity ¹⁰⁰. Therefore, a specification that omits references to these codes or whose stated pressures and temperatures would violate their rules is fundamentally flawed. The designer must provide evidence, either through direct compliance statements or through referenced analysis reports, that the design meets the intent of Division 5.

Beyond static strength, the long-term behavior of materials under irradiation is a major concern, particularly for fuel cladding and internal reactor components. Irradiation can cause dimensional changes such as swelling and creep, as well as affect mechanical properties ¹⁵⁵. The specification should address these effects, likely through conservative design margins or by referencing material qualification programs that account for irradiation damage. For example, the development of microreactors has spurred new research into material qualification for ASME Section III Division 5 components ¹⁴⁸. Similarly, in-service inspection (ISI) rules must be developed rationally, considering the specific features of the SFR design ²⁷¹. The specification should outline the general approach to ISI and aging management, which is a key requirement for maintaining component integrity over the plant's lifetime ⁴². The entire materials and structures discipline is supported by a vast body of international research, including the development of databases for heavy liquid metal cooled fast reactors and the validation

of structural analysis methods ^{88 270}. A robust specification will demonstrate an awareness of these resources and incorporate sound engineering principles to manage the risks associated with high-temperature, high-radiation environments. By verifying the material choices, checking for compliance with ASME codes, and assessing the treatment of long-term degradation mechanisms, the reviewer can ensure the structural soundness of the proposed design.

Validation Methodologies and Benchmarking Against International Standards

Confidence in a self-crafted reactor specification cannot be based solely on internal consistency checks. It must be substantiated through a rigorous validation process that compares the design's key parameters and analytical methods against established benchmarks, experimental data, and the collective knowledge of the international nuclear community. The field of fast reactor technology has matured to a point where a wealth of data and standardized validation procedures are available. A comprehensive review must assess whether the user has employed a credible validation methodology, moving beyond hand calculations to embrace the accepted international practices of best-estimate plus uncertainty (BEPU) analysis and benchmarking.

The cornerstone of modern nuclear reactor analysis is the use of sophisticated computer codes to model neutronics, thermal-hydraulics, and structural mechanics. However, these codes are mathematical approximations of physical reality and must be rigorously validated. The international community facilitates this through coordinated research projects (CRPs) and benchmark exercises, primarily organized by the International Atomic Energy Agency (IAEA) and the Organisation for Economic Co-operation and Development's Nuclear Energy Agency (OECD/NEA) ¹³⁷²²⁷. These initiatives bring together experts from around the world to solve a common problem using their own codes and methods, allowing for a direct comparison of results and an identification of uncertainties. For SFRs, a prominent example is the OECD/NEA subgroup on Uncertainty Analysis in Modelling (UAM) for Sodium-cooled Fast Reactors (SFR-UAM) ¹⁶²²⁰⁵. This group has defined a series of benchmarks covering topics like neutronics, reactivity feedback, and thermal-hydraulics, which participants run to evaluate their modeling capabilities ¹⁶⁴²⁹⁶. The user's specification should ideally be supported by calculations that have been or could be submitted to such a benchmark exercise. Simply stating a calculated value is insufficient; the specification should, at a minimum, document the

code used (e.g., PARCS, SPACE, TRACE), the nuclear data libraries, and the validation cases against which the models were checked ^{22 334}. For example, the EUCLID/V2 multiphysics code is validated on data from the BN-800 reactor ²⁷, and the HYDRA-IBRAE/LM/V1 code has been verified against BN-600 operating data ¹⁹⁵.

The validation process should follow a hierarchical approach, starting with separate-effect tests (SETs) and progressing to integral experiments. SETs focus on validating specific physical phenomena, such as sodium heat transfer correlations or the behavior of a single fuel pin bundle under forced flow ^{21 29}. Integral experiments, on the other hand, involve running an entire reactor or a large-scale test facility and measuring the global response to a transient event ²²⁷. Experiments conducted on past fast reactors like EBR-II in the United States and FFTF in the USA provide invaluable data for validating system codes against real-world transients ¹⁸¹³³⁴. More recently, dedicated test facilities like PERSEO in Italy have been built to study specific safety issues, such as passive decay heat removal in natural circulation ¹²⁶¹²⁸. The user's specification should be benchmarked against these sources of data. For instance, key thermal-hydraulic parameters like core pressure drop and exit temperature can be sensitive to uncertainties in power and hydraulic diameter; these sensitivities should be analyzed and, if possible, compared to results from benchmark studies ¹⁵⁴. The goal of this validation effort is to build confidence that the predictive capabilities of the codes are acceptable for licensing purposes, as outlined in regulatory guides from bodies like the NRC ⁷⁹.

Ultimately, the BEPU methodology represents the state-of-the-art in reactor analysis and safety justification ²⁶⁰. Instead of relying on overly conservative, "pessimistic" calculations, BEPU uses best-estimate codes to predict the most likely outcome of an event and then quantifies the uncertainties in that prediction ²⁰³. This approach provides a more realistic and less unnecessarily restrictive assessment of safety. The SFR-UAM benchmarks are explicitly designed to support the application of the BEPU methodology to SFRs ²⁰⁴. A specification developed using a BEPU approach would not just state a single value for a parameter like control rod worth, but would also provide an uncertainty band around that value, derived from sensitivity studies and comparisons with experimental data. The specification should demonstrate an understanding of this philosophy. Even if a full-blown uncertainty analysis is beyond the scope of a conceptual design, the user should at least discuss the key sources of uncertainty in their calculations and how they have been addressed. For example, they might compare their calculated sodium void worth against the results of international benchmark exercises to gauge the credibility of their neutronics model ¹⁶⁶. By grounding the specification in a framework of international collaboration, transparent code usage, and validation against both

experimental data and established benchmarks, the user can move from a collection of crafted values to a scientifically defensible and credible reactor design.

Reference

1. Feasibility and Economics of Small Nuclear Reactors <https://www.oecd-neo.org/ndd/reports/2011/current-status-small-reactors.pdf>
2. Sodium-Cooled Fast Reactor (SFR) System Safety ... <https://www.gen-4.org/resources/reports/sodium-cooled-fast-reactor-sfr-system-safety-assessment-2017>
3. Control Rod Worths and Interactions in Fast Reactors <https://oecd-neo.org/upload/docs/application/pdf/2020-07/neacrp-a-1983-0605.pdf>
4. PWR November 2020 Neutron Life Cycle <https://www.nrc.gov/reactors/operator-licensing/history-rulemaking-activities/generic-fundamentals-examinations/pwr/pwr-files/192002.pdf>
5. Evaluation of the Control Rods Withdrawal in a Small ... <https://cea.hal.science/cea-02394085/document>
6. Control Rod Worth https://www.bohrium.com/en/sciencepedia/feynman/keyword/control_rod_worth
7. Development of a PC Based System for On-Line ... <https://inis.iaea.org/records/3tssn-jpp56/files/23005562.pdf?preview=0>
8. IV Reactor Validation (IRPhEP 2010 Handbook) <https://inldigitallibrary.inl.gov/sites/sti/sti/4537217.pdf>
9. What's the typical negative reactivity achievable by just ... https://www.reddit.com/r/NuclearPower/comments/1lpffnx/whats_the_typical_negative_reactivity_achievable/
10. Shutdown Margin - SDM | Definition | nuclear-power.com <https://www.nuclear-power.com/nuclear-power/reactor-physics/reactor-operation/shutdown-margin-sdm/>
11. Calculation of Control Rod Worth in APPR-1 <https://www.osti.gov/biblio/4332277>
12. Differential control rod worth. | Download Scientific Diagram https://www.researchgate.net/figure/Differential-control-rod-worth_fig1_327197164
13. Analysis of full-scale thermal-hydraulic characteristics ... <https://www.sciencedirect.com/science/article/abs/pii/S1290072925002327>
14. Fast reactors <http://www.iaea.org/topics/fast-reactors>

15. Review of State of the Art Thermal Hydraulics of Fast Reactors https://www-pub.iaea.org/MTCD/publications/PDF/p15861-DOC-010-498_web.pdf
16. Liquid metal cooled fast reactor thermal hydraulic research ... <https://pmc.ncbi.nlm.nih.gov/articles/PMC10241851/>
17. IAEA-CN245-359 Overview of the IAEA Activities in the ... <https://media.superevent.com/documents/20170620/100fd3520e11e3499382a56e67290749/fr17-359.pdf>
18. Overview of Experiments and Code Validation Efforts for ... <https://nucleus.iaea.org/sites/nexshare/Focus%20Group/LMFR%20FG/LMFR%20FG%20%20Background%20Document%20on%20International%20Organization%20Activities.pdf>
19. Grand challenges in advanced nuclear reactor design <https://www.frontiersin.org/journals/nuclear-engineering/articles/10.3389/fnuen.2022.1000754/full>
20. Sodium-Cooled Fast Reactor Thermal Hydraulics <https://www.ans.org/meetings/am2022/session/view-1246/>
21. A summary of sodium-cooled fast reactor development <https://www.sciencedirect.com/science/article/abs/pii/S0149197014001279>
22. IAEA-CN245-133 <https://media.superevent.com/documents/20170618/08563f896931149cdd38cb9ad4223c49/fr17-133.pdf>
23. New Reactor Safety Measures for the European Sodium Fast ... <https://pmc.ncbi.nlm.nih.gov/articles/PMC8641943/>
24. Full article: Design of Experiments to Support VTR Core ... <https://www.tandfonline.com/doi/full/10.1080/00295639.2022.2043540>
25. International Conference on Fast Reactors and Related Fuel ... <https://conferences.iaea.org/event/218/timetable/?print=1&view=standard>
26. BN-600 AND BN-800 OPERATING EXPERIENCE https://www.gen-4.org/gif/upload/docs/application/pdf/2019-01/gifiv_webinar_pakhomov_19_dec_2018_final.pdf
27. Codes of new generation for safety justification of power ... <https://nucet.pensoft.net/article/54710/>
28. Overview of the system alone and system/CFD coupled ... https://www.researchgate.net/publication/271225878_Overview_of_the_system_alone_and_systemCFD_coupled_calculations_of_the_PHENIX_Natural_Circulation_Test_within_the_THINS_project
29. Preliminary Experimental Validation of Single-Phase ... <https://www.mdpi.com/2673-4362/7/3/45>
30. Operational and decommissioning experience with fast reactors https://www-pub.iaea.org/MTCD/Publications/PDF/te_1405_web.pdf

31. Safety and proliferation resistance of small-sized sodium- ... https://www.aesj.net/document/pnst007/data/338_344.pdf
32. Status of Fast Reactor Research and Technology Development https://www-pub.iaea.org/MTCD/Publications/PDF/TE_1691_CD/PDF/IAEA-TECDOC-1691.pdf
33. IAEA concludes research project on fast reactor safety <https://www.neimagazine.com/news/iaea-concludes-research-project-on-fast-reactor-safety-5924019/>
34. Sodium cooled fast reactors development and operating ... <https://inis.iaea.org/records/sj4mx-sqk70>
35. Disposition Options for a Sodium Cooled Fast Reactor https://inldigitallibrary.inl.gov/sites/sti/sti/Sort_26562.pdf
36. Advanced reactor safety https://www.oecd-neo.org/jcms/pl_39897/advanced-reactor-safety
37. Experimental Facilities for Sodium Fast Reactor Safety ... https://www.oecd-neo.org/jcms/pl_14592/experimental-facilities-for-sodium-fast-reactor-safety-studies?details=true
38. Status Report on Fuel Safety Implications of Extended ... [https://one.oecd.org/document/NEA/CSNI/R\(2023\)4/en/pdf](https://one.oecd.org/document/NEA/CSNI/R(2023)4/en/pdf)
39. Strategic Roadmap for Nuclear Reactor Safety Research https://www.oecd-neo.org/upload/docs/application/pdf/2025-10/7738_nea_strategic_safety_research_roadmap_publication_2025-10-20_16-46-2_313.pdf
40. Advanced Nuclear Reactor Safety Issues and Research ... https://www.oecd.org/content/dam/oecd/en/publications/reports/2002/05/advanced-nuclear-reactor-safety-issues-and-research-needs_g1gh29d5/9789264194441-en.pdf
41. Overview of Section III, Division 5 <https://www.nrc.gov/docs/ML2120/ML21200A072.pdf>
42. Comparison of lifetime assessments between ASME and ... <https://www.sciencedirect.com/science/article/abs/pii/S0029549322003399>
43. ASME Section III, Division 5, High Temperature Reactors https://inldigitallibrary.inl.gov/sites/sti/sti/Sort_65172.pdf
44. Reliability and Integrity Management Scoping Study <https://www.osti.gov/servlets/purl/2203928>
45. Achats normes ASME BPVC 2025 Section III Division 5 <https://www.boutique.afnor.org/fr-fr/norme/asme-bpvc-2025-section-iii-division-5/as781/447336>
46. ASME Division 5: High Temp Reactor Codes | PDF <https://www.scribd.com/document/835106798/1-Div-5-Overview-Sham-rev>

47. ASME Boiler & Pressure Vessel Code (BPVC), Section III ... <https://www.madcad.com/store/package/ASME-BPVC-III-5/>
48. Analysis of the ASME Code Rules for Subsection III-5-HHB ... <https://info.ornl.gov/sites/publications/Files/Pub216010.pdf>
49. 2017 Asme Boiler And Pressure Vessel Code Bpvc ... <https://foleyfamilymedicine.com/archive/uOBEEELK1K0R7/2017-Asme-Boiler-And-Pressure-Vessel-Code-Bpvc-2017>
50. Small Liquid Metal Cooled Reactor Safety Study <http://large.stanford.edu/courses/2017/ph241/tesfai1/docs/ucrl-tr-217093.pdf>
51. How to Validate Impulse Turbine Stage Work Using Energy ... <https://eureka.patsnap.com/report-how-to-validate-impulse-turbine-stage-work-using-energy-balance>
52. Verification and Validation of Model-Scale Turbine ... <https://www.mdpi.com/1996-1073/15/20/7649>
53. Validation of an Integrated Simulation Method with High- ... <http://publications.isope.org/jowe/jowe-01-1/JOWE-01-1-p030-arr01-Kaufer.pdf>
54. Empirical Validation and Uncertainty Characterization for ... <https://www.energy.gov/sites/default/files/2021-09/bto-peer-2021-empirical-validation-uncertainty-characterization.pdf>
55. (PDF) Modeling, Validation, and Control of the IEA – 15 MW ... https://www.researchgate.net/publication/403560247_Modeling_Validation_and_Control_of_the_IEA-15_MW_Reference_Wind_Turbine_and_VolturnUS-S_Platform
56. IEC and IEEE GFM Standardization Efforts https://www.esig.energy/attachment/serve/ieee-iec_joint_standard_esig_spring_2026
57. Enverus PRISM – complex energy data into fast, confident ... <https://www.enverus.com/products/prism/>
58. Integrated finite element models for aeroelastic analysis ... <https://www.ijirss.com/index.php/ijirss/article/view/5033>
59. Publications – Griffith Group <https://labs.utdallas.edu/griffith/publications/>
60. A purely analytical and physical wind turbine wake model ... <https://arxiv.org/html/2510.17236v1>
61. Mastering the technology of fast reactors with liquid-metal ... <https://nucet.pensoft.net/article/182046/>
62. Inside Russia's BN-800 sodium cooled fast reactor at the ... <https://www.facebook.com/iaeaorg/posts/inside-russias-bn-800-sodium-cooled-fast-reactor-at-the-beloyarsk-nuclear-power-/10155955193972062/>

63. IAEA-CN-245-405 THE BN-800 CORE WITH MOX FUEL <https://media.superevent.com/documents/20170620/11795dbfab998cf38da0ea16b6c3181/fr17-405.pdf>
64. BN-800 reactor https://en.wikipedia.org/wiki/BN-800_reactor
65. BN-800 reactor is fully loaded with MOX fuel - IPFM Blog https://fissilematerials.org/blog/2022/09/bn-800_reactor_is_fully_l.html
66. BN-800 – HISTORY AND PERSPECTIVE <https://www.osti.gov/etdeweb/servlets/purl/20236635>
67. BN-800 design validation and construction status https://www.researchgate.net/publication/245238325_BN-800_design_validation_and_construction_status
68. Russia's BN-800 Reactor Enters Commercial Operation <https://neutronbytes.com/2016/11/05/russias-bn-800-reactor-enters-commercial-operation/>
69. Ultrasonic monitoring system tested for BN-800 reactor core <https://www.world-nuclear-news.org/articles/ultrasound-tested-for-monitoring-bn-800-reactor-core>
70. Pages - Fuel Materials for Fast Reactors (FMFR) <https://nucleus.iaea.org/sites/connect/NFEpublic/Pages/FMFR.aspx>
71. Expert Group on Physics of Reactor Systems (EGPRS) https://www.oecd-neo.org/jcms/c_12860/expert-group-on-physics-of-reactor-systems-egprs
72. IAEA-CN245-360 Overview of the international cooperation ... <https://media.superevent.com/documents/20170620/88994326a1a193bc56522c5eb3cbc4b3/fr17-360.pdf>
73. OECD/NEA/CSNI/WGAMA PERSEO benchmark <https://www.sciencedirect.com/science/article/abs/pii/S0029549323000699>
74. Overview of Fast Reactor Activities in NEA https://esfr-smart.eu/wp-content/uploads/2021/04/S1_6_Tatiana_IVANOVA_NEA_ESFR_Smart_Spring_School_29_March_2021.pdf
75. Engagement opportunities in OECD NEA benchmark ... <https://www.frontiersin.org/journals/energy-research/articles/10.3389/fenrg.2023.1085764/full>
76. [PDF] IAEA TECDOC SERIES <https://www-pub.iaea.org/MTCD/Publications/PDF/TE-1902web.pdf>
77. [PDF] Safeguarding Commercial Breed and Burn Sodium-Cooled Fast ... <https://www.osti.gov/servlets/purl/1971524>
78. Advanced Nuclear Reactor Safety Issues and Research ... <https://www.oecd-neo.org/upload/docs/application/pdf/2019-12/3613-advanced-safety-issues.pdf>
79. Regulatory Perspectives on Analytical Codes and Methods ... <https://www.oecd-neo.org/upload/docs/application/pdf/>

2025-06/7617_regulatory_perspectives_on_analytical_codes_and_methods_for_advanced_reactors.pdf

80. 3.18 reactor physics tests for the joyo mk-111 start-up core <https://www.osti.gov/etdeweb/servlets/purl/20531351>
81. Analysis of Control Rod Worth in Experimental Fast Reactor <https://inis.iaea.org/records/81k71-ec280/files/22016792.pdf?download=1>
82. COMPUTING CONTROL ROD WORTHS IN THERMAL ... - rertr <https://www.rertr.anl.gov/METHODS/TM29.pdf>
83. Control rod worth calculations using deterministic and ... https://www.researchgate.net/publication/260227692_Control_rod_worth_calculations_using_deterministic_and_stochastic_methods
84. Lead-cooled Fast Reactor Benchmark (LFR) https://www.oecd-nea.org/jcms/pl_66836/lead-cooled-fast-reactor-benchmark-lfr
85. [PDF] OECD/NEA Data Bank Scientific And Integral Experiments ... <https://www.osti.gov/servlets/purl/911061>
86. [PDF] Nuclear Reactors - INIS-IAEA <https://inis.iaea.org/records/80ycb-v5j86/files/49059928.pdf>
87. [PDF] Sodium Coolant Handbook: Thermal Hydraulic Correlations https://www-pub.iaea.org/MTCD/publications/PDF/CRCP_SOD_003web.pdf
88. [PDF] IAEA TECDOC SERIES <https://www-pub.iaea.org/MTCD/Publications/PDF/TE-1978web.pdf>
89. Overview on Lead-Cooled Fast Reactor Design and Related ... - MDPI <https://www.mdpi.com/1996-1073/14/16/5157>
90. The International Conference on Fast Reactors and Related Fuel ... <https://www.facebook.com/iaeaorg/posts/the-international-conference-on-fast-reactors-and-related-fuel-cycles-begins-on-/1442168804619332/>
91. [PDF] Joint NEA – IAEA International Symposium on Probabilistic Safety ... https://www.oecd-nea.org/upload/docs/application/pdf/2026-06/nea_csni_r2024_3.pdf
92. Enhancing fuel breed-burn performance in a sodium ... <https://www.sciencedirect.com/science/article/abs/pii/S014919702400386X>
93. Feasibility of Sodium-Cooled Breed-and-Burn Reactor with ... <https://www.tandfonline.com/doi/full/10.1080/00295639.2021.1951063>
94. Fast Neutron Reactors: From Core Physics to New Opportunities <http://large.stanford.edu/courses/2026/ph241/marchioni1/>
95. Heterogeneous Transmutation Sodium Fast Reactor https://digital.library.unt.edu/ark:/67531/metadc896710/m2/1/high_res_d/920415.pdf

96. System features of fast sodium reactors in a two ... <https://nucet.pensoft.net/article/129573/>
97. Status of Fast Reactor Research and Technology Development https://www-pub.iaea.org/MTCD/Publications/PDF/te_1691_web.pdf
98. FAST NEUTRON REACTORS <https://www.xylenepower.com/Fast%20Neutron%20Reactors.htm>
99. Neutron Flux Reactor Interactive Calculator https://www.firgelliauto.com/blogs/calculators/neutron-flux-reactor-calculator?srsId=AU7gw4Xy6pLPnu2soCuMTNtI-lvxKRbXnLaMFSp5qs7hE2NGdMApSRH_
100. [PDF] acceptability of asme code, section iii, division 5, “high temperature ... <https://www.nrc.gov/docs/ML2517/ML25176A084.pdf>
101. ASME BPVC III.5: Nuclear Components 2023 | PDF | Patent - Scribd <https://www.scribd.com/document/935950694/Asme-Bpvc-2023-Section-III-Div-5>
102. 2023 Edition of the American Society of Mechanical Engineers ... <https://www.regulations.gov/document/NRC-2020-0029-0001>
103. REGDOC-2.5.2, Design of Reactor Facilities, Version 2 <https://www.cnsccsn.gc.ca/eng/acts-and-regulations/regulatory-documents/published/html/regdoc2-5-2-v2/>
104. New regulatory pathway for advanced nuclear components <https://www.facebook.com/umichNERS/posts/new-regulatory-and-design-pathway-informally-known-as-class-b-new-code-approach-/1616198660509201/>
105. 10 CFR Part 50 -- Domestic Licensing of Production and Utilization ... <https://www.ecfr.gov/current/title-10/chapter-I/part-50>
106. [PDF] Vessel Code Comparison EN 13445 - ASME VIII Div.1 <https://www.energy.gov/sites/default/files/2024-08/Report%20-%20EN%2013445%20ASME%20VIII%20Div.1%20Comparison.pdf>
107. [PDF] Ended Guillotine Break Requirements: Evidence- Based Analysis of ... https://inl.gov/content/uploads/2026/02/INLRPT_26-90155_DEGB-Technical-Assessment.pdf
108. Phenomena identification and ranking table of station blackout ... <https://www.sciencedirect.com/science/article/abs/pii/S030645492100116X>
109. [PDF] Thermal Hydraulic Experimental Test Article – Fiscal Year 2022 ... <https://publications.anl.gov/anlpubs/2022/10/178800.pdf>
110. Publications | Project FAST | PSI - Paul Scherrer Institut <https://www.psi.ch/en/fast/publications>
111. [PDF] Sodium Coolant Properties and Experience - Idaho State University <https://www.isu.edu/media/libraries/college-of-science-and-engineering/nuclear-engineering/documents/Sodium-Properties-Experience-and-Safety.pdf>

112. (PDF) Research Progress in Key Thermal-hydraulic Issue of Sodium ... https://www.researchgate.net/publication/402392306_Research_Progress_in_Key_Thermal-hydraulic_Issue_of_Sodium-cooled_Fast_Reactor
113. [PDF] Core Design and Thermal Hydraulic Technical Report <https://www.nrc.gov/docs/ML2408/ML24088A085.pdf>
114. [PDF] Verification and Validation Activities of Molten Salt Reactors ... https://inldigitallibrary.inl.gov/sites/STI/STI/Sort_85068.pdf
115. BN-800 reactor is a new stage in transition to ... - INIS-IAEA <https://inis.iaea.org/records/wdpyk-p6578>
116. BN-800: A key part of Russia's nuclear strategy https://www.researchgate.net/publication/298624973_BN-800_A_key_part_of_Russia's_nuclear_strategy
117. How does a fast neutron reactor work? Take a closer look ... <https://www.facebook.com/rosatomasia/videos/%EF%B8%8F-how-does-a-fast-neutron-reactor-worktake-a-closer-look-at-the-bn-800-a-next-ge/1915144995695923/>
118. Study of Key Parameters and Uncertainties Based on ... <https://www.mdpi.com/2071-1050/15/23/16266>
119. Enhanced turbine monitoring using emissions ... <https://www.sciencedirect.com/science/article/am/pii/S0306261916304871>
120. Piecewise exact solution of the seismic energy balance ... https://www.researchgate.net/publication/360086174_Piecewise_exact_solution_of_the_seismic_energy_balance_equation_and_its_verification_by_shake_table_tests
121. Application of Reengineering Techniques for Analyzing the ... <https://jemsjournal.org/pdf/17d041fe-057c-4c8e-a75d-948e33c0152a/articles/jems.2026.60973/110-123.pdf>
122. Analysis and calibration of optimal power balance rotor- ... <https://wes.copernicus.org/preprints/wes-2024-158/wes-2024-158-manuscript-version3.pdf>
123. Integrated condition monitoring of a fleet of offshore wind ... <https://www.vliz.be/imisdocs/publications/314137.pdf>
124. Verification and Validation of Model-Scale Turbine ... <https://psecommunity.org/wp-content/plugins/wpor/includes/file/2302/LAPSE-2023.8806-1v1.pdf>
125. System for Generating Electric Power by the Sail Wind ... https://www.espublisher.com/uploads/article_pdf/ee1637.pdf
126. WGAMA PERSEO Benchmark Results Report https://www.oecd-nea.org/jcms/pl_97018/wgama-perseo-benchmark-results-report?details=true
127. WGAMA PERSEO Benchmark Results Report <https://www.oecd-nea.org/nsd/docs/2021/csni-r2021-2-add.pdf>

128. OECD-NEA Activities and Joint Projects https://nucleus.iaea.org/sites/nexshare/Past%20Events%20Materials/NEXSHARE%20Workshop_1st_202406/Day1/10%20-%20M.Adorni_Advancing%20SMR%20safety%20through%20safety%20assessment%20and%20validation%20of%20computer%20codes%20-%20OECD-NEA%20Activities%20and%20Joint%20Projects.pdf
129. CSNI Technical Opinion Paper No. 21 (EN) https://www.oecd.org/content/dam/oecd/en/publications/reports/2023/10/csni-technical-opinion-paper-no-21_b4fb0e0d/0df32944-en.pdf
130. OECD/NEA/CSNI/WGAMA PERSEO benchmark <https://ui.adsabs.harvard.edu/abs/2023NuEnD.40512220M/abstract>
131. Thermal hydraulic code validation benchmark for high ... https://www.oecd-nea.org/jcms/pl_71708/thermal-hydraulic-code-validation-benchmark-for-high-temperature-gas-cooled-reactors-using-httpf-data-htgr-t/h
132. Pages - Publication Database - Nucleus <https://nucleus.iaea.org/sites/fr/Pages/Publication-database.aspx>
133. Benchmark for Neutronic Analysis of Sodium-cooled Fast ... https://www.researchgate.net/publication/296676448_Benchmark_for_Neutronic_Analysis_of_Sodium-cooled_Fast_Reactor_Cores_with_Various_Fuel_Types_and_Core_Sizes
134. Benchmark for Neutronic Analysis of Sodium-cooled Fast ... <https://inis.iaea.org/records/q5mcn-7gg40>
135. Analysis of Fuel Burnup and Transmutations at High Burnup of ... https://www.researchgate.net/publication/366025296_Analysis_of_Fuel_Burnup_and_Transmutations_at_High_Burnup_of_Sodium_Fast_Breeder_Reactor
136. Benchmark for Neutronic Analysis of Sodium-cooled Fast ... <https://www.oecd-nea.org/upload/docs/application/pdf/2020-01/nsc-r2015-9.pdf>
137. IAEA Concludes Four-year Research Project on Fast Reactor ... <https://www.iaea.org/newscenter/news/iaea-concludes-four-year-research-project-on-fast-reactor-safety-features>
138. Optimization of reactivity control in a small modular sodium-cooled ... <https://www.sciencedirect.com/science/article/pii/S1738573319306503>
139. Sodium-cooled fast reactors (SFRs) - Book chapter - IOPscience <https://iopscience.iop.org/book/mono/978-0-7503-6069-2/chapter/bk978-0-7503-6069-2ch11>
140. [PDF] The Industrial Sodium Cooled Fast Reactor - INL Digital Library <https://inldigitallibrary.inl.gov/sites/sti/sti/4363828.pdf>

141. [PDF] ANNUAL REPORT - the Generation IV International Forum https://www.gen-4.org/gif/upload/docs/application/pdf/2016-06/gif_2015_annual_report_-_final_e-book.pdf
142. [PDF] Fast reactors and related fuel cycles : safe technologies and ... <https://www-pub.iaea.org/MTCD/Publications/PDF/Pub1665Vol1Web-68441300.pdf>
143. [PDF] Use of Reprocessed Uranium https://www-pub.iaea.org/MTCD/publications/PDF/TE_1630_CD/PDF/IAEA-TECDOC-1630.pdf
144. [PDF] Advanced Structural Materials for High Temperature Reactor ... <https://www.nrc.gov/docs/ML2526/ML25261A140.pdf>
145. Design of type 316L stainless steel 700 °C high-temperature piping <https://www.sciencedirect.com/science/article/pii/S1738573323002851>
146. [PDF] IAEA Nuclear Energy Series Fatigue Assessment in Light Water ... https://www-pub.iaea.org/MTCD/Publications/PDF/PUB2017_web.pdf
147. Fuel, coolant, cladding, and structure—materials dictate reactor ... <https://www.facebook.com/metallurgist007/posts/fuel-coolant-cladding-and-structurematerials-dictate-reactor-performanceindias-p/939259761820500/>
148. [PDF] FOR-868 Microreactor Applications Research Validation and ... https://inldigitallibrary.inl.gov/sites/sti/sti/Sort_110881.pdf
149. [PDF] Kairos Power, LLC - KP-FHR Metallic Material Qualification Topical ... <https://www.nrc.gov/docs/ML2310/ML23102A179.pdf>
150. [PDF] A Comparative Evaluation and Selection of High-Temperature Heat ... https://inldigitallibrary.inl.gov/content/uploads/50/2026/04/Sort_68426.pdf
151. [PDF] API 521 9th Edition Ballot https://eballotprodstorage.blob.core.windows.net/eballotscontainer/521_e9-WI_11-20250610.pdf
152. [PDF] NDT Handbooks Vol. 8 Magnetic Testing - IPGM – Servicios <https://www.ipgmservicios.com/wp-content/uploads/2024/03/ASNT-NDT-Handbooks-Vol.-8-Magnetic-Testing-I.pdf>
153. Thermal-hydraulic modeling of CAREM-25 advanced small modular ... <https://www.sciencedirect.com/science/article/pii/S1738573323005636>
154. Full article: Modeling of Safety Basis Events in the VTR <https://www.tandfonline.com/doi/full/10.1080/00295639.2022.2053487>
155. Micro long-life lead-bismuth-cooled fast reactor - Frontiers <https://www.frontiersin.org/journals/energy-research/articles/10.3389/fenrg.2022.965319/full>
156. [PDF] Numerical analysis of dynamic load following response in a natural ... <https://www.osti.gov/servlets/purl/1959776>

157. [PDF] 1. Summary - the Generation IV International Forum <https://www.gen-4.org/sites/default/files/2024-07/2018%20RSWG%20Supercritical-water-cooled%20reactor%20system%20%28SCWR%29%20System%20Safety%20Assessment%20%282018%29.pdf>
158. Thermal hydraulic modeling needs for LWR-SMRs. OECD/NEA ... https://www.researchgate.net/publication/373108296_Thermal_hydraulic_modeling_needs_for_LWR-SMRs_OECDNEACSNI_Specialists_Meeting_on_Transient_Thermal-hydraulics_in_Water_Cooled_Nuclear_Reactors_SM-TH
159. Evaluation of OECD/NEA/WPRS benchmark on medium size ... <https://inis.iaea.org/records/hh942-se365>
160. OECD/NEA Data Bank Scientific And Integral Experiments ... <https://inldigitallibrary.inl.gov/sites/sti/sti/3169776.pdf>
161. Evaluation of the OECD/NEA/SFR-UAM Neutronics Reactivity ... <https://inis.iaea.org/records/rc32s-sq984>
162. Nuclear Energy Agency (NEA) - Subgroup on Uncertainty ... https://www.oecd-neo.org/jcms/pl_20438/subgroup-onuncertainty-analysis-in-modelling-uam-for-design-operation-and-safety-analysis-of-sodium-cooled-fast-reactors-sfr-uam
163. Nuclear Energy Agency (NEA) - Regulatory Perspectives on ... https://cms.oecd-neo.org/jcms/pl_60806/regulatory-perspectives-on-safety-aspects-related-to-advanced-sodium-fast-reactors-part-2-neutronics-and-criticality-safety-of-sodium-fast-reactors?details=true
164. Annual meeting of the OECD/NEA Fluoride Salt-Cooled High ... https://www.oecdnea.org/upload/docs/application/pdf/2025-05/announcement-programme-sfr-uam-10_v1.pdf
165. Evaluation of the OECD/NEA/SFR-UAM Neutronics Reactivity ... https://www.researchgate.net/publication/328174689_Evaluation_of_the_OECDNEASFR-UAM_Neutronics_Reactivity_Feedback_and_Uncertainty_Benchmarks
166. Benchmark for Neutronic Analysis of Sodium-cooled Fast ... <https://tdb.oecd-neo.org/upload/docs/application/pdf/2020-01/nsc-r2015-9.pdf>
167. A New Calculation Approach to the Energy Balance of a ... https://www.researchgate.net/publication/267499574_A_New_Calculation_Approach_to_the_Energy_Balance_of_a_Gas_Turbine_Including_a_Study_of_the_Impact_of_the_Uncertainty_of_Measured_Parameters
168. Analysis and calibration of optimal power balance rotor- ... <https://wes.copernicus.org/articles/10/987/2025/wes-10-987-2025.pdf>
169. World Energy Balances https://iea.blob.core.windows.net/assets/2144706e-a521-4353-a9c0-2ff3b170669f/WORLDBAL_Documentation_July2025.pdf

170. Decommissioning Nuclear Facilities <https://world-nuclear.org/information-library/nuclear-fuel-cycle/nuclear-waste/decommissioning-nuclear-facilities>
171. Blue Capsule Technology's Post - LinkedIn https://www.linkedin.com/posts/bluecapsule-technology_what-is-elise-and-why-does-it-matter-building-activity-7485310161138515968-0hHi
172. Technical Review and Status of Small Modular Reactor Technologies <https://www.mdpi.com/1996-1073/18/7/1862>
173. The World Nuclear Industry Status Report 2024 (HTML) <https://www.worldnuclearreport.org/The-World-Nuclear-Industry-Status-Report-2024-HTML>
174. [PDF] Mineral Commodity Summaries 2026 - USGS Publications Warehouse <https://pubs.usgs.gov/periodicals/mcs2026/mcs2026.pdf>
175. China plans to fire up world-first accelerator-driven nuclear reactor ... https://www.reddit.com/r/Futurology/comments/1rm9qe7/1000year_source_china_plans_to_fire_up_worldfirst/
176. References - LGI Sustainable Innovation <https://www.lgi.earth/references>
177. [PDF] World Silver Survey 2026 <https://silverinstitute.org/wp-content/uploads/2026/04/World-Silver-Survey-2026.pdf>
178. [PDF] 2025 EFRC-HUBS-CMS-CCS PI MEETING - DOE Office of Science <https://science.osti.gov/-/media/bes/efrc/pdf/PI-Meetings/2025-EFRC-Hub-CMS-CCS-PI-Meeting-Program-Book.pdf>
179. [PDF] Brent Fultz <https://www.its.caltech.edu/~matsci/btf/BrentFultzCV.pdf>
180. [PDF] Assessment of Nuclear Energy Systems based on a Closed Nuclear ... https://www-pub.iaea.org/MTCD/Publications/PDF/TE_1639_Rev1_web.pdf
181. [PDF] Fast Breeder Reactor Programs: History and Status <https://fissilematerials.org/library/rr08.pdf>
182. [PDF] Initial Evaluation of Fuel-Reactor Concepts for Advanced LEU Fuel ... https://inldigitallibrary.inl.gov/sites/sti/sti/Sort_22041.pdf
183. Review of thorium-containing fuels in LWRs - ScienceDirect.com <https://www.sciencedirect.com/science/article/pii/S0149197024000866>
184. [PDF] Burnable Absorbers in Nuclear Reactors - A Review - OSTI <https://www.osti.gov/servlets/purl/1908247>
185. [PDF] tecdoc 1356 https://www-pub.iaea.org/MTCD/Publications/PDF/te_1356_web.pdf
186. [PDF] Research Needs for Fusion-Fission Hybrid Systems - The FIRE Place https://fire.pppl.gov/Hybrid_Report_Final.pdf
187. [PDF] Fast Breeder Reactor Programs: History and Status <http://large.stanford.edu/courses/2011/ph241/dunn1/docs/rr08.pdf>

188. [PDF] Proceedings of Advances in Reactor Physics 2022 - BARC <https://www.barc.gov.in/symposium/arp2022/proceedings.pdf>
189. Analysis on thermal hydraulic characteristics for PHENIX ... <https://www.sciencedirect.com/science/article/pii/S0149197024003202>
190. Calculation and experimental substantiation of thermal ... https://www.researchgate.net/publication/389534730_Calculation_and_experimental_substantiation_of_thermal-hydraulic_characteristics_for_the_emergency_cooldown_system_of_BN-800_reactor
191. Calculation and experimental substantiation of thermal ... <https://link.springer.com/article/10.1007/s10512-025-01182-3>
192. Testing of sodium-heated steam generator models at SSC RF ... <https://link.springer.com/content/pdf/10.1007/s10512-025-01216-w.pdf>
193. Multi-physics models for design basis accident analysis of ... <https://www.sciencedirect.com/science/article/pii/S0029549318302073>
194. Calculation and experimental substantiation of thermal-hy ... <https://rd.springer.com/content/pdf/10.1007/s10512-025-01182-3.pdf>
195. (PDF) HYDRA-IBRAE/LM/V1 Thermohydraulic Code Verification ... https://www.researchgate.net/publication/319645780_HYDRA-IBRAELMV1_Thermohydraulic_Code_Verification_Based_on_BN-600_Experiments
196. OPERATING EXPERIENCE OF THE BN-800 REACTOR CORE <https://conferences.iaea.org/event/436/contributions/38850/attachments/22649/39335/FR26-269.pdf>
197. OPERATING EXPERIENCE OF THE BN-800 REACTOR CORE https://conferences.iaea.org/event/436/contributions/38850/attachments/22649/41631/FR26-269_Presentation.pdf
198. BN800 | PDF | Nuclear Power Plant | Nuclear Reactor <https://www.scribd.com/document/1006809790/BN800>
199. BN-800 reactor — Grokipedia https://grokipedia.com/page/BN-800_reactor
200. aten13102 - Springer <https://link.springer.com/content/pdf/10.1007/s10512-022-00838-8.pdf>
201. [PDF] Lead-cooled Fast Reactor (LFR) System Safety Assessment <https://www.gen-4.org/sites/default/files/2024-07/2020%20RSWG%20GIF%20LFR%20SSA%20June%202020.pdf>
202. OECD Nuclear Energy Agency Nuclear Science Committee Eighth ... <https://www.oecd-neo.org/upload/docs/application/pdf/2023-05/announcement-programme-sfr-uam-8.pdf>
203. OECD Nuclear Energy Agency - harbor.oecd-neo.org <https://harbor.oecd-neo.org/upload/docs/application/pdf/2023-05/announcement-programme-sfr-uam-8.pdf>

204. Nuclear Energy Agency (NEA) - Eighth NEA Benchmark for ... https://harbor.oecd-nea.org/jcms/pl_81013/eighth-nea-benchmark-for-uncertainty-analysis-in-best-estimate-modelling-uam-for-design-operation-and-safety-analysis-of-sodium-cooled-fast-reactors-announcement-sfr-uam-8?details=true
205. Uncertainty quantification of sodium-cooled fast reactor ... <https://www.sciencedirect.com/science/article/pii/S0306454919300428>
206. Analysis of Th and U breeding in a heat pipe cooled traveling wave ... <https://www.frontiersin.org/journals/energy-research/articles/10.3389/fenrg.2023.1175254/full>
207. Thorium - World Nuclear Association <https://world-nuclear.org/information-library/current-and-future-generation/thorium>
208. Review on sodium corrosion evolution of nuclear-grade 316 ... <https://www.sciencedirect.com/science/article/pii/S1738573321002874>
209. A review of nuclear electric fission space reactor technologies for ... <https://www.sciencedirect.com/science/article/pii/S0149197023002500>
210. Full text of "Bihar District Gazetteers: Shahabad" - Internet Archive https://archive.org/stream/dli.ministry.07467/GR252_djvu.txt
211. Pressurised Water Reactor Main Steam-Line Break (MSLB) ... https://www.oecd-nea.org/jcms/pl_32205/pressurised-water-reactor-main-steam-line-break-mslb-benchmark
212. Analysis of the OECD/NEA PWR Main Steam Line Break ... <https://inis.iaea.org/records/mte00-t3w86>
213. OECD/NEA/CSNI/WGAMA PERSEO benchmark https://www.researchgate.net/publication/369480628_OECDNEACSNIWGAMA_PERSEO_benchmark_Main_outcomes_and_conclusions
214. TRACE/SIMULATE-3K Analysis of the NEA/OECD ... <https://glc.ans.org/nureth-16/data/papers/13418.pdf>
215. NURETH14-612 OECD/NEA MAIN STEAM LINE BREAK ... <https://proceedings.cns-snc.ca/index.php/pcns/article/download/4513/4512>
216. BN-800 fast reactor to reach criticality in April 2014 https://fissilematerials.org/blog/2013/12/bn-800_fast_reactor_to_re.html
217. [PDF] pvp 2023 - ASME Events <https://event.asme.org/Events/media/library/resources/pvp/PVP-2023-Final-Program.pdf>
218. ASME Section III CODE comparsion - pdfcoffee.com <https://pdfcoffee.com/asme-section-iii-code-comparsion-pdf-free.html>
219. [PDF] ARC20-FQ-003, Revision 0.0, "White Paper on ARC-100 Fuel ... <https://www.nrc.gov/docs/ML2332/ML23321A225.pdf>

220. Plant Flare Header Emergency Purge Gas & Thermal Bowing Effect <https://www.facebook.com/groups/380564708786032/posts/2611919682317179/>
221. Mechanical Model for Parabolic Dish Micro Gas Turbines <https://www.mdpi.com/1996-1073/19/5/1188>
222. Enhancing Turbine Performance Degradation Prediction ... <https://papers.phmsociety.org/index.php/phmconf/article/download/2580/1538>
223. Thermal Performance Program Assessment Guideline <https://restservice.epri.com/publicdownload/000000003002005343/0/Product>
224. Modeling and Energy Flow Calculation of Integrated ... <https://journals.riverpublishers.com/index.php/SPEE/article/download/26405/20803/99177>
225. turbine efficiency and power cycle performance https://www.powerinfotoday.com/wp-content/uploads/2017/01/Exergy_Turbine_Powercycleperformance.pdf
226. [PDF] Overview and Update of Sodium Fast Reactor Activities within the ... https://www.gen-4.org/sites/default/files/2024-10/Yoshitaka%20CHIKAZAWA%20GIF%20Webinar%20FINAL%2020%20SEP%202024%20_R1.pdf
227. Fast Reactor Program: Methods, Modeling, and Validation <https://www.anl.gov/nse/frp/methods-and-databases>
228. Calculation of Sodium Cooled Fast Reactor Concepts ... - INIS-IAEA <https://inis.iaea.org/records/fpfae-0yn18>
229. [PDF] Benchmark Study on Innovative Fuels for Fast Reactors with Fuel ... https://www.oecd-neo.org/upload/docs/application/pdf/2023-05/nea_nsc_r_2022_5.pdf
230. [PDF] Analysis of Fuel Burn-up Calculations of 3600 MWth Sodium-cooled ... https://ajnsa.journals.ekb.eg/article_168967_08cc6b2ffa5c35e5f2cec6829bc5c53c.pdf
231. SODIUM-COOLED FAST REACTOR (SFR) RSWG WHITE ... <https://www.gen-4.org/sites/default/files/2024-07/2016%20GIF%20RSWG%20SFR%20White%20Paper.pdf>
232. Survey of Advanced Generation IV Reactor Parameters for ... <https://www.osti.gov/servlets/purl/1782027>
233. Sodium-cooled Fast Reactor (SFR) Benchmark Task Force https://tdb.oecd-neo.org/jcms/pl_46348/sodium-cooled-fast-reactor-sfr-benchmark-task-force
234. DESIGN AND ANALYSIS OF SODIUM-COOLED FAST ... https://docs.lib.purdue.edu/context/open_access_dissertations/article/2996/viewcontent/LinChingSheng.pdf
235. (PDF) Design Considerations for Economically Competitive ... https://www.researchgate.net/publication/228705398_Design_Considerations_for_Economically_Competitive_Sodium_Cooled_Fast_Reactors

236. Sodium-cooled fast reactors (SFR) - Nuclear Energy <https://www.gevernova.com/nuclear/carbon-free-power/sodium-fast-reactors>
237. Numerical investigation on the core thermal hydraulic ... <https://www.frontiersin.org/journals/energy-research/articles/10.3389/fenrg.2024.1439022/full>
238. Nuclear waste more valuable than gold: The BN-800, a ... <https://www.esi-africa.com/industry-sectors/generation/nuclear-waste-more-valuable-than-gold-the-bn-800-a-world-first/>
239. Boiling Water Reactor Turbine Trip (TT) Benchmark Volume I <https://oecd-nea.org/upload/docs/application/pdf/2019-12/nsc-doc2001-1.pdf>
240. Progress in NEA working group analysis of experiment on ... https://www.oecd-nea.org/jcms/pl_108082/progress-in-nea-working-group-analysis-of-experiment-on-multiple-steam-generator-u-tube-rupture
241. Investigation of the OECD/NEA PWR MOX/UO₂ core ... <https://www.osti.gov/biblio/23178701>
242. OECD/NEA and U.S. NRC PWR MOX/UO₂ core ... <https://experts.illinois.edu/en/publications/oecdnea-and-us-nrc-pwr-moxuo-sub2sub-core-transient-benchmark/>
243. [PDF] Regulatory Considerations Regarding Potential High-Temperature ... <https://publications.anl.gov/anlpubs/2023/04/180211.pdf>
244. [PDF] Sodium-Cooled Fast Test Reactors Using Fuel Plates https://inldigitallibrary.inl.gov/sites/sti/sti/Sort_27089.pdf
245. [PDF] BN-600 MOX Core Benchmark Analysis https://www-pub.iaea.org/MTCD/Publications/PDF/TE-1700_web.pdf
246. [PDF] Sodium Fast Reactor Fuels and Materials: Research Needs - OSTI <https://www.osti.gov/servlets/purl/1044975>
247. Survey of Advanced Generation IV Reactor Parameters ... - INFO <https://info.ornl.gov/sites/publications/Files/Pub154541.pdf>
248. Pressurised Water Reactor Main Steam Line Break (MSLB) ... <https://www.oecd-nea.org/upload/docs/application/pdf/2019-12/nsc-doc2003-21.pdf>
249. COMPARATIVE ANALYSIS OF EXERCISE 2 RESULTS OF ... <https://inis.iaea.org/records/wres5-me562/files/38071937.pdf>
250. RELAP5-3D Solutions to Exercise 1 of the OECD-NEA HTTF ... https://inldigitallibrary.inl.gov/content/uploads/50/2026/04/Sort_64815.pdf
251. Beyond Electricity: The Economics of Nuclear Cogeneration https://www.oecd.org/content/dam/oecd/en/publications/reports/2022/07/beyond-electricity_c21e514b/bed3e52c-en.pdf
252. [PDF] Startup Physics Testing of Advanced Reactors - INL Digital Library https://inldigitallibrary.inl.gov/sites/sti/sti/Sort_88374.pdf

253. Control Rod Worth Measurement in Monju Restart Core - INIS-IAEA <https://inis.iaea.org/records/y8erm-km880>
254. Control rod drive mechanism for fast breeder reactor (Journal Article) <https://www.osti.gov/etdeweb/biblio/6315342>
255. Untitled - JOPSS <https://jopss.jaea.go.jp/pdfdata/PNC-TN251-76-28.pdf>
256. On Line Measurement of Reactivity Worth of TRIGA Mark-II ... https://file.scirp.org/Html/14-7500431_7144.htm
257. [PDF] nedo-33091.pdf <http://large.stanford.edu/courses/2017/ph241/barry1/docs/nedo-33091.pdf>
258. Calculation of Control Rods Reactivity Worth of RSG-GAS First Core ... <https://atomindonesia.brin.go.id/index.php/aij/article/view/810>
259. [PDF] Existing Practices for Multi-physics Validation https://www.oecd-neo.org/upload/docs/application/pdf/2022-10/nea_nsc_r_2019_7.pdf
260. [PDF] MORPHEE a multiphysics tool for control rod withdrawal modeling in ... <https://www.sciencedirect.com/science/article/am/pii/S0306454924003876>
261. Thermal-Hydraulics of Water Cooled Nuclear Reactors [1st Edition ... <https://dokumen.pub/thermal-hydraulics-of-water-cooled-nuclear-reactors-1st-edition-9780081006795-9780081006627.html>
262. Neutronics simulation of China Experimental Fast Reactor start-up ... <https://www.sciencedirect.com/science/article/abs/pii/S0029549322003892>
263. [PDF] Superphénix Benchmark Part II: Transient Results - HZDR <https://www.hzdr.de/publications/PublDoc-17142.pdf>
264. Nuclear Data Sensitivity Study for the EBR-II Fast Reactor ... - MDPI <https://www.mdpi.com/2673-4362/2/4/28>
265. [PDF] Advances in fast reactor technology https://www-pub.iaea.org/MTCD/Publications/PDF/te_1015_prn.pdf
266. [PDF] Recommendation for Limiting Conditions for ASME BPVC Section III ... https://inldigitallibrary.inl.gov/sites/sti/sti/Sort_47591.pdf
267. [PDF] Overview of ASME Section III, Division 5, High Temperature Reactors <https://www.osti.gov/servlets/purl/1975270>
268. ASME Section III, Division 5: 2025 Code Updates - Munich Re <https://www.munichre.com/hsb/en/services/engineering/global-inspection/resource-center/pressure-points/25q302.html>
269. A Study on Creep-Fatigue Evaluation of Nuclear Cladded ... - MDPI <https://www.mdpi.com/1996-1073/16/6/2898>
270. [PDF] structural analysis of nuclear safety related components for elevated ... <https://scholarworks.calstate.edu/downloads/q811kt31d>

271. [PDF] Development of In-Service Inspection Rules for Sodium-Cooled Fast ... https://www.gen-4.org/sites/default/files/2024-09/Dr.%20Tayaya-%20GIF%20Webinar%20SEP%2019%20SEP%202022_final.pdf
272. [PDF] KEY CHANGES TO 2021 ASME BOILER CODE EDITIONS (BY ... <https://www.csagroup.org/wp-content/uploads/KEY-CHANGES-TO-2021-BOILER-CODE-CSA-GROUP-FINAL.pdf?srsltid=AU7gw4ViUmyK60gSgAWRdvM9z4Em4GEbnrufQDiidtqwI8jgh3HxFDGU>
273. Objectives and Status of the OECD/NEA sub-group on Uncertainty ... <https://inis.iaea.org/records/aaq3n-5sn02>
274. [PDF] Current Status and Perspectives of the OECD/NEA sub ... - Hal-CEA <https://cea.hal.science/cea-02339103/document>
275. Eighth NEA Benchmark for Uncertainty Analysis in Best-Estimate ... https://www.oecd-nea.org/jcms/pl_81013/eighth-nea-benchmark-for-uncertainty-analysis-in-best-estimate-modelling-uam-for-design-operation-and-safety-analysis-of-sodium-cooled-fast-reactors-announcement-sfr-uam-8?details=true
276. Benchmark for Uncertainty Analysis in Best-Estimate Modelling for ... https://www.oecd-nea.org/jcms/pl_32175/benchmark-for-uncertainty-analysis-in-best-estimate-modelling-for-design-operation-and-safety-analysis-of-light-water-reactors-lwr-uam
277. IAEA-CN245-149 Evaluation of the OECD/NEA/SFR-UAM ... <http://www.aztlanplatform.mx/wp-content/uploads/2018/11/FR17-149.pdf>
278. NEA/NRC Benchmark based on NUPEC BWR Full-size Fine-mesh ... <https://www.oecd-nea.org/science/wprs/egrsltb/BFBT/>
279. OECD/NRC Benchmark based on NUPEC BWR Full-size Fine-mesh ... https://www.oecd-nea.org/jcms/pl_32183/oecd/nrc-benchmark-based-on-nupec-bwr-full-size-fine-mesh-bundle-tests-bfbt
280. NEA Data Bank Nuclear Data Services: JEF(F) Reports https://www.oecd-nea.org/dbdata/nds_eval_jefrep.htm
281. [PDF] NUREG-0800 - Chapter 15, Section 15.4.1, Revision 3, Uncontrolled ... <https://www.nrc.gov/docs/ML0636/ML063600413.pdf>
282. [PDF] IAEA Nuclear Energy Series Design Features and Operating ... https://www-pub.iaea.org/MTCD/Publications/PDF/Pub1585_web.pdf
283. [PDF] A Versatile Coupled Test Reactor Concept - INL Digital Library <https://inldigitallibrary.inl.gov/sites/sti/sti/8059201.pdf>
284. [PDF] The NEA Small Modular Reactor Dashboard: Third Edition https://www.oecd-nea.org/upload/docs/application/pdf/2025-09/web_-_smr_dashboard_-_third_edition.pdf

285. [PDF] 2023 NEA https://www.oecd-neo.org/upload/docs/application/pdf/2024-11/7676_ar_2023.pdf
286. [PDF] Computational Fluid Dynamics for Nuclear Reactor Safety https://na-admin.eventcloud.com/file_uploads/698b61ae15db42ff1c249f298c51f8c1_Book_of_abstracts_v12.pdf
287. [PDF] Nuclear Innovation and Newly Emerging Disruptive Technologies https://www.oecd-neo.org/upload/docs/application/pdf/2025-11/nuclear_innovation_and_newly_emerging_disruptive_technologies__recent_initiatives_by_industry_research_laboratories_and_gove.pdf
288. [PDF] Fast Breeder Reactor Programs: History and Status - ABEN https://aben.org.br/wp-content/uploads/2023/07/Fast_breeder_reactor_programs_History_an.pdf
289. ESFR-SMART Core Safety Measures and Their Preliminary ... <https://asmedigitalcollection.asme.org/nuclearengineering/article/8/1/011322/1120782/ESFR-SMART-Core-Safety-Measures-and-Their>
290. BN-600: 45 Years of Fast Reactor Excellence <https://rosatomnewsletter.com/2025/04/28/bn-600-45-years-of-fast-reactor-excellence/>
291. Progress of Thermal Hydraulic Evaluation Methods and ... http://glc.ans.org/nureth-16/data/papers/keynotepaper_Kamide.pdf
292. PRISM: A competitive small modular sodium-cooled reactor https://www.researchgate.net/publication/282406273_PRISM_A_competitive_small_modular_sodium-cooled_reactor
293. [PDF] PROFILES SUMMARY https://www-pub.iaea.org/MTCD/Publications/PDF/SupplementaryMaterials/P1728/Summary_web.pdf
294. [PDF] 24th National Symposium on Radiation Physics https://isrp.in/wp-content/uploads/2025/04/E-Proceedings_NSRP_compressed.pdf
295. Benchmark on Artificial Intelligence and Machine Learning ... [https://one.oecd.org/document/NEA/WKP\(2023\)1/en/pdf](https://one.oecd.org/document/NEA/WKP(2023)1/en/pdf)
296. announcement-programme-sfr-uam- ... https://www.oecd-neo.org/upload/docs/application/pdf/2025-05/announcement-programme-sfr-uam-10_v1.pdf
297. Design Configurations and Coupling High Temperature Gas ... <https://inldigitallibrary.inl.gov/sites/sti/sti/4027517.pdf>
298. Russian BN-800 breeder has reached criticality - IPFM Blog https://fissilematerials.org/blog/2014/06/russian_bn-800_breeder_re.html
299. Thermal Performance Engineers Handbook, Volume II <https://restservice.epri.com/publicdownload/TR-107422-V2/0/Product>
300. Prioritization of VHTR System Modeling Needs Based on ... <https://publications.anl.gov/anlpubs/2007/08/59659.pdf>

301. [PDF] Use of NEA Database Projects Operating Experience Data ... - OECD [https://one.oecd.org/document/NEA/CSNI/R\(2020\)12/en/pdf](https://one.oecd.org/document/NEA/CSNI/R(2020)12/en/pdf)
302. [PDF] Reactor Pressure Vessel Fluence, DPA, and Uncertainty ... <https://www.nrc.gov/docs/ML2113/ML21137A310.pdf>
303. Nuclear Safety Research Joint Projects https://www.oecdnea.org/jcms/pl_72332/nuclear-safety-research-joint-projects
304. Main features of the BN-800 passive shutdown rods - INIS-IAEA <https://inis.iaea.org/records/tmrf5-h7v75>
305. [PDF] Status of HPRL entries - Nuclear Energy Agency (NEA) https://www.oecd-nea.org/upload/docs/application/pdf/2020-03/hprl_status_feedback_review_2018_cea.pdf
306. Japan abandons Monju fast reactor: the slow death of a nuclear dream <https://theecologist.org/2016/oct/06/japan-abandons-monju-fast-reactor-slow-death-nuclear-dream>
307. MASS: Masked Sequence to Sequence Pre-training for ... <https://arxiv.org/abs/1905.02450>
308. M.A.S.S. Home - M.A.S.S. <https://www.massupt.org/>
309. Mass Formation and its Antidote | Mattias Desmet <https://www.youtube.com/watch?v=KN0G2pHBg18>
310. Midnight Mass | Teaser Trailer | Netflix <https://www.youtube.com/watch?v=89UV8vmWXIY>
311. Where Do Trees Get Their Mass? https://www.youtube.com/watch?v=2KZb2_vcNTg
312. An Introduction to Moles and Molar Mass - AP Chem Unit 1, ... <https://www.youtube.com/watch?v=wynFro1c09k>
313. Gang Starr - Mass Appeal <https://www.youtube.com/watch?v=y9lNbNGbo24>
314. Mass Flourishing https://press.princeton.edu/books/paperback/9780691165790/mass-flourishing?srsId=AU7gw4VREu5AKticDtnfITSf4qpOgKQK395vqULA_R_L8TXbbeV9tZ1v
315. Mass - Official Trailer <https://www.youtube.com/watch?v=WgvsfKhGdgl>
316. Mass Spectrometry <https://www.youtube.com/watch?v=mBT73Pesioq>
317. BASIC DESIGN DATA OF BN REACTORS https://www.researchgate.net/figure/BASIC-DESIGN-DATA-OF-BN-REACTORS_tbl4_351614179
318. MANUFACTURE, INSTALLATION AND ADJUSTMENT OF ... <https://inis.iaea.org/records/xgbhe-2cs85/files/48088104.pdf>
319. Russia BN 600 and BN 800 Mr. Ilya Pakhomov, IPPE, Russia https://gif.jaea.go.jp/webinar/Series24/w24_BN-600_and_BN-800_Operating_Experience.pdf

320. Engineering:BN-800 reactor https://www.handwiki.org/wiki/Engineering:BN-800_reactor
321. Balance Pan-Asian Grille: Fresh Bowls, Tacos & Salads <https://balancegrille.com/>
322. The Golden Balance (@thegoldenbalance) <https://www.tiktok.com/@thegoldenbalance?lang=en>
323. Your Balance Will Continue to Get Worse After 60... Unless ... <https://www.youtube.com/watch?v=Ei7ekehRj6M>
324. Classic Chili Recipe <https://www.budgetbytes.com/basic-chili/>
325. Balance Problems: Causes, Diagnosis & Improvement Tips <https://www.health.harvard.edu/topics/balance>
326. BALANCE (Better Approaches to Lifestyle and Nutrition ... <https://www.cms.gov/priorities/innovation/innovation-models/balance>
327. Meditation For Mental Balance and Grounding <https://www.youtube.com/watch?v=x0nZ1ZLephQ>
328. White Balance is Broken <https://www.youtube.com/watch?v=WADuXiMZxq4>
329. Marry Me Chicken Pasta <https://www.budgetbytes.com/marry-me-chicken-pasta/>
330. How to Create a Balanced Life: 9 Tips to Feel Calm and ... <https://tinybuddha.com/blog/9-tips-to-create-a-balanced-life/>
331. [PDF] Nuclear Energy and Technology <https://nucet.pensoft.net/article/116657/download/pdf/954748>
332. Fundamental and applied investigations of the liquid-metal cooled ... <https://www.sciencedirect.com/science/article/abs/pii/S0029549323001991>
333. [PDF] iaea-tecdoc-2056 <https://www-pub.iaea.org/MTCD/publications/PDF/TE-2056web.pdf>
334. Fast Reactors - INIS-IAEA <https://inis.iaea.org/records/ffj4f-vg543/files/49089593.pdf?download=1>
335. International Benchmark Activity in the Field of Sodium Fast Reactors <https://www.intechopen.com/chapters/76773>