

FIRST NOTIFICATION OF LOSS

Submitted by Harborcrest Community Management, LLC · Broker reference HCM/BT/2026/0502

NOTIFICATION

Reported by:	Thaddeus Oyelowo-Brand
Reporting organisation:	Harborcrest Community Management, LLC
Role:	Community Manager
Email:	t.oyelowo-brand@harborcrestmgmt.example
Telephone:	+1 360 555 0244
Date reported:	5 May 2026

POLICY

Policy number:	
Insured name:	Bayview Terrace Condominium Association, Inc.
Insured organisation:	Bayview Terrace Condominium Association, Inc.
Policy type:	Not stated — the association's insurance file is incomplete
Period of cover:	Not stated on the notice

CLAIMANT

Claimant name:	Bayview Terrace Condominium Association, Inc.
Claimant contact:	Cordelia Nakamura-Whitfield, Board President
Claimant email:	c.nakamura-whitfield@bayviewterracecoa.example

FIRST NOTIFICATION OF LOSS (CONTINUED)

Policy · Bayview Terrace Condominium Association, Inc.

THE LOSS

Date of loss: **2 May 2026**
Time of loss: **between 02:00 and 05:30, discovered 05:35**
Loss location: **1200 Bayview Terrace Drive, Bremerton, WA 98312**
Country: **United States**
Cause of loss: **Escape of water — pitting corrosion failure of a copper hot water riser**

Description of loss:

The 2-inch copper domestic hot water riser in the Building 2 central chase failed at a pinhole that opened into a longitudinal split between the second and third floors. Water discharged into the chase and then into units on all three floors of the west stack and into the ground floor storage rooms. The attending plumber attributes the failure to internal pitting corrosion consistent with the age of the pipe and the association's water chemistry.

Property affected:

Units 2-301, 2-201 and 2-101 uninhabitable; six further units with moderate or minor damage; twelve ground floor storage lockers with owner contents affected in nine; the central chase, corridor flooring on three floors and the stairwell landing; a Building 2 electrical sub-panel

Injuries: **0**
Fatalities: **0**
Business interruption: **No — three households displaced to hotels**
Structural damage: **No**
Environmental exposure: **No**

FINANCIAL

Currency: **USD**
Estimated loss: **697,400**
Repair estimate: **549,000**

ADDITIONAL

Incident reference: **BTC-2026-0502**
Authorities involved: **None**
Potential litigation: **None indicated**