

FIRST NOTIFICATION OF LOSS

Submitted by Ozark Meridian Insurance Partners · Broker reference OMI/CAS/2026/0033

NOTIFICATION

Reported by:	Henrietta Balogun-Sawicki
Reporting organisation:	Ozark Meridian Insurance Partners
Role:	Account Executive
Email:	h.balogun-sawicki@ozarkmeridian.example
Telephone:	+1 816 555 0722
Date reported:	21 May 2026

POLICY

Policy number:	
Insured name:	Cobalt Ridge Utility Contractors, LLC
Insured organisation:	Cobalt Ridge Utility Contractors, LLC
Policy type:	Not stated — multiple placements potentially engaged
Period of cover:	Not stated on the notice

CLAIMANT

Claimant name:	City of Overland Park
Claimant contact:	Solomon Vanterpool-Achike, HSE Director (insured)
Claimant email:	s.vanterpool-achike@cobaltridgeutility.example

FIRST NOTIFICATION OF LOSS (CONTINUED)

Policy · Cobalt Ridge Utility Contractors, LLC

THE LOSS

Date of loss: **19 May 2026**
Time of loss: **09:34 CDT**
Loss location: **2200 block of West Carbondale Avenue, Overland Park, KS 66214**
Country: **United States**
Cause of loss: **Excavation collapse — wall failure beyond the end of the trench box**

Description of loss:

A crew of five was working in an open cut excavation approximately fourteen feet deep replacing a section of vitrified clay sanitary sewer. A trench box was in use for the working section. The north wall failed at a point about six feet beyond the end of the box, where the excavation had been extended to expose an unmarked service lateral. Two employees were partially buried to chest height and were extricated by the crew and by technical rescue.

Property affected:

Approximately 40 feet of public sidewalk and 30 feet of the eastbound kerb lane collapsed; a 4-inch gas service to an adjacent retail centre lost its support; the existing sewer main fractured with an estimated 9,000 gallons discharged; an excavator tipped into the void; a rented compressor and a contractor vehicle lost

Injuries: **3**
Fatalities: **0**
Business interruption: **Yes — nine retail tenants without gas for 31 hours, two restaurants closed**
Structural damage: **Yes — public roadway and sidewalk collapse, City stop work order issued**
Environmental exposure: **Yes — approximately 9,000 gallons of sewage into the storm system**

FINANCIAL

Currency: **USD**
Estimated loss: **1,150,000**
Repair estimate: **584,000**

ADDITIONAL

Incident reference: **CRU-2026-IN-0033**
Authorities involved: **OSHA Region VII; Kansas Department of Health and Environment; Overland Park Police**
Potential litigation: **Yes — counsel retained, OSHA citation exposure**