

FIRST NOTIFICATION OF LOSS

Submitted by Talbot & Rennick Insurance Brokers, Inc. · Broker reference TR/PROP/2025/4471

NOTIFICATION

Reported by:	Diane Whitcomb-Reyes
Reporting organisation:	Talbot & Rennick Insurance Brokers, Inc.
Role:	Account Executive
Email:	d.whitcomb-reyes@talbotrennick.example
Telephone:	+1 410 555 0182
Date reported:	12 January 2026

POLICY

Policy number:	CP-4471-88210
Insured name:	Harborline Cold Storage & Logistics, LLC
Insured organisation:	Harborline Cold Storage & Logistics, LLC
Policy type:	Commercial Property
Period of cover:	1 March 2025 to 1 March 2026

CLAIMANT

Claimant name:	Harborline Cold Storage & Logistics, LLC
Claimant contact:	Nathaniel Osei-Barrow, VP Operations
Claimant email:	n.osei-barrow@harborlinecold.example

FIRST NOTIFICATION OF LOSS (CONTINUED)

Policy CP-4471-88210 · Harborline Cold Storage & Logistics, LLC

THE LOSS

Date of loss: **10 January 2026**
Time of loss: **04:20 EST**
Loss location: **2870 Patapsco Industrial Parkway, Baltimore, MD 21226**
Country: **United States**
Cause of loss: **Ammonia release — weld failure on a liquid ammonia header**

Description of loss:

A welded elbow on the 4-inch liquid ammonia header serving the low-temp evaporators in Rooms 4 to 6 failed overnight. Plant detection alarmed at 04:18 and the refrigeration plant went into automatic shutdown as designed. Ammonia entered the three freezer rooms and the customer-owned product in them is presumed contaminated pending testing. With the plant down, room temperatures rose from -10F to +26F over 31 hours before rental cooling was cut in. A defrost line split as the plant was isolated and thawed, putting water through the engine room and the electrical room housing the compressor drive panels.

Property affected:

Customer-owned frozen product in Rooms 4, 5 and 6; the insured's own stock; two compressor VFD cabinets; approximately 3,600 sq ft of engine room floor; insulated metal panel ceiling in Room 5

Injuries: **0**
Fatalities: **0**
Business interruption: **Yes — Rooms 4 to 6 out of service, rental cooling in place**
Structural damage: **Yes — ceiling panel delamination in Room 5**
Environmental exposure: **Yes — anhydrous ammonia release, HAZMAT attended**

FINANCIAL

Currency: **USD**
Estimated loss: **3,700,000**
Repair estimate: **1,410,000**

ADDITIONAL

Incident reference: **BCFD-2026-001188**
Authorities involved: **Baltimore City Fire Department HAZMAT**
Potential litigation: **None indicated**