

FIRST NOTIFICATION OF LOSS

Submitted by Talbot & Rennick Insurance Brokers, Inc. · Broker reference TR/PROP/2025/4471

NOTIFICATION

Reported by:	Diane Whitcomb-Reyes
Reporting organisation:	Talbot & Rennick Insurance Brokers, Inc.
Role:	Account Executive
Email:	d.whitcomb-reyes@talbotrennick.example
Telephone:	+1 410 555 0182
Date reported:	9 February 2026

POLICY

Policy number:	
Insured name:	Harborline Cold Storage & Logistics, LLC
Insured organisation:	Harborline Cold Storage & Logistics, LLC
Policy type:	Commercial Property
Period of cover:	Not stated on the notice

CLAIMANT

Claimant name:	Harborline Cold Storage & Logistics, LLC
Claimant contact:	Nathaniel Osei-Barrow, VP Operations
Claimant email:	n.osei-barrow@harborlinecold.example

FIRST NOTIFICATION OF LOSS (CONTINUED)

Policy · Harborline Cold Storage & Logistics, LLC

THE LOSS

Date of loss: **1 February 2026**
Time of loss: **discovered 05:50 EST**
Loss location: **419 Delaware Terminal Road, New Castle, DE 19720**
Country: **United States**
Cause of loss: **Freeze — frozen sprinkler branch line**

Description of loss:

A 4-inch wet-pipe sprinkler branch line in the unheated dock canopy above doors 14 to 22 froze and split during an extreme cold event. NWS Wilmington recorded a low of -4F with a 22 mph north-west wind, following three consecutive days below 15F. Standing water covered approximately 31,000 sq ft of the cross-dock floor. Two 480V panels and a motor control centre took water at the base, six dock leveller pits were submerged, and 214 of 640 stored pallets had direct water contact.

Property affected:

31,000 sq ft of cross-dock floor; 340 linear feet by 8 feet of metal building insulation; two 480V distribution panels and one motor control centre; six hydraulic dock levellers; 214 water-affected pallets of which 137 bear third-party customer labels

Injuries: **0**
Fatalities: **0**
Business interruption: **Yes — running out of doors 1 to 13 only, volume diverted to Baltimore**
Structural damage: **No**
Environmental exposure: **No**

FINANCIAL

Currency: **USD**
Estimated loss: **1,240,000**
Repair estimate: **407,130**

ADDITIONAL

Incident reference: **RTI-2026-0447**
Authorities involved: **New Castle County AHJ notified of the sprinkler impairment**
Potential litigation: **None indicated**