

FIRST NOTIFICATION OF LOSS

Submitted by Pemberton Wexler Associates, Inc. · Broker reference PWA/PROP/2025/0022

NOTIFICATION

Reported by:	Anselm Duchamp-Rivera
Reporting organisation:	Pemberton Wexler Associates, Inc.
Role:	Producer
Email:	a.duchamp-rivera@pembertonwexler.example
Telephone:	+1 317 555 0904
Date reported:	29 January 2026

POLICY

Policy number:	CP-6650-11223
Insured name:	Meadowcrest Assisted Living Communities, Inc.
Insured organisation:	Meadowcrest Assisted Living Communities, Inc.
Policy type:	Commercial Property
Period of cover:	1 October 2025 to 1 October 2026

CLAIMANT

Claimant name:	Meadowcrest at Zionsville Operating Co., LLC
Claimant contact:	Otilie Rasmussen-Baptiste, Executive Director
Claimant email:	o.rasmussen-baptiste@meadowcrestal.example

FIRST NOTIFICATION OF LOSS (CONTINUED)

Policy CP-6650-11223 · Meadowcrest Assisted Living Communities, Inc.

THE LOSS

Date of loss: **26 January 2026**
Time of loss: **03:50 EST, discovered 04:15**
Loss location: **1180 North Ford Road, Zionsville, IN 46077**
Country: **United States**
Cause of loss: **Freeze — frozen sprinkler branch line in the east wing attic**

Description of loss:

A wet-pipe sprinkler branch line serving the east wing attic froze and split during an extreme cold event, with NWS Indianapolis recording a low of -11F and wind chills near -30F after four consecutive days below 10F. Water discharged for approximately twenty-five minutes before the riser was closed by facilities staff. Fifty resident rooms across two floors, the east corridor and the main kitchen and servery were affected, and fifty residents were relocated.

Property affected:

11,000 sq ft of attic and ceiling assemblies; 50 resident rooms with ceiling collapse in nine; 180 linear feet of corridor ceiling grid; the main kitchen and servery including two reach-in refrigerators and the dish machine; the nurse call head end; elevator No. 2 pit; one 208V distribution panel

Injuries: **0**
Fatalities: **0**
Business interruption: **Yes — the east wing is out of service and 50 residents relocated**
Structural damage: **No**
Environmental exposure: **No**

FINANCIAL

Currency: **USD**
Estimated loss: **2,900,000**
Repair estimate: **1,840,000**

ADDITIONAL

Incident reference: **ZFD-2026-000188**
Authorities involved: **Zionsville Fire Department; Indiana State Department of Health**
Potential litigation: **None indicated**