

FIRST NOTIFICATION OF LOSS

Submitted by Kettleridge Risk Partners, LLC · Broker reference KRP/HAB/2025/7735

NOTIFICATION

Reported by:	Marcus Adeyemi-Croft
Reporting organisation:	Kettleridge Risk Partners, LLC
Role:	Producer
Email:	m.adeyemi-croft@kettleridgerisk.example
Telephone:	+1 918 555 0347
Date reported:	5 December 2025

POLICY

Policy number:	
Insured name:	Sundale Property Group, LLC
Insured organisation:	Sundale Property Group, LLC
Policy type:	Commercial Property - Habitational
Period of cover:	Not stated on the notice

CLAIMANT

Claimant name:	Windrow Grove Apartments, LP
Claimant contact:	Dale Fontenot-Kimura, Community Manager
Claimant email:	d.fontenot-kimura@sundalepg.example

FIRST NOTIFICATION OF LOSS (CONTINUED)

Policy · Sundale Property Group, LLC

THE LOSS

Date of loss: **21 November 2025**
Time of loss: **02:14 CST**
Loss location: **6120 East 91st Street, Tulsa, OK 74137 — Building K**
Country: **United States**
Cause of loss: **Fire — lint ignition at a clothes dryer**

Description of loss:

Fire started in the enclosed laundry alcove of Unit K-206 at or immediately behind the landlord-provided electric clothes dryer, from lint accumulated in the dryer cabinet and a crushed foil transition duct. It extended into the ceiling assembly and through the dryer vent penetration into a common attic void with no draftstopping at the unit demising lines, then ran east and west above the second and third floors. Forty per cent of the roof structure over the west half was opened for ventilation or consumed.

Property affected:

Units K-206 and K-306 total loss; K-106 heavy water damage with ceiling collapse; K-205, K-207, K-305, K-307 fire extension and overhaul; K-105 and K-107 water damage; the remaining 15 units smoke-affected and de-energised; 2,600 sq ft of charred trusses; radiant heat damage to Building L and two resident vehicles

Injuries: **3**
Fatalities: **0**
Business interruption: **Yes — 24 units out, 47 residents displaced**
Structural damage: **Yes — 2,600 sq ft of roof trusses charred, 40% of the west roof opened**
Environmental exposure: **No**

FINANCIAL

Currency: **USD**
Estimated loss: **2,610,000**
Repair estimate: **2,260,000**

ADDITIONAL

Incident reference: **TFD-2025-0091447**
Authorities involved: **Tulsa Fire Department; Public Service Company of Oklahoma; American Red Cross**
Potential litigation: **None indicated**