GENERAL INSTRUCTIONS

PRELIMINARY GEK-11093

ERRATA SHEET
NUMBER ONE

GP-100
20 TO 200HP
DC ADJUSTABLE SPEED DRIVE SYSTEM

ERRATA SHEET: Affects Preliminary GEK-11093

This errata sheet should be attached inside the front cover and retained as a part of this book.

The instruction book text should be changed in accordance with information contained in this errata sheet. Revised areas of the text are indicated by a star (*).

Under TABLE 2-1 FUNCTION OF CONTROLS AND INDICATORS

Under Control/Indicator column between "Jog Speed Adjust Potentiometer" and "Driver Regulator," add:

*Zero Cal Potentiometer

In the adjacent column beside the "Zero Cal Potentiometer" addition add:

*Provides a means of adjusting the motor speed to zero RPM with zero speed reference input.

To the last sentence in paragraph 4.5.20 add:

*with the speed control set to 0 (fully ccw) adjust the "Zero Cal" adjustment for zero motor shaft RPM.

These instructions do not purport to cover all details or variations in equipment nor to provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the General Electric Company

GENERAL ELECTRIC