AIDCF

AI Data Centre Facilities Assurance Framework

ASSESSMENT METHODOLOGY PRACTITIONER HANDBOOK

Version 1.0

Complete fieldwork procedures, domain playbooks, decision rules and reusable workpapers

Artifact ID: AIDCF-AM-001
Status: Draft for controlled review
Author: Siva Sethumadhavan
Release 2: Practitioner Methodology

Document control

Field	Value
Title	AIDCF Assessment Methodology Practitioner Handbook v1.0
Artifact ID	AIDCF-AM-001
Depends on	AIDCF Manifesto; Core Conceptual Model; AIDCF-003 through AIDCF-008
Control universe	15 domains, 90 families and 360 controls.
Evidence basis	AIDCF-008 evidence classes, quality, sufficiency, conflict and UNKNOWN.
Purpose	Initiate, scope, plan, execute, review, decide, report and reassess AIDCF engagements.
Safety	No hazardous or disruptive testing without explicit authority and competent engineering governance.

Executive thesis

An AIDCF assessment is a controlled chain from decision question to capability, outcomes, boundary, dependencies, controls, failure paths, evidence, critical gates, independent review and bounded decision. The chain is never strengthened by presentation, averaging or automation.

Lifecycle

Initiate → Profile → Scope → Tailor → Plan → Collect → Validate → Assess → Analyse → Gate → Find → Review → Decide → Report → Reassess

A1 Authority and conformance

Apply artifact precedence and declare AM0-AM5 conformance.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Confirm purpose, authority and intended users.	WP-A1-01
2	Declare applicable artifact and profile versions.	WP-A1-02
3	Record professional, legal, safety and confidentiality boundaries.	WP-A1-03
4	Define prohibited claims and exceptions.	WP-A1-04
5	Approve version, repository and record controls.	WP-A1-05
6	Escalate any conflict with constitutional invariants.	WP-A1-06

Outputs

- Approved workpaper and review record.
- Visible limitations, UNKNOWN and decisions.

Quality checks

- No silent deletion or uncontrolled versioning.
- All material statements are traceable.

Escalation and stop criteria

- Pause where authority, safety, evidence custody or competence is unresolved.

A2 Normative requirements

Establish mandatory rules for all assessment work.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Identify Capability Instance and Service Outcomes.	WP-A2-01
2	Declare boundary, state, period and evidence limits.	WP-A2-02
3	Justify applicability and N/A decisions.	WP-A2-03
4	Preserve UNKNOWN and conflicting evidence.	WP-A2-04
5	Evaluate gates before scores.	WP-A2-05
6	Require independent review of material decisions.	WP-A2-06

Outputs

- Approved workpaper and review record.
- Visible limitations, UNKNOWN and decisions.

Quality checks

- No silent deletion or uncontrolled versioning.
- All material statements are traceable.

Escalation and stop criteria

- Pause where authority, safety, evidence custody or competence is unresolved.

A3 Assessment types

Select readiness, design, implementation, operating, resilience, change, incident or continuing assessment.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Define primary decision question.	WP-A3-01
2	Select A0-A5 assurance ceiling.	WP-A3-02
3	Match evidence classes to claim type.	WP-A3-03
4	Identify mandatory gates and scenarios.	WP-A3-04
5	Set method depth by consequence.	WP-A3-05
6	Document excluded higher-level claims.	WP-A3-06

Outputs

- Approved workpaper and review record.
- Visible limitations, UNKNOWN and decisions.

Quality checks

- No silent deletion or uncontrolled versioning.
- All material statements are traceable.

Escalation and stop criteria

- Pause where authority, safety, evidence custody or competence is unresolved.

A4 Roles and independence

Staff the engagement with appropriate authority, competence and separation.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Appoint sponsor and decision authority.	WP-A4-01
2	Assign lead assessor and domain SMEs.	WP-A4-02
3	Assign evidence and quality roles.	WP-A4-03
4	Declare conflicts and safeguards.	WP-A4-04
5	Separate preparation, technical approval and decision.	WP-A4-05
6	Record external specialist reliance.	WP-A4-06

Outputs

- Approved workpaper and review record.
- Visible limitations, UNKNOWN and decisions.

Quality checks

- No silent deletion or uncontrolled versioning.
- All material statements are traceable.

Escalation and stop criteria

- Pause where authority, safety, evidence custody or competence is unresolved.

A5 Competency management

Demonstrate collective competence for the assessed domains.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Map scope to required disciplines.	WP-A5-01
2	Assess qualifications and current experience.	WP-A5-02
3	Assign licensed or authorised judgments correctly.	WP-A5-03
4	Brief team on AIDCF method and evidence rules.	WP-A5-04
5	Track competence gaps and supervision.	WP-A5-05
6	Restrict conclusions where competence is absent.	WP-A5-06

Outputs

- Approved workpaper and review record.
- Visible limitations, UNKNOWN and decisions.

Quality checks

- No silent deletion or uncontrolled versioning.
- All material statements are traceable.

Escalation and stop criteria

- Pause where authority, safety, evidence custody or competence is unresolved.

A6 Lifecycle stage gates

Control progression from authorisation to closeout.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Approve SG0 purpose and authority.	WP-A6-01
2	Approve SG1 capability and scope.	WP-A6-02
3	Approve SG2 plan, safety and evidence.	WP-A6-03
4	Confirm SG3 fieldwork completeness or limitations.	WP-A6-04
5	Complete SG4 technical and SG5 independent review.	WP-A6-05
6	Approve SG6 decision and SG7 archive.	WP-A6-06

Outputs

- Approved workpaper and review record.
- Visible limitations, UNKNOWN and decisions.

Quality checks

- No silent deletion or uncontrolled versioning.
- All material statements are traceable.

Escalation and stop criteria

- Pause where authority, safety, evidence custody or competence is unresolved.

A7 Quality management

Make assessments reproducible, reviewable and resistant to unsupported claims.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Define workpaper identifiers and review conventions.	WP-A7-01
2	Track open points, conflicts and deviations.	WP-A7-02
3	Perform evidence-to-assertion traces.	WP-A7-03
4	Perform finding-to-decision traces.	WP-A7-04
5	Retain review comments and resolutions.	WP-A7-05
6	Issue conformance report.	WP-A7-06

Outputs

- Approved workpaper and review record.
- Visible limitations, UNKNOWN and decisions.

Quality checks

- No silent deletion or uncontrolled versioning.
- All material statements are traceable.

Escalation and stop criteria

- Pause where authority, safety, evidence custody or competence is unresolved.

B1 Initiation and chartering

Convert the request into a bounded assessment charter

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Record trigger and requested conclusion.	WP-B1-01
2	Identify sponsor, decision owner and intended users.	WP-B1-02
3	Define preliminary capability and outcomes.	WP-B1-03
4	Set type, ceiling and exclusions.	WP-B1-04
5	Record constraints and approvals.	WP-B1-05
6	Freeze charter baseline.	WP-B1-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B2 Capability profiling

Build the capability, outcome and operating-envelope model

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Identify owner, lifecycle and architecture.	WP-B2-01
2	Define outcome tolerances and criticality.	WP-B2-02
3	Map critical functions and demand.	WP-B2-03
4	Record peak, transient and future demand.	WP-B2-04
5	Define states and operating envelope.	WP-B2-05
6	Validate profile with SMEs.	WP-B2-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B3 Boundary and dependency discovery

Define scope without hiding external or excluded dependencies

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Set physical, logical, organisational and temporal boundaries.	WP-B3-01
2	Identify boundary crossings.	WP-B3-02
3	Map upstream, downstream and recovery dependencies.	WP-B3-03
4	Identify shared and common-mode dependencies.	WP-B3-04
5	Record exclusions and evidence-access constraints.	WP-B3-05
6	Approve scope and dependency baseline.	WP-B3-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B4 Applicability and tailoring

Select controls and gates based on capability reality

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Map entities and functions to domains.	WP-B4-01
2	Determine 360-control applicability.	WP-B4-02
3	Assign target assurance level.	WP-B4-03
4	Select gates and evidence profiles.	WP-B4-04
5	Approve N/A rationale.	WP-B4-05
6	Add profile controls without weakening baseline.	WP-B4-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B5 Assessment planning

Translate scope into sequenced workstreams and workpapers

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assign domain leads and reviews.	WP-B5-01
2	Map controls to methods and evidence.	WP-B5-02
3	Design interviews, visits, samples and tests.	WP-B5-03
4	Set safety rules and access.	WP-B5-04
5	Define checkpoints and dependencies.	WP-B5-05
6	Approve plan and workpaper index.	WP-B5-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B6 Evidence request and intake

Collect evidence under AIDCF-008 controls

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Issue claim-specific requests.	WP-B6-01
2	Record class, period, state and quality floor.	WP-B6-02
3	Receive into controlled repository.	WP-B6-03
4	Assign ID, classification and custody.	WP-B6-04
5	Validate provenance, integrity and readability.	WP-B6-05
6	Record missing, stale, restricted or substituted evidence.	WP-B6-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B7 Document review

Test intent, authority, scope and design

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Restate assertion.	WP-B7-01
2	Verify ownership, approval, version and applicability.	WP-B7-02
3	Extract criteria and assumptions.	WP-B7-03
4	Compare conflicting documents.	WP-B7-04
5	Link to architecture and controls.	WP-B7-05
6	Record support, challenge and limits.	WP-B7-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B8 Configuration review

Reconcile approved design with current technical state

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Define target configuration and subject.	WP-B8-01
2	Capture authorised source and extraction context.	WP-B8-02
3	Compare baseline, as-built and observed state.	WP-B8-03
4	Trace exceptions and unauthorized drift.	WP-B8-04
5	Assess dependency and state impact.	WP-B8-05
6	Record evidence and follow-up.	WP-B8-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B9 Interview method

Use human evidence for practice and context, not unsupported proof

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Define role-specific objectives.	WP-B9-01
2	Prepare open, scenario and evidence-seeking questions.	WP-B9-02
3	Explain handling and recording.	WP-B9-03
4	Distinguish personal practice from approved process.	WP-B9-04
5	Capture contradictions and evidence references.	WP-B9-05
6	Confirm notes and follow-ups.	WP-B9-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B10 Site inspection

Observe implementation and condition safely

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Complete induction and pre-brief.	WP-B10-01
2	Follow approved route and access.	WP-B10-02
3	Verify sampled assets and zones.	WP-B10-03
4	Observe condition, labels, alarms and maintenance.	WP-B10-04
5	Record deviations and inaccessible areas.	WP-B10-05
6	Debrief immediate concerns.	WP-B10-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B11 Sampling method

Create documented and defensible coverage

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Define population and its reliability.	WP-B11-01
2	Stratify by risk, site, state, age or topology.	WP-B11-02
3	Select random, systematic, judgmental or scenario sample.	WP-B11-03
4	Record rationale and inference.	WP-B11-04
5	Expand after exceptions.	WP-B11-05
6	State coverage and extrapolation limits.	WP-B11-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B12 Data and telemetry analysis

Evaluate performance, state, events and cross-domain behavior

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Define metric, source, period and resolution.	WP-B12-01
2	Verify clocks, gaps and collection health.	WP-B12-02
3	Baseline normal and peak/degraded states.	WP-B12-03
4	Correlate events without premature causality.	WP-B12-04
5	Investigate anomalies and counter-evidence.	WP-B12-05
6	Retain query, lineage and limitations.	WP-B12-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B13 Testing and exercises

Validate implementation, effectiveness or resilience under controlled conditions

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Define proposition, initial state and expected result.	WP-B13-01
2	Assess safety and operational risk.	WP-B13-02
3	Approve procedure, instrumentation and abort criteria.	WP-B13-03
4	Execute or observe authorised test.	WP-B13-04
5	Record anomalies, post-state and restoration.	WP-B13-05
6	Issue evidence and retest needs.	WP-B13-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

B14 Rules of engagement

Protect people, operations, evidence and confidential architecture

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Classify method risk and permits.	WP-B14-01
2	Name change, safety and stop authorities.	WP-B14-02
3	Define communications, monitoring and rollback.	WP-B14-03
4	Protect credentials and sensitive paths.	WP-B14-04
5	Record deviations, incidents and near misses.	WP-B14-05
6	Close access and restore environment.	WP-B14-06

Outputs

- Completed method workpaper.
- Evidence and follow-up references.

Quality checks

- Method is proportionate and reproducible.
- Representativeness and limitations are explicit.

Escalation and stop criteria

- Stop unsafe, unauthorised or uncontrolled activity.
- Escalate critical missing evidence.

C1 Control assessment

Evaluate each applicable control at its target assurance level

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Restate requirement and claim type.	WP-C1-01
2	Confirm subject, state, period and boundary.	WP-C1-02
3	Review evidence quality and sufficiency.	WP-C1-03
4	Perform planned method.	WP-C1-04
5	Record support, challenge, exception and UNKNOWN.	WP-C1-05
6	Assign controlled result with rationale.	WP-C1-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C2 Failure scenario analysis

Trace credible adversity to capability consequence

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Select bottom-up, top-down, path, state or capability method.	WP-C2-01
2	Separate threat/hazard, event, cause, mode, effect and consequence.	WP-C2-02
3	Trace dependencies and fault domains.	WP-C2-03
4	Evaluate safeguards and their dependencies.	WP-C2-04
5	Determine residual state and recovery.	WP-C2-05
6	Record evidence, UNKNOWN and gates.	WP-C2-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C3 Critical gate evaluation

Apply non-compensating gate logic

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Confirm applicability and criterion.	WP-C3-01
2	Verify mandatory evidence classes and floor.	WP-C3-02
3	Evaluate all relevant states and scenarios.	WP-C3-03
4	Assign Pass, Fail, UNKNOWN or approved N/A.	WP-C3-04
5	Determine decision ceiling and closure.	WP-C3-05
6	Obtain independent review.	WP-C3-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C4 Findings and causes

Write evidence-linked and outcome-focused findings

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	State factual condition and evidence.	WP-C4-01
2	Map criterion and affected outcome.	WP-C4-02
3	Identify immediate and systemic causes.	WP-C4-03
4	Describe consequence and residual exposure.	WP-C4-04
5	Classify materiality and confidence.	WP-C4-05
6	Define action and validation requirement.	WP-C4-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C5 UNKNOWN and limitations

Preserve unresolved knowledge and its decision effect

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Classify missing, inaccessible, stale, conflicting or integrity issue.	WP-C5-01
2	Identify subject and missing attribute.	WP-C5-02
3	Assess plausible consequence and gate impact.	WP-C5-03
4	Define evidence needed and owner.	WP-C5-04
5	Apply decision ceiling or suspension.	WP-C5-05
6	Track resolution and history.	WP-C5-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C6 Independent review

Challenge method, evidence, gates, findings and decision

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Verify scope and criteria.	WP-C6-01
2	Sample assertions back to evidence.	WP-C6-02
3	Challenge omitted and contradictory evidence.	WP-C6-03
4	Review scenario and gate completeness.	WP-C6-04
5	Test wording against ceiling.	WP-C6-05
6	Record resolution and approval or return.	WP-C6-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C7 Assurance decision

Issue a bounded status only after review

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Restate question and subject.	WP-C7-01
2	Summarise evidence, coverage and limitations.	WP-C7-02
3	Evaluate gate status and critical UNKNOWN.	WP-C7-03
4	Select controlled decision status.	WP-C7-04
5	Set conditions, validity and triggers.	WP-C7-05
6	Approve immutable package.	WP-C7-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C8 Reporting and closeout

Communicate without scope inflation or false precision

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Prepare executive and technical views.	WP-C8-01
2	Place scope, coverage, gates and UNKNOWN beside outcomes.	WP-C8-02
3	Protect sensitive evidence.	WP-C8-03
4	Reconcile references and versions.	WP-C8-04
5	Assign actions and validation.	WP-C8-05
6	Archive and close.	WP-C8-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

C9 Reassessment

Maintain decision validity through change and evidence triggers

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Monitor changes, incidents, evidence expiry and gates.	WP-C9-01
2	Map trigger to assertions and controls.	WP-C9-02
3	Suspend invalidated claims.	WP-C9-03
4	Perform delta or full reassessment.	WP-C9-04
5	Independently review material updates.	WP-C9-05
6	Supersede without erasing history.	WP-C9-06

Outputs

- Result, finding or decision record.
- Evidence links and reviewer signoff.

Quality checks

- No score overrides gates.
- Wording is bounded and controlled.

Escalation and stop criteria

- Withhold stronger assurance when chain is incomplete.

B9.1 Executive interviews

Structured prompts must be adapted and corroborated.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Ask and evidence: What decision must the capability support?	WP-B9.1-01
2	Ask and evidence: What outcomes and tolerances are non-negotiable?	WP-B9.1-02
3	Ask and evidence: Which assumptions are externally dependent?	WP-B9.1-03
4	Ask and evidence: What changes or incidents reduced confidence?	WP-B9.1-04
5	Ask and evidence: Who can accept residual exposure?	WP-B9.1-05
6	Ask and evidence: What suspends assurance?	WP-B9.1-06

Outputs

- Confirmed interview record.
- Contradictions and evidence follow-ups.

Quality checks

- Do not treat confidence of response as technical proof.

Escalation and stop criteria

- Escalate concealment, unsafe practice or unsupported critical claims.

B9.2 Engineering interviews

Structured prompts must be adapted and corroborated.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Ask and evidence: What conditions and deratings govern capacity?	WP-B9.2-01
2	Ask and evidence: What shared dependencies remain?	WP-B9.2-02
3	Ask and evidence: How are maintenance and degraded states controlled?	WP-B9.2-03
4	Ask and evidence: What tests demonstrate transfer and recovery?	WP-B9.2-04
5	Ask and evidence: Where does as-built differ?	WP-B9.2-05
6	Ask and evidence: What evidence is disputed?	WP-B9.2-06

Outputs

- Confirmed interview record.
- Contradictions and evidence follow-ups.

Quality checks

- Do not treat confidence of response as technical proof.

Escalation and stop criteria

- Escalate concealment, unsafe practice or unsupported critical claims.

B9.3 Technology interviews

Structured prompts must be adapted and corroborated.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Ask and evidence: What topology and compatibility baseline applies?	WP-B9.3-01
2	Ask and evidence: What limits usable capacity?	WP-B9.3-02
3	Ask and evidence: Which failures cross compute, fabric and storage?	WP-B9.3-03
4	Ask and evidence: How are checkpoints and restart validated?	WP-B9.3-04
5	Ask and evidence: What changes firmware or scheduling behavior?	WP-B9.3-05
6	Ask and evidence: Which telemetry blind spots remain?	WP-B9.3-06

Outputs

- Confirmed interview record.
- Contradictions and evidence follow-ups.

Quality checks

- Do not treat confidence of response as technical proof.

Escalation and stop criteria

- Escalate concealment, unsafe practice or unsupported critical claims.

B9.4 Operations and provider interviews

Structured prompts must be adapted and corroborated.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Ask and evidence: Who can operate and command critical systems?	WP-B9.4-01
2	Ask and evidence: How are alarms and emergency access controlled?	WP-B9.4-02
3	Ask and evidence: Which provider identities and services are essential?	WP-B9.4-03
4	Ask and evidence: How are incidents and evidence preserved?	WP-B9.4-04
5	Ask and evidence: What recovery relies on external support?	WP-B9.4-05
6	Ask and evidence: Which contractual boundaries limit assurance?	WP-B9.4-06

Outputs

- Confirmed interview record.
- Contradictions and evidence follow-ups.

Quality checks

- Do not treat confidence of response as technical proof.

Escalation and stop criteria

- Escalate concealment, unsafe practice or unsupported critical claims.

DGOV Domain Playbook: Governance, Accountability and Assurance Direction

Primary gates: CG-13, CG-14. Baseline evidence: charters, roles, policies, minutes and reviews.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

GOV-01 Governance architecture

Practitioner procedure for the governance architecture control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-GOV-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-GOV-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-GOV-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-GOV-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-GOV-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-GOV-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes charters, roles, policies, minutes and reviews.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

GOV-02 Accountability and responsibility

Practitioner procedure for the accountability and responsibility control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-GOV-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-GOV-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-GOV-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-GOV-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-GOV-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-GOV-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes charters, roles, policies, minutes and reviews.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

GOV-03 Policy and standards management

Practitioner procedure for the policy and standards management control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-GOV-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-GOV-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-GOV-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-GOV-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-GOV-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-GOV-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes charters, roles, policies, minutes and reviews.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

GOV-04 Risk and assurance governance

Practitioner procedure for the risk and assurance governance control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-GOV-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-GOV-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-GOV-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-GOV-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-GOV-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-GOV-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes charters, roles, policies, minutes and reviews.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

GOV-05 Stakeholder and regulatory interface

Practitioner procedure for the stakeholder and regulatory interface control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-GOV-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-GOV-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-GOV-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-GOV-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-GOV-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-GOV-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes charters, roles, policies, minutes and reviews.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

GOV-06 Ethics, impartiality and competence

Practitioner procedure for the ethics, impartiality and competence control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-GOV-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-GOV-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-GOV-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-GOV-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-GOV-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-GOV-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes charters, roles, policies, minutes and reviews.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DCAP Domain Playbook: AI Capability, Service Outcome and Demand Management

Primary gates: CG-01, CG-02. Baseline evidence: capability, outcomes, demand, tolerances and architecture.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

CAP-01 Capability inventory

Practitioner procedure for the capability inventory control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-CAP-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-CAP-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-CAP-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-CAP-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CAP-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CAP-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes capability, outcomes, demand, tolerances and architecture.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-01, CG-02.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CAP-02 Service outcome definition

Practitioner procedure for the service outcome definition control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-CAP-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-CAP-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-CAP-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-CAP-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CAP-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CAP-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes capability, outcomes, demand, tolerances and architecture.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-01, CG-02.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CAP-03 Criticality and materiality

Practitioner procedure for the criticality and materiality control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-CAP-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-CAP-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-CAP-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-CAP-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CAP-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CAP-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes capability, outcomes, demand, tolerances and architecture.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-01, CG-02.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CAP-04 Demand and growth modelling

Practitioner procedure for the demand and growth modelling control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-CAP-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-CAP-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-CAP-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-CAP-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CAP-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CAP-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes capability, outcomes, demand, tolerances and architecture.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-01, CG-02.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CAP-05 Operating envelope

Practitioner procedure for the operating envelope control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-CAP-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-CAP-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-CAP-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-CAP-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CAP-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CAP-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes capability, outcomes, demand, tolerances and architecture.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-01, CG-02.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CAP-06 Capability lifecycle and change

Practitioner procedure for the capability lifecycle and change control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-CAP-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-CAP-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-CAP-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-CAP-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CAP-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CAP-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes capability, outcomes, demand, tolerances and architecture.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-01, CG-02.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DDEP Domain Playbook: Dependency, Concentration and External Reliance Management

Primary gates: CG-03, CG-12. Baseline evidence: dependency graphs, contracts, routes and provider evidence.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

DEP-01 Dependency discovery

Practitioner procedure for the dependency discovery control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-DEP-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-DEP-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-DEP-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-DEP-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-DEP-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-DEP-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes dependency graphs, contracts, routes and provider evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DEP-02 Shared and common-mode dependencies

Practitioner procedure for the shared and common-mode dependencies control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-DEP-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-DEP-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-DEP-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-DEP-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-DEP-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-DEP-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes dependency graphs, contracts, routes and provider evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DEP-03 External providers and utilities

Practitioner procedure for the external providers and utilities control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-DEP-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-DEP-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-DEP-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-DEP-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-DEP-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-DEP-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes dependency graphs, contracts, routes and provider evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DEP-04 Concentration and substitutability

Practitioner procedure for the concentration and substitutability control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-DEP-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-DEP-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-DEP-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-DEP-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-DEP-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-DEP-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes dependency graphs, contracts, routes and provider evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DEP-05 Boundary and interface control

Practitioner procedure for the boundary and interface control control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-DEP-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-DEP-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-DEP-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-DEP-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-DEP-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-DEP-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes dependency graphs, contracts, routes and provider evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DEP-06 Dependency monitoring and review

Practitioner procedure for the dependency monitoring and review control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-DEP-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-DEP-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-DEP-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-DEP-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-DEP-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-DEP-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes dependency graphs, contracts, routes and provider evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DPHY Domain Playbook: Physical Site, Building and Security Infrastructure

Primary gates: CG-02, CG-04. Baseline evidence: site studies, drawings, inspections, access and life-safety records.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

PHY-01 Site and location resilience

Practitioner procedure for the site and location resilience control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-PHY-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-PHY-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-PHY-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-PHY-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-PHY-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-PHY-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes site studies, drawings, inspections, access and life-safety records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

PHY-02 Building and structural integrity

Practitioner procedure for the building and structural integrity control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-PHY-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-PHY-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-PHY-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-PHY-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-PHY-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-PHY-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes site studies, drawings, inspections, access and life-safety records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

PHY-03 Physical zoning and segregation

Practitioner procedure for the physical zoning and segregation control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-PHY-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-PHY-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-PHY-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-PHY-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-PHY-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-PHY-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes site studies, drawings, inspections, access and life-safety records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

PHY-04 Access and surveillance

Practitioner procedure for the access and surveillance control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-PHY-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-PHY-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-PHY-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-PHY-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-PHY-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-PHY-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes site studies, drawings, inspections, access and life-safety records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

PHY-05 Asset movement and custody

Practitioner procedure for the asset movement and custody control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-PHY-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-PHY-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-PHY-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-PHY-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-PHY-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-PHY-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes site studies, drawings, inspections, access and life-safety records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

PHY-06 Fire, life safety and emergency interfaces

Practitioner procedure for the fire, life safety and emergency interfaces control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-PHY-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-PHY-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-PHY-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-PHY-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-PHY-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-PHY-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes site studies, drawings, inspections, access and life-safety records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DPOW Domain Playbook: Electrical Power Infrastructure and Energy Continuity

Primary gates: CG-05. Baseline evidence: SLD, studies, settings, telemetry, maintenance and tests.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

POW-01 Utility and grid interface

Practitioner procedure for the utility and grid interface control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-POW-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-POW-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-POW-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-POW-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-POW-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-POW-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes SLD, studies, settings, telemetry, maintenance and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-05.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

POW-02 Generation and fuel

Practitioner procedure for the generation and fuel control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-POW-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-POW-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-POW-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-POW-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-POW-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-POW-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes SLD, studies, settings, telemetry, maintenance and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-05.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

POW-03 UPS and energy storage

Practitioner procedure for the ups and energy storage control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-POW-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-POW-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-POW-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-POW-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-POW-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-POW-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes SLD, studies, settings, telemetry, maintenance and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-05.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

POW-04 Distribution and protection

Practitioner procedure for the distribution and protection control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-POW-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-POW-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-POW-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-POW-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-POW-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-POW-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes SLD, studies, settings, telemetry, maintenance and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-05.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

POW-05 Power quality and transient response

Practitioner procedure for the power quality and transient response control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-POW-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-POW-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-POW-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-POW-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-POW-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-POW-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes SLD, studies, settings, telemetry, maintenance and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-05.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

POW-06 Electrical monitoring, maintenance and recovery

Practitioner procedure for the electrical monitoring, maintenance and recovery control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-POW-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-POW-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-POW-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-POW-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-POW-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-POW-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes SLD, studies, settings, telemetry, maintenance and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-05.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DTHM Domain Playbook: Cooling, Thermal and Fluid Infrastructure

Primary gates: CG-06. Baseline evidence: P&ID, models, controls, telemetry, fluids and tests.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

THM-01 Thermal architecture and capacity

Practitioner procedure for the thermal architecture and capacity control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-THM-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-THM-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-THM-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-THM-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-THM-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-THM-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes P&ID, models, controls, telemetry, fluids and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-06.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

THM-02 Air cooling systems

Practitioner procedure for the air cooling systems control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-THM-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-THM-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-THM-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-THM-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-THM-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-THM-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes P&ID, models, controls, telemetry, fluids and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-06.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

THM-03 Liquid cooling systems

Practitioner procedure for the liquid cooling systems control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-THM-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-THM-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-THM-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-THM-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-THM-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-THM-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes P&ID, models, controls, telemetry, fluids and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-06.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

THM-04 Heat rejection and water systems

Practitioner procedure for the heat rejection and water systems control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-THM-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-THM-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-THM-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-THM-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-THM-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-THM-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes P&ID, models, controls, telemetry, fluids and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-06.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

THM-05 Fluid quality and leak management

Practitioner procedure for the fluid quality and leak management control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-THM-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-THM-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-THM-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-THM-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-THM-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-THM-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes P&ID, models, controls, telemetry, fluids and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-06.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

THM-06 Thermal control, maintenance and recovery

Practitioner procedure for the thermal control, maintenance and recovery control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-THM-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-THM-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-THM-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-THM-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-THM-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-THM-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes P&ID, models, controls, telemetry, fluids and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-06.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DENV Domain Playbook: Environmental and Resource Performance

Primary gates: CG-02, CG-04. Baseline evidence: environmental telemetry, meters, permits and calculations.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

ENV-01 Environmental operating conditions

Practitioner procedure for the environmental operating conditions control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-ENV-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-ENV-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-ENV-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-ENV-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-ENV-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-ENV-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes environmental telemetry, meters, permits and calculations.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

ENV-02 Energy performance

Practitioner procedure for the energy performance control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-ENV-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-ENV-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-ENV-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-ENV-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-ENV-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-ENV-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes environmental telemetry, meters, permits and calculations.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

ENV-03 Water performance

Practitioner procedure for the water performance control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-ENV-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-ENV-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-ENV-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-ENV-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-ENV-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-ENV-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes environmental telemetry, meters, permits and calculations.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

ENV-04 Carbon and resource reporting

Practitioner procedure for the carbon and resource reporting control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-ENV-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-ENV-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-ENV-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-ENV-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-ENV-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-ENV-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes environmental telemetry, meters, permits and calculations.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

ENV-05 Hazardous materials and waste

Practitioner procedure for the hazardous materials and waste control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-ENV-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-ENV-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-ENV-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-ENV-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-ENV-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-ENV-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes environmental telemetry, meters, permits and calculations.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

ENV-06 Climate adaptation and resource continuity

Practitioner procedure for the climate adaptation and resource continuity control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-ENV-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-ENV-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-ENV-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-ENV-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-ENV-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-ENV-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes environmental telemetry, meters, permits and calculations.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-02, CG-04.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DCMP Domain Playbook: AI Compute Infrastructure

Primary gates: CG-08. Baseline evidence: topology, firmware, configuration, telemetry and tests.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

CMP-01 Compute architecture and configuration

Practitioner procedure for the compute architecture and configuration control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-CMP-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-CMP-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-CMP-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-CMP-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CMP-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CMP-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, firmware, configuration, telemetry and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CMP-02 Cluster and scale-up domains

Practitioner procedure for the cluster and scale-up domains control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-CMP-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-CMP-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-CMP-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-CMP-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CMP-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CMP-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, firmware, configuration, telemetry and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CMP-03 Capacity, scheduling and utilisation

Practitioner procedure for the capacity, scheduling and utilisation control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-CMP-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-CMP-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-CMP-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-CMP-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CMP-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CMP-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, firmware, configuration, telemetry and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CMP-04 Firmware, driver and compatibility

Practitioner procedure for the firmware, driver and compatibility control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-CMP-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-CMP-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-CMP-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-CMP-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CMP-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CMP-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, firmware, configuration, telemetry and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CMP-05 Compute health and observability

Practitioner procedure for the compute health and observability control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-CMP-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-CMP-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-CMP-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-CMP-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CMP-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CMP-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, firmware, configuration, telemetry and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

CMP-06 Compute lifecycle and recovery

Practitioner procedure for the compute lifecycle and recovery control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-CMP-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-CMP-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-CMP-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-CMP-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-CMP-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-CMP-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, firmware, configuration, telemetry and tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DSTO Domain Playbook: AI Storage and Data Infrastructure

Primary gates: CG-08, CG-10. Baseline evidence: architecture, integrity, performance, replication and recovery tests.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

STO-01 Storage architecture and tiering

Practitioner procedure for the storage architecture and tiering control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-STO-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-STO-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-STO-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-STO-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-STO-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-STO-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes architecture, integrity, performance, replication and recovery tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

STO-02 Performance and capacity

Practitioner procedure for the performance and capacity control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-STO-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-STO-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-STO-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-STO-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-STO-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-STO-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes architecture, integrity, performance, replication and recovery tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

STO-03 Integrity and consistency

Practitioner procedure for the integrity and consistency control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-STO-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-STO-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-STO-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-STO-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-STO-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-STO-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes architecture, integrity, performance, replication and recovery tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

STO-04 Protection and replication

Practitioner procedure for the protection and replication control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-STO-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-STO-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-STO-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-STO-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-STO-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-STO-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes architecture, integrity, performance, replication and recovery tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

STO-05 Checkpoint and recovery services

Practitioner procedure for the checkpoint and recovery services control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-STO-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-STO-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-STO-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-STO-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-STO-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-STO-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes architecture, integrity, performance, replication and recovery tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

STO-06 Storage monitoring and lifecycle

Practitioner procedure for the storage monitoring and lifecycle control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-STO-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-STO-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-STO-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-STO-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-STO-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-STO-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes architecture, integrity, performance, replication and recovery tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DNET Domain Playbook: AI Network and Interconnect Architecture

Primary gates: CG-08. Baseline evidence: topology, cabling, configuration, telemetry and failover tests.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

NET-01 Scale-up and scale-out fabrics

Practitioner procedure for the scale-up and scale-out fabrics control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-NET-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-NET-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-NET-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-NET-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-NET-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-NET-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, cabling, configuration, telemetry and failover tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

NET-02 Performance and congestion control

Practitioner procedure for the performance and congestion control control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-NET-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-NET-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-NET-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-NET-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-NET-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-NET-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, cabling, configuration, telemetry and failover tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

NET-03 Storage and service networks

Practitioner procedure for the storage and service networks control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-NET-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-NET-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-NET-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-NET-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-NET-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-NET-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, cabling, configuration, telemetry and failover tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

NET-04 Management and out-of-band networks

Practitioner procedure for the management and out-of-band networks control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-NET-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-NET-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-NET-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-NET-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-NET-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-NET-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, cabling, configuration, telemetry and failover tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

NET-05 Physical connectivity and optics

Practitioner procedure for the physical connectivity and optics control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-NET-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-NET-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-NET-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-NET-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-NET-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-NET-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, cabling, configuration, telemetry and failover tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

NET-06 Network control and observability

Practitioner procedure for the network control and observability control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-NET-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-NET-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-NET-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-NET-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-NET-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-NET-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes topology, cabling, configuration, telemetry and failover tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-08.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DOPS Domain Playbook: Building Operations and Service Management

Primary gates: CG-07, CG-13, CG-14. Baseline evidence: procedures, work orders, alarms, incidents and changes.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

OPS-01 Operating model and staffing

Practitioner procedure for the operating model and staffing control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-OPS-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-OPS-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-OPS-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-OPS-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-OPS-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-OPS-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes procedures, work orders, alarms, incidents and changes.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

OPS-02 Procedure and work control

Practitioner procedure for the procedure and work control control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-OPS-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-OPS-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-OPS-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-OPS-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-OPS-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-OPS-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes procedures, work orders, alarms, incidents and changes.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

OPS-03 Maintenance and reliability

Practitioner procedure for the maintenance and reliability control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-OPS-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-OPS-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-OPS-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-OPS-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-OPS-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-OPS-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes procedures, work orders, alarms, incidents and changes.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

OPS-04 Alarm, incident and problem management

Practitioner procedure for the alarm, incident and problem management control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-OPS-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-OPS-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-OPS-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-OPS-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-OPS-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-OPS-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes procedures, work orders, alarms, incidents and changes.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

OPS-05 Change and configuration management

Practitioner procedure for the change and configuration management control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-OPS-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-OPS-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-OPS-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-OPS-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-OPS-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-OPS-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes procedures, work orders, alarms, incidents and changes.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

OPS-06 Capacity and service operations

Practitioner procedure for the capacity and service operations control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-OPS-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-OPS-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-OPS-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-OPS-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-OPS-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-OPS-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes procedures, work orders, alarms, incidents and changes.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-13, CG-14.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DRES Domain Playbook: Resilience, Continuity and Recovery

Primary gates: CG-09, CG-10. Baseline evidence: scenarios, continuity and recovery plans, exercises and retests.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

RES-01 Resilience strategy

Practitioner procedure for the resilience strategy control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-RES-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-RES-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-RES-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-RES-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-RES-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-RES-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes scenarios, continuity and recovery plans, exercises and retests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-09, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

RES-02 Fault-domain and containment design

Practitioner procedure for the fault-domain and containment design control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-RES-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-RES-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-RES-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-RES-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-RES-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-RES-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes scenarios, continuity and recovery plans, exercises and retests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-09, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

RES-03 Continuity planning

Practitioner procedure for the continuity planning control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-RES-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-RES-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-RES-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-RES-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-RES-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-RES-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes scenarios, continuity and recovery plans, exercises and retests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-09, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

RES-04 Recovery planning

Practitioner procedure for the recovery planning control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-RES-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-RES-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-RES-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-RES-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-RES-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-RES-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes scenarios, continuity and recovery plans, exercises and retests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-09, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

RES-05 Testing and exercising

Practitioner procedure for the testing and exercising control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-RES-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-RES-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-RES-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-RES-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-RES-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-RES-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes scenarios, continuity and recovery plans, exercises and retests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-09, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

RES-06 Crisis and adaptive response

Practitioner procedure for the crisis and adaptive response control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-RES-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-RES-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-RES-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-RES-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-RES-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-RES-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes scenarios, continuity and recovery plans, exercises and retests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-09, CG-10.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DSUP Domain Playbook: Supply Chain, OEM and Ecosystem Assurance

Primary gates: CG-03, CG-13. Baseline evidence: due diligence, contracts, provenance, support and spares evidence.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

SUP-01 Supplier due diligence

Practitioner procedure for the supplier due diligence control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-SUP-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-SUP-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-SUP-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-SUP-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SUP-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SUP-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes due diligence, contracts, provenance, support and spares evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-13.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SUP-02 Contract and service obligations

Practitioner procedure for the contract and service obligations control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-SUP-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-SUP-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-SUP-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-SUP-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SUP-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SUP-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes due diligence, contracts, provenance, support and spares evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-13.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SUP-03 Hardware and component provenance

Practitioner procedure for the hardware and component provenance control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-SUP-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-SUP-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-SUP-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-SUP-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SUP-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SUP-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes due diligence, contracts, provenance, support and spares evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-13.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SUP-04 Software, firmware and update supply

Practitioner procedure for the software, firmware and update supply control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-SUP-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-SUP-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-SUP-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-SUP-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SUP-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SUP-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes due diligence, contracts, provenance, support and spares evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-13.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SUP-05 Spares, logistics and obsolescence

Practitioner procedure for the spares, logistics and obsolescence control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-SUP-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-SUP-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-SUP-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-SUP-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SUP-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SUP-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes due diligence, contracts, provenance, support and spares evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-13.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SUP-06 Remote support and third-party access

Practitioner procedure for the remote support and third-party access control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-SUP-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-SUP-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-SUP-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-SUP-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SUP-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SUP-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes due diligence, contracts, provenance, support and spares evidence.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-03, CG-13.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DSEC Domain Playbook: Digital, OT and Control-Plane Security

Primary gates: CG-07, CG-15. Baseline evidence: identity, privilege, configuration, logs and authorised tests.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

SEC-01 Identity and privileged access

Practitioner procedure for the identity and privileged access control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-SEC-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-SEC-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-SEC-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-SEC-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SEC-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SEC-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes identity, privilege, configuration, logs and authorised tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-15.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SEC-02 Control-plane protection

Practitioner procedure for the control-plane protection control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-SEC-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-SEC-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-SEC-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-SEC-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SEC-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SEC-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes identity, privilege, configuration, logs and authorised tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-15.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SEC-03 Network security and segmentation

Practitioner procedure for the network security and segmentation control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-SEC-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-SEC-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-SEC-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-SEC-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SEC-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SEC-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes identity, privilege, configuration, logs and authorised tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-15.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SEC-04 Configuration, vulnerability and patching

Practitioner procedure for the configuration, vulnerability and patching control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-SEC-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-SEC-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-SEC-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-SEC-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SEC-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SEC-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes identity, privilege, configuration, logs and authorised tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-15.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SEC-05 Detection and response

Practitioner procedure for the detection and response control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-SEC-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-SEC-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-SEC-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-SEC-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SEC-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SEC-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes identity, privilege, configuration, logs and authorised tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-15.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

SEC-06 AI-enabled and automated action

Practitioner procedure for the ai-enabled and automated action control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-SEC-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-SEC-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-SEC-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-SEC-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-SEC-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-SEC-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes identity, privilege, configuration, logs and authorised tests.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-07, CG-15.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

DEVA Domain Playbook: Evidence, Assessment and Assurance Management

Primary gates: CG-11, CG-12. Baseline evidence: manifests, workpapers, findings, gates and decision records.

Planning dimension	Requirement
Subject	Map to Capability Instance, outcomes and functions.
Boundary	Identify assets, interfaces, providers and exclusions.
States	Assess normal and material maintenance, degraded, emergency and recovery states.
Methods	Use design/configuration review, observation, analytics and safe test as appropriate.
Scenarios	Trace local, cross-domain, common-mode and recovery paths.
Decision	Preserve UNKNOWN and apply non-compensation.

- Confirm SME competence and authority.
- Select populations and risk-based samples.
- Identify evidence gaps affecting gates.
- Independently review material conclusions.

EVA-01 Evidence architecture

Practitioner procedure for the evidence architecture control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 001: governance and design intent against measurable criteria.	WP-EVA-01-01
2	Assess control 002: implemented state and architecture alignment.	WP-EVA-01-02
3	Assess control 003: operation, monitoring, exceptions and current evidence.	WP-EVA-01-03
4	Assess control 004: failure, degraded-state, recovery and adaptation.	WP-EVA-01-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-EVA-01-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-EVA-01-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes manifests, workpapers, findings, gates and decision records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-11, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

EVA-02 Evidence provenance and quality

Practitioner procedure for the evidence provenance and quality control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 005: governance and design intent against measurable criteria.	WP-EVA-02-01
2	Assess control 006: implemented state and architecture alignment.	WP-EVA-02-02
3	Assess control 007: operation, monitoring, exceptions and current evidence.	WP-EVA-02-03
4	Assess control 008: failure, degraded-state, recovery and adaptation.	WP-EVA-02-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-EVA-02-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-EVA-02-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes manifests, workpapers, findings, gates and decision records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-11, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

EVA-03 Assessment planning and execution

Practitioner procedure for the assessment planning and execution control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 009: governance and design intent against measurable criteria.	WP-EVA-03-01
2	Assess control 010: implemented state and architecture alignment.	WP-EVA-03-02
3	Assess control 011: operation, monitoring, exceptions and current evidence.	WP-EVA-03-03
4	Assess control 012: failure, degraded-state, recovery and adaptation.	WP-EVA-03-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-EVA-03-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-EVA-03-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes manifests, workpapers, findings, gates and decision records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-11, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

EVA-04 Findings, UNKNOWN and limitations

Practitioner procedure for the findings, unknown and limitations control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 013: governance and design intent against measurable criteria.	WP-EVA-04-01
2	Assess control 014: implemented state and architecture alignment.	WP-EVA-04-02
3	Assess control 015: operation, monitoring, exceptions and current evidence.	WP-EVA-04-03
4	Assess control 016: failure, degraded-state, recovery and adaptation.	WP-EVA-04-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-EVA-04-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-EVA-04-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes manifests, workpapers, findings, gates and decision records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-11, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

EVA-05 Critical gates and decisions

Practitioner procedure for the critical gates and decisions control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 017: governance and design intent against measurable criteria.	WP-EVA-05-01
2	Assess control 018: implemented state and architecture alignment.	WP-EVA-05-02
3	Assess control 019: operation, monitoring, exceptions and current evidence.	WP-EVA-05-03
4	Assess control 020: failure, degraded-state, recovery and adaptation.	WP-EVA-05-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-EVA-05-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-EVA-05-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes manifests, workpapers, findings, gates and decision records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-11, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

EVA-06 Reassessment and continuing assurance

Practitioner procedure for the reassessment and continuing assurance control family.

Entry criteria

- Authorised assessment purpose and current scope.
- Named preparer, technical reviewer and evidence sources.

Practitioner procedure

Step	Required action	Record
1	Assess control 021: governance and design intent against measurable criteria.	WP-EVA-06-01
2	Assess control 022: implemented state and architecture alignment.	WP-EVA-06-02
3	Assess control 023: operation, monitoring, exceptions and current evidence.	WP-EVA-06-03
4	Assess control 024: failure, degraded-state, recovery and adaptation.	WP-EVA-06-04
5	Rate evidence quality and sufficiency under AIDCF-008.	WP-EVA-06-05
6	Assign result, gate impact, finding, UNKNOWN and reassessment trigger.	WP-EVA-06-06

Outputs

- Four control-result workpapers.
- Evidence set and sampling record.
- Family conclusion and gate linkage.

Quality checks

- Baseline evidence includes manifests, workpapers, findings, gates and decision records.
- Design, observed and tested states are distinct.
- Technical conclusion has competent review.

Escalation and stop criteria

- Escalate applicable CG-11, CG-12.
- Stop unsafe or unauthorised tests.
- Cap assurance for material inaccessible, stale or conflicting evidence.

E1 Assessment Charter Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E2 Capability Profile Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E3 Scope and Boundary Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E4 Applicability Matrix Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E5 Assessment Plan Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E6 Evidence Request Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E7 Interview Record Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E8 Site Inspection Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E9 Sampling Plan Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E10 Test Plan Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E11 Test Result Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E12 Control Result Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E13 Scenario Record Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E14 Critical Gate Result Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E15 Finding Record Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E16 UNKNOWN Record Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E17 Limitation Record Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E18 Independent Review Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E19 Assurance Decision Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

E20 Reassessment Record Template

Complete all applicable fields. Blank fields are not evidence of Not Applicable.

Field	Practitioner entry
stableId	
subject	
decisionQuestion	
scope	
boundary	
operatingState	
criterion	
method	
evidenceRefs	
qualityAndSufficiency	
result	
UNKNOWNAndConflicts	
gateImpact	
owner	
reviewer	
versionAndDate	

Quality review

Check	Yes/No	Reviewer note
Scope and state explicit		
Evidence traceable		
UNKNOWN and conflicts visible		
Gate and decision effect correct		
Wording within ceiling		

Appendix A Controlled status vocabulary

Object	States
Control	NOT ASSESSED; UNKNOWN; N/A; NOT IMPLEMENTED; PARTIAL; IMPLEMENTED; OPERATING EFFECTIVELY; INEFFECTIVE; SUSPENDED
Gate	PASS; FAIL; UNKNOWN; approved N/A
Finding	OBSERVATION; CONFORMING; PARTIAL; NONCONFORMING; UNKNOWN; CONFLICTING; N/A; SUSPENDED
Decision	NOT ASSESSED; UNKNOWN; INCONCLUSIVE; ADVERSE; LIMITED; CONDITIONAL; REASONABLY ASSURED; SUSPENDED; WITHDRAWN; SUPERSEDED

Appendix B Machine-readable package

Artifact	Purpose
assessment-charter.schema.json	Authority
capability-profile.schema.json	Capability and outcomes
assessment-plan.schema.json	Procedures
control-result.schema.json	Control results
scenario-result.schema.json	Failure scenarios
critical-gate-result.schema.json	Gate status
finding.schema.json	Findings
unknown.schema.json	UNKNOWN
assurance-decision.schema.json	Decision
aidcf-am-v1.0.owl / ttl	Ontology
aidcf-am-shapes-v1.0.ttl	Validation

Appendix C Validation rules

AM-VAL-001 Assessment has decision question, capability and outcomes.

AM-VAL-002 Every control has applicability, method, evidence and result.

AM-VAL-003 Every assertion has evidence or UNKNOWN.

AM-VAL-004 Every test has authority, initial state and abort criteria.

AM-VAL-005 Every gate has evidence and independent review.

AM-VAL-006 No score overrides a failed or critical-UNKNOWN gate.

AM-VAL-007 Every finding maps evidence, criterion, cause and outcome.

AM-VAL-008 Every decision states scope, period, conditions and owner.

AM-VAL-009 Every automated inference remains candidate until reviewed.

AM-VAL-010 Every superseded decision remains traceable.

AM-VAL-011 Every external dependency remains visible.

AM-VAL-012 Every N/A has approved rationale.

AM-VAL-013 Every critical UNKNOWN has decision effect.

AM-VAL-014 Every sensitive record has classification.

AM-VAL-015 Every material change maps affected decisions.

Appendix D Review and release gates

Role	Status	Focus
Methodology author	Draft completed	Coherence
Lead assessor peer	Pending	Practical execution
Electrical SME	Pending	Power procedures
Mechanical SME	Pending	Thermal procedures
Compute/HPC SME	Pending	Compute procedures
Storage/network SME	Pending	Technical methods
Operations/reliability	Pending	Fieldwork and recovery
OT/security	Pending	Control planes
Evidence/assurance	Pending	AIDCF-008
Safety/legal/privacy	Pending	Boundaries
Ontology/tooling	Pending	Schemas
Independent pilot	Pending	Reproducibility
Public release	Not approved	All gates

Final doctrine

An AIDCF assessment is complete only when decision question, capability, outcomes, boundary, dependencies, controls, failure paths, safeguards, evidence, UNKNOWN, gates, review and validity are traceably connected. Otherwise the practitioner reduces, conditions, suspends or withholds assurance.