

Block 1: System values (Read input register)

Modbus address	Object designation	WPMsys-tem	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Unit	Write/read (w/r)
501	ACTUAL TEMPERATURE FE7	x	x	x				2	°C	r
502	SET TEMPERATURE FE7	x	x	x				2	°C	r
503	ACTUAL TEMPERATURE FEK		x	x				2	°C	r
504	SET TEMPERATURE FEK		x	x				2	°C	r
505	RELATIVE HUMIDITY		x	x				2	%	r
506	DEW POINT TEMPERATURE		x	x		-40	30	2	°C	r
507	OUTSIDE TEMPERATURE	x	x	x		-60	80	2	°C	r
508	ACTUAL TEMPERATURE HK 1	x	x	x		0	40	2	°C	r
509	SET TEMPERATURE HK 1			x		0	65	2	°C	r
510	SET TEMPERATURE HK 1	x	x			0	40	2	°C	r
511	ACTUAL TEMPERATURE HK 2	x	x	x		0	90	2	°C	r
512	SET TEMPERATURE HK 2	x	x	x		0	65	2	°C	r
513	ACTUAL FLOW TEMPERATURE WP	x	x	x	MFG, if available			2	°C	r
514	ACTUAL FLOW TEMPERATURE NHZ	x	x	x	MFG, if available			2	°C	r
515	ACTUAL FLOW TEMPERATURE	x	x	x				2	°C	r
516	ACTUAL RETURN TEMPERATURE	x	x	x		0	90	2	°C	r
517	SET FIXED TEMPERATURE	x	x	x		20	50	2	°C	r
518	ACTUAL BUFFER TEMPERATURE	x	x	x		0	90	2	°C	r
519	SET BUFFER TEMPERATURE	x	x	x				2	°C	r
520	HEATING PRESSURE	x	x	x	MFG, if available			7	bar	r
521	FLOW RATE	x	x	x	MFG, if available			2	l/min	r
522	ACTUAL TEMPERATURE	x	x	x	DHW	10	65	2	°C	r
523	SET TEMPERATURE	x	x	x	DHW	10	65	2	°C	r
524	ACTUAL TEMPERATURE FAN	x	x	x	Cooling			2	K	r
525	SET TEMPERATURE FAN	x	x	x	Cooling	7	25	2	K	r
526	ACTUAL TEMPERATURE AREA	x	x	x	Cooling			2	K	r
527	SET TEMPERATURE AREA	x	x	x	Cooling			2	K	r
528	COLLECTOR TEMPERATURE		x		Solar thermal	0	90	2	°C	r
529	CYLINDER TEMPERATURE		x		Solar thermal	0	90	2	°C	r
530	RUNTIME		x		Solar thermal			6	h	r
531	ACTUAL TEMPERATURE	x	x		External heat source	10	90	2	°C	r

Modbus address	Object designation	WPMsystem	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Unit	Write/read (w/r)
532	SET TEMPERATURE	x	x		External heat source			2	K	r
533	APPLICATION LIMIT HZG	x	x	x	Lower heating limit	-40	40	2	°C	r
534	APPLICATION LIMIT WW	x	x	x	Lower DHW limit	-40	40	2	°C	r
535	RUNTIME	x	x		External heat source			6	h	r
536	SOURCE TEMPERATURE	x	x	x				2	°C	r
537	MIN SOURCE TEMPERATURE	x	x	x		-10	10	2	°C	r
538	SOURCE PRESSURE	x	x	x				7	bar	r
539	HOT GAS TEMPERATURE			x				2	°C	r
540	HIGH PRESSURE			x				2	bar	r
541	LOW PRESSURE			x				2	bar	r
542	RETURN TEMPERATURE	x	x		Heat pump 1			2	°C	r
543	FLOW TEMPERATURE	x	x		Heat pump 1			2	°C	r
544	HOT GAS TEMPERATURE	x	x		Heat pump 1			2	°C	r
545	LOW PRESSURE	x	x		Heat pump 1			7	bar	r
546	MEAN PRESSURE	x	x		Heat pump 1			7	bar	r
547	HIGH PRESSURE	x	x		Heat pump 1			7	bar	r
548	WP WATER FLOW RATE	x	x		Heat pump 1			2	l/min	r
549	RETURN TEMPERATURE	x	x		Heat pump 2			2	°C	r
550	FLOW TEMPERATURE	x	x		Heat pump 2			2	°C	r
551	HOT GAS TEMPERATURE	x	x		Heat pump 2			2	°C	r
552	LOW PRESSURE	x	x		Heat pump 2			7	bar	r
553	MEAN PRESSURE	x	x		Heat pump 2			7	bar	r
554	HIGH PRESSURE	x	x		Heat pump 2			7	bar	r
555	WP WATER FLOW RATE	x	x		Heat pump 2			2	l/min	r
556	RETURN TEMPERATURE	x	x		Heat pump 3			2	°C	r
557	FLOW TEMPERATURE	x	x		Heat pump 3			2	°C	r
558	HOT GAS TEMPERATURE	x	x		Heat pump 3			2	°C	r
559	LOW PRESSURE	x	x		Heat pump 3			7	bar	r
560	MEAN PRESSURE	x	x		Heat pump 3			7	bar	r
561	HIGH PRESSURE	x	x		Heat pump 3			7	bar	r
562	WP WATER FLOW RATE	x	x		Heat pump 3			2	l/min	r
563	RETURN TEMPERATURE	x	x		Heat pump 4			2	°C	r
564	FLOW TEMPERATURE	x	x		Heat pump 4			2	°C	r
565	HOT GAS TEMPERATURE	x	x		Heat pump 4			2	°C	r
566	LOW PRESSURE	x	x		Heat pump 4			7	bar	r
567	MEAN PRESSURE	x	x		Heat pump 4			7	bar	r
568	HIGH PRESSURE	x	x		Heat pump 4			7	bar	r
569	WP WATER FLOW RATE	x	x		Heat pump 4			2	l/min	r
570	RETURN TEMPERATURE	x	x		Heat pump 5			2	°C	r
571	FLOW TEMPERATURE	x	x		Heat pump 5			2	°C	r
572	HOT GAS TEMPERATURE	x	x		Heat pump 5			2	°C	r
573	LOW PRESSURE	x	x		Heat pump 5			7	bar	r
574	MEAN PRESSURE	x	x		Heat pump 5			7	bar	r
575	HIGH PRESSURE	x	x		Heat pump 5			7	bar	r
576	WP WATER FLOW RATE	x	x		Heat pump 5			2	l/min	r
577	RETURN TEMPERATURE	x	x		Heat pump 6			2	°C	r
578	FLOW TEMPERATURE	x	x		Heat pump 6			2	°C	r
579	HOT GAS TEMPERATURE	x	x		Heat pump 6			2	°C	r
580	LOW PRESSURE	x	x		Heat pump 6			7	bar	r
581	MEAN PRESSURE	x	x		Heat pump 6			7	bar	r
582	HIGH PRESSURE	x	x		Heat pump 6			7	bar	r
583	WP WATER FLOW RATE	x	x		Heat pump 6			2	l/min	r

Modbus address	Object designation	WPMsystem	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Unit	Write/read (w/r)
584	ACTUAL TEMPERATURE	x			Room temperature, heating circuit 1			2	°C	r
585	SET TEMPERATURE	x			Room temperature, heating circuit 1			2	°C	r
586	RELATIVE HUMIDITY	x			Heating circuit 1			2	%	r
587	DEW POINT TEMPERATURE	x			Heating circuit 1			2	°C	r
588	ACTUAL TEMPERATURE	x			Room temperature, heating circuit 2			2	°C	r
589	SET TEMPERATURE	x			Room temperature, heating circuit 2			2	°C	r
590	RELATIVE HUMIDITY	x			Heating circuit 2			2	%	r
591	DEW POINT TEMPERATURE	x			Heating circuit 2			2	°C	r
592	ACTUAL TEMPERATURE	x			Room temperature, heating circuit 3			2	°C	r
593	SET TEMPERATURE	x			Room temperature, heating circuit 3			2	°C	r
594	RELATIVE HUMIDITY	x			Heating circuit 3			2	%	r
595	DEW POINT TEMPERATURE	x			Heating circuit 3			2	°C	r
596	ACTUAL TEMPERATURE	x			Room temperature, heating circuit 4			2	°C	r
597	SET TEMPERATURE	x			Room temperature, heating circuit 4			2	°C	r
598	RELATIVE HUMIDITY	x			Heating circuit 4			2	%	r
599	DEW POINT TEMPERATURE	x			Heating circuit 4			2	°C	r
600	ACTUAL TEMPERATURE	x			Room temperature, heating circuit 5			2	°C	r
601	SET TEMPERATURE	x			Room temperature, heating circuit 5			2	°C	r
602	RELATIVE HUMIDITY	x			Heating circuit 5			2	%	r
603	DEW POINT TEMPERATURE	x			Heating circuit 5			2	°C	r
604	SET TEMPERATURE	x			Room temperature, cooling circuit 1			2	°C	r
605	SET TEMPERATURE	x			Room temperature, cooling circuit 2			2	°C	r
606	SET TEMPERATURE	x			Room temperature, cooling circuit 3			2	°C	r
607	SET TEMPERATURE	x			Room temperature, cooling circuit 4			2	°C	r
608	SET TEMPERATURE	x			Room temperature, cooling circuit 5			2	°C	r

Block 2: System parameters (Read/write holding register)

Modbus address	Object designation	WPM-system	WPM 3	WPM 3i	Comments	Min. value	Max. value	Step size	Data type	Unit	Write/read (w/r)	Coding	Option
1501	OPERATING MODE	x	x	x		0	5	1	8		r/w	STANDBY MODE 1 PROGRAMMED 2 OPERATION COMFORT MODE 3 ECO MODE 4 DHW MODE 5 EMERGENCY 0 OPERATION	
1502	COMFORT TEMPERATURE	x	x	x	Heating circuit 1 5	30	1	2	°C	r/w			
1503	ECO TEMPERATURE	x	x	x	Heating circuit 1 5	30	1	2	°C	r/w			
1504	HEATING CURVE RISE	x	x	x	Heating circuit 1 0	3	1	7		r/w			
1505	COMFORT TEMPERATURE	x	x	x	Heating circuit 2 5	30	1	2	°C	r/w			
1506	ECO TEMPERATURE	x	x	x	Heating circuit 2 5	30	1	2	°C	r/w			
1507	HEATING CURVE RISE	x	x	x	Heating circuit 2 0	3	1	7		r/w			

Modbus address	Object designation	WPM-system	WPM 3	WPM 3i	Comments	Min. value	Max. value	Step size	Data type	Unit	Write/read (w/r)	Coding	Option
1508	FIXED VALUE OPERATION	x	x	x	[*]	OFF/20°	70°		2	°C	r/w		
1509	DUAL MODE TEMP HZG		x	x	Observe application limits.	-40	40	5	2	°C	r/w		
1510	COMFORT TEMPERATURE	x	x	x	DHW	10	60	5	2	°C	r/w		
1511	ECO TEMPERATURE	x	x	x	DHW	10	60	5	2	°C	r/w		
1512	DHW STAGES	x	x	x	Please note: Observe number of connected heat pumps	0	6	1	8		r/w		
1513	DUAL MODE TEMP WW	x	x	x	DHW temperatures	-40	40	1	2	°C	r/w		
1514	SET FLOW TEMPERATURE	x	x	x	Area cooling	7	25	1	2	°C	r/w		
1515	FLOW TEMP HYSTERESIS	x	x	x	Cooling	1	5	1	2	K	r/w		
1516	SET ROOM TEMPERATURE	x	x	x	Area cooling	20	30	1	2	°C	r/w		
1517	SET FLOW TEMPERATURE	x	x	x	Fan cooling	7	25	1	2	°C	r/w		
1518	FLOW TEMP HYSTERESIS	x	x	x	Fan cooling	1	5	1	2	K	r/w		
1519	SET ROOM TEMPERATURE	x	x	x	Fan cooling	20	30	1	2	°C	r/w		
1520	RESET	x	x	x	Please note: Reset system is factory reset. All settings lost when performed.	1	3	1	6		r/w	FAULT LIST RESET	2
												HEAT PUMP RESET	3
												SYSTEM RESET	1
1521	RESTART ISG	x	x	x		0	2	1	6		r/w	OFF	0
												RESTART	1
												SERVICE KEY	2

* OFF via 9000Hex. Value between 20 and 70 °C activates function simultaneously. This function is available in the WPMsystem, the WPM 3 with software version 39005 or higher, and the WPM3i with software version 39106 or higher. With earlier software versions, this function can only be activated and adjusted.

Block 3: System status (Read input register)

Modbus address	Object designation	WPM-system	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Write/read (w/r)	Coding	Option
2501	OPERATING STATUS	x	x	x	bit-coded, WPM 3i does not support silent mode			6	r	HC 1 PUMP	B0
										HC 2 PUMP	B1
										HEAT-UP PROGRAM	B2
										NHZ STAGES RUNNING	B3
										HP IN HEATING MODE	B4
										HP IN DHW MODE	B5
										COMPRESSOR RUNNING	B6
										SUMMER MODE ACTIVE	B7
										COOLING MODE ACTIVE	B8
										MIN. ONE IWS IN DEFROST MODE	B9
										SILENT MODE 1 ACTIVE	B10
										SILENT MODE 2 ACTIVE (HP OFF)	B11
2502	POWER-OFF	x	x	x	bit-coded			8	r	POWER-OFF	B0

Modbus address	Object designation	WPM-system	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Write/read (w/r)	Coding	Option
2503	OPERATING STATUS	x			bit-coded			6	r	COMPRESSOR-1	B0
										COMPRESSOR-2	B1
										COMPRESSOR-3	B2
										COMPRESSOR-4	B3
										COMPRESSOR-5	B4
										COMPRESSOR-6	B5
										BUFFER CHARGING PUMP-1	B6
										BUFFER CHARGING PUMP-2	B7
										BUFFER CHARGING PUMP-3	B8
										BUFFER CHARGING PUMP-4	B9
										BUFFER CHARGING PUMP-5	B10
										BUFFER CHARGING PUMP-6	B11
										NHZ-1	B12
										NHZ-2	B13
2504	FAULT STATUS	x	x	x	System fault Fault acknowledgement via Servicewelt interface	0	1	6	r	NO FAULT	0
										FAULT	1
2505	BUS-STATUS	x	x	x		-4	0	6	r	STATUS OK	0
										STATUS ERROR	-1
										ERROR-PASSIVE	-2
										BUS-OFF	-3
										PHYSICAL-ERROR	-4
2506	DEFROST INITIATED	x	x		defrost initiated	0	1	6	r	OFF	0
										INITIATED	1
2507	active error	x	x	x	Fault number	0	65535	6	r		
2508	Message number	x			Message number	0	65535	6	r		
2509	HEATING CIRCUIT PUMP 1	x			WPM status	0	1	6	r		
2510	HEATING CIRCUIT PUMP 2	x			WPM status	0	1	6	r		
2511	HEATING CIRCUIT PUMP 3	x			WPM status	0	1	6	r		
2512	BUFFER CHARGING PUMP 1	x			WPM status	0	1	6	r		
2513	BUFFER CHARGING PUMP 2	x			WPM status	0	1	6	r		
2514	DHW CHARGING PUMP	x			WPM status	0	1	6	r		
2515	SOURCE PUMP	x			WPM status	0	1	6	r		
2516	FAULT OUTPUT	x			WPM status	0	1	6	r		
2517	DHW CIRCULATION PUMP	x			WPM status	0	1	6	r		
2518	WE 2 DHW	x			WPM status	0	1	6	r		
2519	WE 2 HEATING	x			WPM status	0	1	6	r		
2520	COOLING MODE	x			WPM status	0	1	6	r		
2521	MIXER OPEN, HTG CIRCUIT 2	x			WPM status	0	1	6	r		
2522	MIXER CLOSE, HTG CIRCUIT 2	x			WPM status	0	1	6	r		
2523	MIXER OPEN, HTG CIRCUIT 3	x			WPM status	0	1	6	r		
2524	MIXER CLOSE, HTG CIRCUIT 3	x			WPM status	0	1	6	r		
2525	NHZ 1	x			WPM status	0	1	6	r		

Modbus address	Object designation	WPM-system	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Write/read (w/r)	Coding	Option
2526	NHZ 2	x			WPM status	0	1	6	r		
2527	NHZ 1/2	x			WPM status	0	1	6	r		
2528	HEATING CIRCUIT PUMP 4	x			WPE status	0	1	6	r		
2529	HEATING CIRCUIT PUMP 5	x			WPE status	0	1	6	r		
2530	BUFFER CHARGING PUMP 3	x			WPE status	0	1	6	r		
2531	BUFFER CHARGING PUMP 4	x			WPE status	0	1	6	r		
2532	BUFFER CHARGING PUMP 5	x			WPE status	0	1	6	r		
2533	BUFFER CHARGING PUMP 6	x			WPE status	0	1	6	r		
2534	DIFF. CONTROLLER PUMP 1	x			WPE status	0	1	6	r		
2535	DIFF. CONTROLLER PUMP 2	x			WPE status	0	1	6	r		
2536	POOL PUMP, PRIMARY	x			WPE status	0	1	6	r		
2537	POOL PUMP, SECONDARY	x			WPE status	0	1	6	r		
2538	MIXER OPEN, HTG CIRCUIT 4	x			WPE status	0	1	6	r		
2539	MIXER CLOSE, HTG CIRCUIT 4	x			WPE status	0	1	6	r		
2540	MIXER OPEN, HTG CIRCUIT 5	x			WPE status	0	1	6	r		
2541	MIXER CLOSE, HTG CIRCUIT 5	x			WPE status	0	1	6	r		
2542	COMPRESSOR 1	x			Heat pump status 1	0	1	6	r		
2543	COMPRESSOR 2	x			Heat pump status 2	0	1	6	r		
2544	COMPRESSOR 3	x			Heat pump status 3	0	1	6	r		
2545	COMPRESSOR 4	x			Heat pump status 4	0	1	6	r		
2546	COMPRESSOR 5	x			Heat pump status 5	0	1	6	r		
2547	COMPRESSOR 6	x			Heat pump status 6	0	1	6	r		

Block 4: Energy data (Read input register)

Modbus address	Object designation	WPM-system	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Unit	Write/read (w/r)
3501	VD HEATING DAY	x	x	x	Amount of heat - all heat pumps	0	65535	6	kWh	r
3502	VD HEATING TOTAL	x	x	x	Amount of heat - all heat pumps	0	999	6	kWh	r
3503	VD HEATING TOTAL	x	x	x	Amount of heat - all heat pumps	0	65535	6	MWh	r
3504	VD DHW DAY	x	x	x	Amount of heat - all heat pumps	0	65535	6	kWh	r
3505	VD DHW TOTAL	x	x	x	Amount of heat - all heat pumps	0	999	6	kWh	r
3506	VD DHW TOTAL	x	x	x	Amount of heat - all heat pumps	0	65535	6	MWh	r
3507	NHZ HEATING TOTAL	x	x	x	Amount of heat - all heat pumps	0	999	6	kWh	r
3508	NHZ HEATING TOTAL	x	x	x	Amount of heat - all heat pumps	0	65535	6	MWh	r
3509	NHZ DHW TOTAL	x	x	x	Amount of heat - all heat pumps	0	999	6	kWh	r
3510	NHZ DHW TOTAL	x	x	x	Amount of heat - all heat pumps	0	65535	6	MWh	r
3511	VD HEATING DAY	x	x	x	Power consumption - all heat pumps	0	65535	6	kWh	r
3512	VD HEATING TOTAL	x	x	x	Power consumption - all heat pumps	0	999	6	kWh	r
3513	VD HEATING TOTAL	x	x	x	Power consumption - all heat pumps	0	65535	6	MWh	r
3514	VD DHW DAY	x	x	x	Power consumption - all heat pumps	0	65535	6	kWh	r
3515	VD DHW TOTAL	x	x	x	Power consumption - all heat pumps	0	999	6	kWh	r
3516	VD DHW TOTAL	x	x	x	Power consumption - all heat pumps	0	65535	6	MWh	r
3517	VD HEATING			x	Runtime	0	999	6	h	r
3518	VD DHW			x	Runtime	0	999	6	h	r
3519	VD COOLING			x	Runtime	0	999	6	h	r

Modbus address	Object designation	WPMsystem	WPM 3	WPM 31	Comments	Min. value	Max. value	Data type	Unit	Write/read (w/r)
3573	VD DHW TOTAL	x	x		Amount of heat HP 3	0	65535	6	MWh	r
3574	VD HEATING DAY	x	x		Power consumption HP 3	0	65535	6	kWh	r
3575	VD HEATING TOTAL	x	x		Power consumption HP 3	0	999	6	kWh	r
3576	VD HEATING TOTAL	x	x		Power consumption HP 3	0	65535	6	MWh	r
3577	VD DHW DAY	x	x		Power consumption HP 3	0	65535	6	kWh	r
3578	VD DHW TOTAL	x	x		Power consumption HP 3	0	999	6	kWh	r
3579	VD DHW TOTAL	x	x		Power consumption HP 3	0	65535	6	MWh	r
3580	VD 1 HEATING	x	x		Runtime HP 3			6	h	r
3581	VD 2 HEATING	x	x		Runtime HP 3			6	h	r
3582	VD 1/2 HEATING	x	x		Runtime HP 3			6	h	r
3583	VD 1 DHW	x	x		Runtime HP 3			6	h	r
3584	VD 2 DHW	x	x		Runtime HP 3			6	h	r
3585	VD 1/2 DHW	x	x		Runtime HP 3			6	h	r
3586	VD COOLING	x	x		Runtime HP 3			6	h	r
3587	VD HEATING DAY	x	x		Amount of heat HP 4	0	65535	6	kWh	r
3588	VD HEATING TOTAL	x	x		Amount of heat HP 4	0	999	6	kWh	r
3589	VD HEATING TOTAL	x	x		Amount of heat HP 4	0	65535	6	MWh	r
3590	VD DHW DAY	x	x		Amount of heat HP 4	0	65535	6	kWh	r
3591	VD DHW TOTAL	x	x		Amount of heat HP 4	0	999	6	kWh	r
3592	VD DHW TOTAL	x	x		Amount of heat HP 4	0	65535	6	MWh	r
3593	VD HEATING DAY	x	x		Power consumption HP 4	0	65535	6	kWh	r
3594	VD HEATING TOTAL	x	x		Power consumption HP 4	0	999	6	kWh	r
3595	VD HEATING TOTAL	x	x		Power consumption HP 4	0	65535	6	MWh	r
3596	VD DHW DAY	x	x		Power consumption HP 4	0	65535	6	kWh	r
3597	VD DHW TOTAL	x	x		Power consumption HP 4	0	999	6	kWh	r
3598	VD DHW TOTAL	x	x		Power consumption HP 4	0	65535	6	MWh	r
3599	VD 1 HEATING	x	x		Runtime HP 4			6	h	r
3600	VD 2 HEATING	x	x		Runtime HP 4			6	h	r
3601	VD 1/2 HEATING	x	x		Runtime HP 4			6	h	r
3602	VD 1 DHW	x	x		Runtime HP 4			6	h	r
3603	VD 2 DHW	x	x		Runtime HP 4			6	h	r
3604	VD 1/2 DHW	x	x		Runtime HP 4			6	h	r
3605	VD COOLING	x	x		Runtime HP 4			6	h	r
3606	VD HEATING DAY	x	x		Amount of heat HP 5	0	65535	6	kWh	r
3607	VD HEATING TOTAL	x	x		Amount of heat HP 5	0	999	6	kWh	r
3608	VD HEATING TOTAL	x	x		Amount of heat HP 5	0	65535	6	MWh	r
3609	VD DHW DAY	x	x		Amount of heat HP 5	0	65535	6	kWh	r
3610	VD DHW TOTAL	x	x		Amount of heat HP 5	0	999	6	kWh	r
3611	VD DHW TOTAL	x	x		Amount of heat HP 5	0	65535	6	MWh	r
3612	VD HEATING DAY	x	x		Power consumption HP 5	0	65535	6	kWh	r
3613	VD HEATING TOTAL	x	x		Power consumption HP 5	0	999	6	kWh	r
3614	VD HEATING TOTAL	x	x		Power consumption HP 5	0	65535	6	MWh	r
3615	VD DHW DAY	x	x		Power consumption HP 5	0	65535	6	kWh	r
3616	VD DHW TOTAL	x	x		Power consumption HP 5	0	999	6	kWh	r
3617	VD DHW TOTAL	x	x		Power consumption HP 5	0	65535	6	MWh	r
3618	VD 1 HEATING	x	x		Runtime HP 5			6	h	r
3619	VD 2 HEATING	x	x		Runtime HP 5			6	h	r
3620	VD 1/2 HEATING	x	x		Runtime HP 5			6	h	r
3621	VD 1 DHW	x	x		Runtime HP 5			6	h	r
3622	VD 2 DHW	x	x		Runtime HP 5			6	h	r
3623	VD 1/2 DHW	x	x		Runtime HP 5			6	h	r
3624	VD COOLING	x	x		Runtime HP 5			6	h	r
3625	VD HEATING DAY	x	x		Amount of heat HP 6	0	65535	6	kWh	r

Modbus address	Object designation	WPMsystem	WPM 3	WPM 31	Comments	Min. value	Max. value	Data type	Unit	Write/read (w/r)
3520	NHZ 1			x	Runtime	0	999	6	h	r
3521	NHZ 2			x	Runtime	0	999	6	h	r
3522	NHZ 1/2			x	Runtime	0	999	6	h	r
3523	VD HEATING DAY	x	x		Amount of heat HP 1	0	65535	6	kWh	r
3524	VD HEATING TOTAL	x	x		Amount of heat HP 1	0	999	6	kWh	r
3525	VD HEATING TOTAL	x	x		Amount of heat HP 1	0	65535	6	MWh	r
3526	VD DHW DAY	x	x		Amount of heat HP 1	0	65535	6	kWh	r
3527	VD DHW TOTAL	x	x		Amount of heat HP 1	0	999	6	kWh	r
3528	VD DHW TOTAL	x	x		Amount of heat HP 1	0	65535	6	MWh	r
3529	NHZ HEATING TOTAL	x	x		Amount of heat HP 1	0	999	6	kWh	r
3530	NHZ HEATING TOTAL	x	x		Amount of heat HP 1	0	65535	6	MWh	r
3531	NHZ DHW TOTAL	x	x		Amount of heat HP 1	0	999	6	kWh	r
3532	NHZ DHW TOTAL	x	x		Amount of heat HP 1	0	65535	6	MWh	r
3533	VD HEATING DAY	x	x		Power consumption HP 1	0	65535	6	kWh	r
3534	VD HEATING TOTAL	x	x		Power consumption HP 1	0	999	6	kWh	r
3535	VD HEATING TOTAL	x	x		Power consumption HP 1	0	65535	6	MWh	r
3536	VD DHW DAY	x	x		Power consumption HP 1	0	65535	6	kWh	r
3537	VD DHW TOTAL	x	x		Power consumption HP 1	0	999	6	kWh	r
3538	VD DHW TOTAL	x	x		Power consumption HP 1	0	65535	6	MWh	r
3539	VD 1 HEATING	x	x		Runtime HP 1			6	h	r
3540	VD 2 HEATING	x	x		Runtime HP 1			6	h	r
3541	VD 1/2 HEATING	x	x		Runtime HP 1			6	h	r
3542	VD 1 DHW	x	x		Runtime HP 1			6	h	r
3543	VD 2 DHW	x	x		Runtime HP 1			6	h	r
3544	VD 1/2 DHW	x	x		Runtime HP 1			6	h	r
3545	VD COOLING	x	x		Runtime HP 1			6	h	r
3546	NHZ 1	x	x		Runtime reheating stage			6	h	r
3547	NHZ 2	x	x		Runtime reheating stage			6	h	r
3548	NHZ 1/2	x	x		Runtime reheating stage			6	h	r
3549	VD HEATING DAY	x	x		Amount of heat HP 2	0	65535	6	kWh	r
3550	VD HEATING TOTAL	x	x		Amount of heat HP 2	0	999	6	kWh	r
3551	VD HEATING TOTAL	x	x		Amount of heat HP 2	0	65535	6	MWh	r
3552	VD DHW DAY	x	x		Amount of heat HP 2	0	65535	6	kWh	r
3553	VD DHW TOTAL	x	x		Amount of heat HP 2	0	999	6	kWh	r
3554	VD DHW TOTAL	x	x		Amount of heat HP 2	0	65535	6	MWh	r
3555	VD HEATING DAY	x	x		Power consumption HP 2	0	65535	6	kWh	r
3556	VD HEATING TOTAL	x	x		Power consumption HP 2	0	999	6	kWh	r
3557	VD HEATING TOTAL	x	x		Power consumption HP 2	0	65535	6	MWh	r
3558	VD DHW DAY	x	x		Power consumption HP 2	0	65535	6	kWh	r
3559	VD DHW TOTAL	x	x		Power consumption HP 2	0	999	6	kWh	r
3560	VD DHW TOTAL	x	x		Power consumption HP 2	0	65535	6	MWh	r
3561	VD 1 HEATING	x	x		Runtime HP 2			6	h	r
3562	VD 2 HEATING	x	x		Runtime HP 2			6	h	r
3563	VD 1/2 HEATING	x	x		Runtime HP 2			6	h	r
3564	VD 1 DHW	x	x		Runtime HP 2			6	h	r
3565	VD 2 DHW	x	x		Runtime HP 2			6	h	r
3566	VD 1/2 DHW	x	x		Runtime HP 2			6	h	r
3567	VD COOLING	x	x		Runtime HP 2			6	h	r
3568	VD HEATING DAY	x	x		Amount of heat HP 3	0	65535	6	kWh	r
3569	VD HEATING TOTAL	x	x		Amount of heat HP 3	0	999	6	kWh	r
3570	VD HEATING TOTAL	x	x		Amount of heat HP 3	0	65535	6	MWh	r
3571	VD DHW DAY	x	x		Amount of heat HP 3	0	65535	6	kWh	r
3572	VD DHW TOTAL	x	x		Amount of heat HP 3	0	999	6	kWh	r

Modbus address	Object designation	WPMsystem	WPM 3	WPM 3i	Comments	Min. value	Max. value	Data type	Unit	Write/read (w/r)
3626	VD HEATING TOTAL	x	x		Amount of heat HP 6	0	999	6	kWh	r
3627	VD HEATING TOTAL	x	x		Amount of heat HP 6	0	65535	6	MWh	r
3628	VD DHW DAY	x	x		Amount of heat HP 6	0	65535	6	kWh	r
3629	VD DHW TOTAL	x	x		Amount of heat HP 6	0	999	6	kWh	r
3630	VD DHW TOTAL	x	x		Amount of heat HP 6	0	65535	6	MWh	r
3631	VD HEATING DAY	x	x		Power consumption HP 6	0	65535	6	kWh	r
3632	VD HEATING TOTAL	x	x		Power consumption HP 6	0	999	6	kWh	r
3633	VD HEATING TOTAL	x	x		Power consumption HP 6	0	65535	6	MWh	r
3634	VD DHW DAY	x	x		Power consumption HP 6	0	65535	6	kWh	r
3635	VD DHW TOTAL	x	x		Power consumption HP 6	0	999	6	kWh	r
3636	VD DHW TOTAL	x	x		Power consumption HP 6	0	65535	6	MWh	r
3637	VD 1 HEATING	x	x		Runtime HP 6		6		h	r
3638	VD 2 HEATING	x	x		Runtime HP 6		6		h	r
3639	VD 1/2 HEATING	x	x		Runtime HP 6		6		h	r
3640	VD 1 DHW	x	x		Runtime HP 6		6		h	r
3641	VD 2 DHW	x	x		Runtime HP 6		6		h	r
3642	VD 1/2 DHW	x	x		Runtime HP 6		6		h	r
3643	VD COOLING	x	x		Runtime HP 6		6		h	r
3644	VD HEATING	x			Runtime HP 1		6		h	r
3645	VD DHW	x			Runtime HP 1		6		h	r
3646	VD HEATING	x			Runtime HP 2		6		h	r
3647	VD DHW	x			Runtime HP 2		6		h	r
3648	VD HEATING	x			Runtime HP 3		6		h	r
3649	VD DHW	x			Runtime HP 3		6		h	r
3650	VD HEATING	x			Runtime HP 4		6		h	r
3651	VD DHW	x			Runtime HP 4		6		h	r
3652	VD HEATING	x			Runtime HP 5		6		h	r
3653	VD DHW	x			Runtime HP 5		6		h	r
3654	VD HEATING	x			Runtime HP 6		6		h	r
3655	VD DHW	x			Runtime HP 6		6		h	r