



Report No: URPT-20260914-0002

Certificate No: N/A

Date: 14-09-2026

TEST REPORT
California Bearing Ratio

Report No: URPT-20260914-0002
Execution: #1 | Result Rev: 1 | Report Rev: 1
Sample: 26-000037 | Case: DMSPL-000025

Overall Decision: NOT_CONFIGURED
Approved: 14 Sep 2026 17:14
Tested: 14 Sep 2026 17:14

Customer / Sample

CustomerSILICON SIGNAL

AddressSCIENCE CITY, 380060

Sample26-000037 — Golden CBR with Spec - Granular Sub-base Soil v2 SPEC IS 2720 P16

GradeSUBGRADE

Branch / DeptDevine Laboratory / Geotechnical / Soil Department

Received14 Sep 2026

Test & Method (frozen)

TestSOIL_CBR — California Bearing Ratio

Discipline-

MethodCalifornia Bearing Ratio

Method Version1987

SpecificationPROJECT_SUBGRADE_CBR_SPEC - Project Subgrade CBR Specification

LayoutSOIL_CBR_LAYOUT (ObservationMatrix)

Results (finalized values)

Parameter	Result	Unit	Min	Max	Verdict
MOISTURE_CONTENT — Moisture Content	12.50	%	-	-	NOT_CONFIGURED
DRY_DENSITY — Dry Density	2.05	g/cc	-	-	NOT_CONFIGURED
MAX_DRY_DENSITY — Maximum Dry Density	2.15	g/cc	1.600000	2.400000	PASS
COMPACTION — Compaction	95.35	%	-	-	NOT_CONFIGURED
SAMPLE_PREPARATION_MOISTURE — Preparation Moisture	12.80	%	8.000000	14.000000	PASS
SURCHARGE_LOAD — Surcharge Load	5.00	kg	4.000000	6.000000	PASS
PENETRATION_2_5MM_LOAD — Load at 2.5 mm Penetration	1.08	kN	0.500000	2.000000	PASS
PENETRATION_5_0MM_LOAD — Load at 5.0 mm Penetration	1.52	kN	0.800000	2.500000	PASS
CBR_2_5 — CBR at 2.5 mm	8.18	%	5.000000	15.000000	PASS
CBR_5_0 — CBR at 5.0 mm	7.68	%	5.000000	15.000000	PASS
CBR_RESULT — CBR Result	8.18	%	-	-	NOT_CONFIGURED

Decision: ALL_REQUIRED_PASS | Acceptance: -

Conditions (configured vs actual)

Condition	Configured	Actual
- — Curing Age	= - -	-
- — Moisture Condition	= - -	-
- — Specimen Thickness	= - mm	-

Equipment (requirement vs used)

Equipment	Requirement	Calibration
Casagrande Apparatus	-	- (valid upto -)

Measurement Uncertainty (frozen)

Type: Expanded Uncertainty (k=2) | U = 2.500000 % (k = 2.0000, basis Type B)

Review / Verification / Approval

AnalystSystem Admin

ReviewerJinal Prajapati

Verified ByRonak Sinh Parmar 14 Sep 2026 17:14

Approved BySuper Admin 14 Sep 2026 17:14



Report No: URPT-20260914-0002 **Certificate No: N/A** **Date: 14-09-2026**

Review Remarks verified spec CBR v2 95.35 8.18
Approval Remarks approved spec CBR v2
Recorded scope status: Referenced; accreditation mark applied only where WithinScope.

System Admin Ronak Sinh Parmar Super Admin