



Report No: URPT-20260928-0002

ULR: TC50982600000001

Date: 28-09-2026

TEST CERTIFICATE / REPORT

Tensile Test at Ambient Temperature

Retest — Execution #2 (Previous: #1)

Report No.: URPT-20260928-0002

Report Status: RELEASED

Issue Date: 28-09-2026

Report Revision: 1

ULR No.: TC50982600000001

Result Revision: 1

1. Report & Test Identity

Test Execution ID	2	Test Group	1
Test Name	Tensile Test at Ambient Temperature	Test Category	TENSILE_TEST
Discipline	-	Department	Mechanical Testing Laboratory
Test Location	Devine Laboratory (Head Office)	Execution / Run No.	2
Retest	YES	Previous Execution	1

2. Sample Information

Sample ID	26-000001	Registration No.	DMSPL-000001
Sample Type	Fe 500D	Description	TMT Rebar 16mm Fe 500D Heat H-101
Quantity	-	Unit	-
Received Date	25-09-2026	Test Start Date	28-09-2026
Completion Date	28-09-2026		
Sampling Information			
Sampling Date	-	Sampled By	-
Sampling Method	-	Sampling Location	-

3. Customer / Request Information

Customer Name	E2E STEEL WORKS	Contact Person	-
Customer Address	14 GOPAL INDUSTRIAL ESTATE ODHAV AHMEDABAD, 382415	Contact Details	-
Customer Request No.	DMSPL-000001	Customer Reference	-
Project / Work Order	-		

4. Test Method & Specification

Test Method	Tension Testing of Metallic Materials	Method Code	IS 1608 (Part 1):2022
Method Version	Part 1:2022	Method Effective Date	-
Specification	IS_1786 - High Strength Deformed Steel Bars for Concrete Reinforcement	Specification Version	-
Product / Material	-	Grade	Fe 500D
Classification	-		

Applicable Requirement: IS_1786 - High Strength Deformed Steel Bars for Concrete Reinforcement
Decision Rule: ALL_REQUIRED_PASS

5. Test Conditions

No conditions configured —

6. Equipment & Metrological Traceability

Only equipment used / relevant to the frozen execution is displayed.

Equipment	ID / Serial No.	Traceability / Calibration
UTM-101	UTM-101-1000KN / UTM_TENSILE_1000KN	- (valid upto -)

7. Test Results & Conformity

No.	Test Parameter	Unit	Result	Requirement	Verdict
1	YIELD_STRENGTH — Yield Strength	MPa	540.00	500.000000 - -	PASS
2	TENSILE_STRENGTH — Tensile Strength	MPa	650.00	545.000000 - -	PASS
3	ELONGATION — Elongation	%	22.00	16.000000 - -	PASS

Result Interpretation: PASS / FAIL / INFORMATIONAL / NOT APPLICABLE

Overall Decision: PASS

Decision Basis: ALL_REQUIRED_PASS

8. Calculation / Derived Results

No calculated / derived results.

9. Measurement Uncertainty

U = 3.000000 % | Coverage probability / confidence: - | Coverage factor (k): 2.0000 | Basis: Type B



Report No: URPT-20260928-0002 ULR: TC50982600000001 Date: 28-09-2026

Parameter	Result	U	Coverage Factor (k)
YIELD_STRENGTH – Yield Strength	540.00	-	-
TENSILE_STRENGTH – Tensile Strength	650.00	-	-
ELONGATION – Elongation	22.00	-	-

U = expanded / configured uncertainty. If uncertainty is not configured for a parameter: U = -.

10. Compliance / Acceptance Summary

Parameter	Compliance Value	Effective Requirement	Margin / Delta	Verdict
YIELD_STRENGTH – Yield Strength	540.000000	500.000000 - -	-	PASS
TENSILE_STRENGTH – Tensile Strength	650.000000	545.000000 - -	-	PASS
ELONGATION – Elongation	22.000000	16.000000 - -	-	PASS

Total Evaluated	3 Parameters	Conforming (PASS)	3 Parameters
Non-Conforming (FAIL)	0 Parameters	Statement of Conformity	PASS
Applied Decision Rule	ALL_REQUIRED_PASS	Tolerance Applied	None
Tolerance Source	NONE	Guard Banding / MU	Direct Evaluation

11. Accreditation & Scope Information

Accreditation Status	Active	Certificate No.	TC5098
Accreditation Location	Devine Laboratory (Head Office)	Scope Status	WithinScope
NABL Symbol Status	APPLICABLE	ULR Status	APPLICABLE
ULR No.	TC50982600000001		

Scope Statement: 4

Accreditation claims are limited to the applicable accredited scope. Non-accredited results shall not be represented as accredited results.

12. Review, Verification & Approval

Stage	Performed By	Date / Time	Status
Tested By	Super Admin	28 Sep 2026 11:53	Completed
Reviewed By	-	-	Reviewed
Verified By	System Admin	28 Sep 2026 11:56	Verified
Approved By	User 10044	28 Sep 2026 11:57	Approved

Approval Status: APPROVED

Review Remarks: Independent technical verification by admin: readings 540/650/22 within frozen spec limits and NABL scope ranges, method IS 1608 Part 1:2022 adhered, UTM-101 valid. Verified.
Approval Remarks: Authorized signatory approval: verified result PASS Rev 1 accepted, NABL scope referenced under TC5098, report generation unlocked. Approved.

13. Report Authentication

Report No.: URPT-20260928-0002 | Report Revision: 1 | ULR No.: TC50982600000001

Verify this report online using the verification QR code or authentic URL reference.

Document Hash / Integrity Reference: 2ba555bdae0b14e700399551f2334dda868e3ba48fa973631927a6768ea117b5

14. Declarations, Terms & Conditions

1. Results relate only to the sample / test item identified in this report as received by the laboratory.
2. This test report shall not be reproduced except in full without written approval of the testing laboratory.
3. Metrological traceability of test results and measurement standards is maintained through valid calibration.
4. Accreditation claims and NABL Symbol apply only to the tests and parameters covered under valid scope.
5. Any amendments, corrections, or reissues are tracked under distinct Report Revision numbers and audit trail.

Super Admin

System Admin

User 10044



Verify Online