



1. SAMPLE & CUSTOMER IDENTIFICATION

Sample ID	: 26-000001	Customer Name	: E2E STEEL WORKS
Sample Reg. No.	: DMSPL-000001	Customer Address	: 14 GOPAL INDUSTRIAL ESTATE ODHAV AHMEDABAD, 382415
Material / Grade	: Fe 500D	Customer Ref/PO	: DMSPL-000001
Heat / Batch No.	: TMT Rebar 16mm Fe 500D Heat H-101	Sample Received	: 25-09-2026
Discipline/Group	: - / Mechanical Testing Laboratory	Date of Testing	: 28-09-2026 to 28-09-2026

2. TEST METHOD & SPECIFICATION

Test Standard	: IS 1608 (Part 1):2022	Governing Spec	: IS_1786 - High Strength Deformed Steel Bars for Concrete Reinforcement
Test Description	: TENSILE_TEST	Decision Rule	: ALL_REQUIRED_PASS

3. TEST RESULTS & CONFORMITY EVALUATION

#	Test Parameter	Test Method / Standard	Unit	Observed Value	Specified Requirement	Compliance
1	Yield Strength YIELD_STRENGTH	IS 1608 (Part 1):2022	MPa	540.00	500.000000 - -	PASS
2	Tensile Strength TENSILE_STRENGTH	IS 1608 (Part 1):2022	MPa	650.00	545.000000 - -	PASS
3	Elongation ELONGATION	IS 1608 (Part 1):2022	%	22.00	16.000000 - -	PASS

4. MEASUREMENT UNCERTAINTY & REMARKS (WHERE APPLICABLE)

- Expanded Uncertainty (U): ±3.000000 % at approx. 95.45% confidence level (coverage factor k = 2.0000).
- Remarks: Independent technical verification by admin: readings 540/650/22 within frozen spec limits and NABL scope ranges, method IS 1608 Part 1:2022 adhered, UTM-101 valid. Verified.

5. FOUR-EYES AUTHORIZATION & NABL AUTHENTICATION

Tested By:

Super Admin
Testing Technician / Analyst
Date: 28-09-2026

Verified By:

System Admin
Technical Reviewer / Verifier
Date: 28-09-2026

Approved By:

User 10044
Quality Manager / Technical Director
Date: 28-09-2026

