



Test Certificate

ULR No	-	Date of Issue	30-03-2026
Certificate No	-	Page	1 of 1
Customer Name	Harsh Gujral	Sample Received	29-03-2026
Customer Address	Bengaluru, KA, India	Test Performed At	Devine Laboratory

INFORMATION PROVIDED BY THE CUSTOMER

Reference	-		
Description	TMT 12mm Bar		
Stamped As	-	Sample Drawn By	-
Nature	TMT 12mm Bar		
Specification	TMT Bar		

MECHANICAL + METALS & ALLOYS

METALS & ALLOYS

Test Name: Tensile Test Test Method: IS 1608 Dt. of Testing: 29-03-2026

Specification: Tensile Test

Sr.	Parameter	Unit	Spec Min	Spec Max	Result
1	UTS	MPa	545	900	600
2	Yield	N/mm ²	500	900	900
3	Elongation	%	12	15	16

Test Images — Tensile Test



["Before Test"]

— End of Report —

Statement of Conformity

Decision Rule: With MOU consideration

Overall Result: **The test results do not conform to the specification requirements.**

Note: Expanded uncertainty (U) at 95% confidence level has been considered in the conformity assessment.

Remarks & Observations

UTS: First Observation
Yield: First Observation
Elongation: First Observation

Tested By
Sk Singh
HoD

Reviewed & Authorized By
Authorized Signatory
Director



Scan to verify