



## JV Management System

Doc Number : GMJV-KeNHA-BRW-WOM039FM008  
 Revision : 01  
 Doc Type : Form  
 Author/Owner : Wellington Odali  
 Reviewed by : Maurice Ademba  
 Effective Date : January 2022  
 Review Date : January 2023  
 Number Pages : Page 1 of 3  
 Approved by : Godfrey Walala

### Title: Daily Maintenance Report

Site Name		BUSIA WEIGHTBRIDGE		
Dates/Duration		29/07/2022		
Technician Name		YOUNG SAMUEL		
Systems		System Check		Comments/issues/observations
		X	✓	
Electrical Systems	<b>VOLTAGE</b>			
	<b>LINE VOLTAGE</b>			
	L1-L2	426	✓	Voltage okay. All within range.
	L1-L3	430	✓	
	L2-L3	427	✓	
	<b>PHASE VOLTAGE</b>			
	L1-N	243	✓	
	L2-N	246	✓	
	L3-N	245	✓	
	<b>PHASE &amp; EARTH</b>			
	L1-E	243	✓	
	L2-E	242	✓	
	L3-E	245	✓	
	<b>OTHER APPLIANCES</b>			
	Isolators		✓	All appliances okay.
MCCBs		✓		
Contactors		✓		
MCBs		✓		
Photocells		✓		
Scales systems Check the following:-	Scale Accuracy		✓	Accurate
	Indicator Functionality		✓	okay
	System Grounding		✓	okay
	Remote Display Unit		✓	Function.
		X		



## JV Management System

Doc Number : GMJV-KeNHA-BRW-WC-M039FM008

Revision : 01

Doc Type : Form

Author/Owner : Wellington Odali

Reviewed by : Maurice Ademba

Effective Date : January 2022

Review Date : January 2023

Number Pages : Page 2 of 3

Approved by : Godfrey Walala

### Title: Daily Maintenance Report

<b>Traffic control system</b> Check the following:-	Booms functionality	✓	✓	Okay. Arms not Connected
	Traffic lights	✓	✓	Okay
	Clean cameras	✓	✓	Okay
	Network equipment			N/A
<b>Generator</b> Check the following:-	Battery Voltage	✓	✓	13.7V
	Test run genset	✓	✓	Okay
	Fuel level	✓	✓	3/4 full
	Voltages on test run(vac)	✓	✓	L-L-430V, L-N-246V Okay
	Run hours to service	✓	✓	27.4 hrs.
	Emergency button	✓	✓	Okay
<b>Buildings &amp; General Maintenance</b> Check the following:-	Power to Buildings	✓	✓	All power supplies Okay.
	Power to Switches	✓	✓	
	Power to socket outlets	✓	✓	
	Power to Bulbs	✓	✓	
	Power to Floodlights	✓	✓	
	Air Conditioners	X	✓	10P AC faulty. 20W AC mod 3 Maintenance
	Leaking Roof	X	✓	None
	Drainage	✓	✓	Okay.

 <b>GOKHAN &amp; MASTERSPACE JV LIMITED</b>	<b>JV Management System</b>	Doc Number : GMJV-KeNHA-BRW-WC039FM008 Revision : 01 Doc Type : Form Author/Owner : Wellington Odali Reviewed by : Maurice Ademba Effective Date : January 2022 Review Date : January 2023 Number Pages : Page 3 of 3 Approved by : Godfrey Walala
	<b>Title: Daily Maintenance Report</b>	

Others					
				None	
<b>Health, Safety &amp; Environment</b>  Check the following:	Adherence to safety procedures by staff		✓	} All adhered to.	
	Adheres to min PPE		✓		
	Potential hazards	X			None

Prepared By: (Technician) YOUNG SAMUEL Sign [Signature]  
 Checked By: (Duty Manager) Dayando Mgamuler Sign [Signature]







## JV Management System

Title: HSWIM Check List

Doc Number : GMJV-KENHA-BRW-WOM039FM004

Revision : 01

Doc Type : Form

Author/Owner : Wellington Odali

Reviewed by : Maurice Ademba

Effective Date : January 2022

Review Date : January 2023

Number Pages : Page 1 of 1

Approved by : Godfrey Walala

### HSWIM CHECK LIST

Name of Technician

YOUNG SAMUEL

Date or Duration valid

29/07/2022

Site Name


BUSIA WEIGHBRIDGE

PHYSICAL & SYSTEM CHECKS	FREQ	✓	X	COMMENTS
1. Check on the functionality of Weighing Sensors	D	✓		} All functionalities Okay
2. Check on the functionality of Loops	D	✓		
3. Check on the functionality of MSI Position Sensors	D	✓		
4. Check on the functionality of ANPR cameras	D	✓		
5. Check on the functionality of Overview Cameras	D	✓		
6. Check on the alignment of ANPR and Overview Cameras	D	✓		well-aligned
7. Check on the functionality of gantry floodlights	D	✓		okay
8. Check whether HSWIM parameters are transmitted and viewed at the Directing Office.	D	✓		well-transmitted
9. Check on the state of Grounding and Lightening Arrestors	D	✓		Grounding okay
10. Check on the Physical State of HSWIM Equipment	D	✓		okay
i) Check cables are intact and well terminated and not exposed	D	✓		okay
ii) Check on the grouting status of the sensors	M	✓		} secured
iii) Check on the physical state of the gantry (ensure it is not knocked/damaged)	D	✓		
iv) Check on the state of gantry protection (bollards)	D	✓		
v) Check cable routing (pipes, sleeves and ducts) are secure and not flooded with water	D	✓		No floods
vi) Check whether silt/soil has accumulated at the sensor area	D	✓		No silt
vii) Check drainage around the sensor area to ensure it is not flooded.	D	✓		No floods
11. Check on the white box components	D			
i) Check on the functionality and physical state of Breakers, Connectors, PLCs, Network Switches, Power Supply and cable termination.	D	✓		} okay
*Gantry Cameras to be cleaned and aligned monthly	M	✓		

N/B - Above checklist only applies for Busia Bound HSWIM.

Prepared By: (Technician) YOUNG SAMUEL Sign [Signature]

Checked By: (Duty Manager) Onyando Mawulur Sign [Signature]





## JV Management System

Doc Number : GMJV-KeNHA-BRW-WO-M039FM007

Revision : 01

Doc Type : Form

Author/Owner : Wellington Odali

Reviewed by : Maurice Ademba

Effective Date : January 2022

Review Date : January 2023

Number Pages : Page 1 of 1

Approved by : Godfrey Walala

### Title: SCALE ANPR, SCALE SIDE VIEW & CCTV CAMERAS CHECK LIST

### SCALE ANPR, SCALE SIDE VIEW & CCTV CAMERAS CHECKLIST

Name of Technician

YOUNG SAMUEL

Date or Duration valid

29/07/2022

Site Name

BUSIA WEIGHBRIDGE

CAMERAS CHECKLIST	FREQ	✓	X	Comments
<b>ANPR &amp; Side View photos</b>				
1. Check with the system administrators at the image server all cameras to ensure they are all ON	D	✓		ANPR & Side View cameras okay.
2. If all cameras are OFF check the single phase consumer unit at the weighing room for any tripped MCB	D	✓		
3. If the cameras are OFF randomly, check the yellow boxes at the camera pole for a tripped MCB or a faulty blue ginger PSU (check LED)	D	✓		
4. If blue ginger and/or circuit breaker are faulty after testing the input and output ensure they are replaced (AC circuit breaker input & output=240V while Blue ginger input AC 240V & output DC 12V)	D	✓		
5. If 4 above is true test the camera functionality from the server with the system admin	D	✓		
6. Inspect cameras' 4 port IP switches in the outdoor housing-Check that its powered, ports LED blinking, cables connected securely	W	✓		
7. Inspect all cameras for physical damage or misalignment	D	✓		
8. Inspect cameras view relative to master alignment photo.	D	✓		
9. If camera is misaligned after 7 above, realign the camera as required and test the view from the image server again	D	✓		
10. Wipe all camera view window with a clean damp cloth followed by a dry lint free cloth till the window is clean	W	✓		
11. Inspect the lanes next to the cameras for probable danger of knocking the poles and advise accordingly	D	✓		
12. Check floodlights for proper functionality-ON/OFF status as required- (Night inspection)	W	✓		
13. Check floodlights for proper alignment	W	✓		
<b>CCTV</b>				
1. Check at the LED monitor for ON or OFF status for all CCTV cameras	D	✓		CCTV cameras functionalities okay.
2. If any camera is OFF check the single phase consumer unit at the weigh room for any tripped MCB	D	✓		
3. Check BNC connectors for proper connections at the back of the DVR in case 2 above is ON and cameras are still OFF	D	✓		
4. Check for proper focus of each CCTV camera	W	✓		
5. If any camera is off focus, have a person (system admin) at the screen and yourself at the camera to adjust the focus knobs under the Redi view cameras till focus is restored.	W	✓		
6. Check the playback of the CCTV cameras at the DVR at different dates and time	W	✓		
7. Inspect the CCTV cameras for physical damage and misalignment	W	✓		
8. If misaligned after 6 above ensure they are correctly aligned as the per the master alignment photo	W	✓		
9. Wipe all camera view window with a clean damp cloth followed by a dry lint free cloth till the window is clean	W	✓		

#### NOTES

1. Use a lint free cloth to clean Camera lenses and windows
2. Use a properly functioning multimeter to measure voltage
3. Ensure you have all minimum personal protective safety gear while working at heights

YOUNG SAMUEL

Maurice Ademba

29 JUL 2022







## JV Management System

Doc Number : GMJV-KeNHA-BRW-WOM039FM002

Revision : 01

Doc Type : Form

Author/Owner : Wellington Odali

Reviewed by : Maurice Adamba

Effective Date : January 2022

Review Date : January 2023

Number Pages : Page 1 of 2

Approved by : Godfrey Walala

Title: Generator Start-Up Form

Name of Technician

YOUNG SAMUEL

Date or Duration valid

29/04/2022

Site Name

BUSIA WRIGHTBRIDGE

### GENERATOR START UP PROCEDURE-14KVA 3PHASE TEKSAN GENERATOR

	✓	X	COMMENTS
1. Ensure the emergency (RED) buttons are NOT pressed in. If pressed-in twist clockwise and the button will pop out.	✓		Done. All functions Okay.
2. Press the STOP soft key for 2 seconds to clear any old emergency status	✓		
3. Press the AUTO soft key till the GREEN LED appears to show the generator is on automatic standby.	✓		
4. In case the generator is switched off using the emergency button, follow the steps 1 to 3 again	✓		
5. Whenever the generator does not start automatically and its on AUTO standby, press the OFF soft key button then press either AUTO or MANUAL soft key button	✓		
6. When generators comes ON after procedure 5. above press the AUTO soft key button	✓		
7. To stop the generator whenever the automatic change over does not switch it OFF use the STOP soft key not the EMERGENCY button	✓		
8. Always ensure before locking the generator shelter that you inspect it for leakages. Follow steps 1 and finally inspect the cables	✓		



## JV Management System

Doc Number : GMJV-KeNHA-BRW-WOM039FM002

Revision : 01

Doc Type : Form

Author/Owner : Wellington Odali

Reviewed by : Maurice Ademba

Effective Date : January 2022

Review Date : January 2023

Number Pages : Page 2 of 2

Approved by : Godfrey Walala

Title: Generator Start-Up Form

### RESETTING THE GENERATOR AFTER SERVICE ALARMS COME ON

1. Use the programme (PGM) arrow < > soft keys to select the function on the controller screen.	✓		
2. Select COUNTERS screen, the first screen will show engine total hours of running, after pressing the arrow key again, the second COUNTERS screen will show Engine hours to service request	✓		
3. If the hours (100hrs) to service request have already been achieved and the alarm lamp for service request and the hazard lamp are ON, call the service provider immediately	✓		
4. To enable the generator to run before the service provider is on site, clear the alarms by pressing the test lamp ⚡ and the alarm ⏏ soft key buttons together for 2secs till alarm ! Clears then press the STOP soft key button to clear the alarm for service request.	✓		
5. Press the AUTO button soft key button.	✓		

Done - All  
functionality  
Okay



Prepared By: (Technician) YOUNG SAMUEL Sign Samuel

Checked By: (Duty Manager) Onyando Maxmuler Sign Onyando