

Doc Number:

GMJV-KeNHA-BRW-WOM039FM008

Revision:

01

Doc Type: Form
Author/Owner: Wellingtone Odali

Reviewed by: Maurice Ademba
Effective Date: January 2022

Review Date: January 2023

Number Pages: Page 1 of 3

Approved by: Godfrey Walala

Title: Daily Maintenance Report

Site Name		RONGO WEIGHBRIDGE.						
Dates/Duration		16.08.2022						
Technician Name		HILL	HILLARY ONTAMO					
			System Check					
Systems			Х		Comments/issues/observations			
	VOLTAGE			-				
Electrical Systems	LINE VOLTAGE	-						
	L1-L2	412		~				
	L1-L3	417		4				
	L2-L3	418		4	GAII WHORESOIL			
	<u>PHASE</u> <u>VOLTAGE</u>		2					
	L1-N	238		1				
	L2-N	237		/				
	L3-N	237		4	ANG 2 2?			
	PHASE & EARTH				WHAT HIDAM			
	L1-E	238		V	16 AUG S.S.			
	L2-E	238			& AUG CO			
	L3-E	238			Manager Hungs 1: 001001 Hull P.O.BOX 49112			
	OTHER APPLIANCES				Manager Hung 2, 00 NV			
				.)	O.BON II			
	Isolators							
	MCCBs			~				
	Contactors				All functional.			
	Contactore							
	MCBs			~				
	Photocells							
Scales systems								
Check the following:-	Scale Accuracy			•	O &			
	Indicator Functionality			/	06			
	System Grounding							
	External Display		X		Wounding ou			



Doc Number: GM

GMJV-KeNHA-BRW-WOM039FM008

Revision :
Doc Type :

Form

Author/Owner: Wellingtone Odali
Reviewed by: Maurice Ademba
Effective Date: January 2022
Review Date: January 2023
Number Pages: Page 2 of 3

Approved by: Godfrey Walala

Title: Daily Maintenance Report

Traffic control system		×		Fuilty
Check the following:-	Booms functionality			
	Traffic lights	Χ		/A .
	Clean cameras		/	7
			./	\@W
	Network equipment		~	
Generator Check the following:-				13.6
oneck the following	Battery Voltage		V	().0
			V	Done
	Test run genset			at the second
	Fuel level		V	"If Jank
				L-L-417V, L-N-233V
	Voltages on test run(vac)			38 00 hours
	Run hours to service			5,0 0 We oot)
	Face and the state of			9 L
	Emergency button		Y	
Buildings & General Maintenance				
Check the following:-	B T T T			
	Power to Buildings		V	
	Power to Switches		/	
	Power to socket outlets			All Supplies on
	Fower to socket outlets			
	Power to Bulbs			
	Power to Floodlights	٤		
	Power to Floodlights	16	•	V
	Air Conditioners		<u> </u>	9 lu
	Leaking Roof	\times		Na
	Drainage	2		



Title: Daily Maintenance Report

Doc Number :

GMJV-KeNHA-BRW-WOM039FM008

Revision:

Form

Doc Type :

Author/Owner: Wellingtone Odali

Reviewed by: Maurice Ademba Effective Date: January 2022 Review Date: January 2023

Number Pages: Page 3 of 3

Approved by: Godfrey Walala

				PA.
Others				
Health, Safety & Environment				
Check the following:	Adherence to safety procedures by staff		/	[& dhered to one
	procedures by stair		7/	
	Adheres to min PPE			
	Potential hazards	X	Sp2	W/A
epared By: (Technician)	HILLARY ONTA.	NDC)	Sign
acked By: (Duty Manager)				Sign ANTHORY



Title: Generator Start-Up Form

Doc Number: GMJV-KeNHA-BRW-WOM039FM002

Revision: Doc Type:

Form

Author/Owner: Wellingtone Odali

Number Pages: Page 1 of 2

Reviewed by:

Maurice Ademba

Effective Date: January 2022

Review Date:

January 2023

Approved by:

Godfrey Walala

Name of Technician	HILLARY OMANDO
Date or Duration valid	16.02.2022
<u>Site Name</u>	RONGO.

	\checkmark	X	COMMENTS
Ensure the emergency (RED) buttons are NOT pressed in. If pressed-in twist clockwise and the button will pop out.	/		Dan
2. Press the STOP soft key for 2 seconds to clear any old emergency status	1		Ou
3. Press the AUTO soft key till the GREEN LED appears to show the generator is on automatic standby.	/		Ou
4. Incase the generator is switched off using the emergency button, follow the steps 1 to 3			01-
5. Whenever the generator does not start automatically and its on AUTO standby, press the OFF soft key button then press either AUTO	/		Ow
6. When generators comes ON afrer procedure 5. above press the AUTO soft key	~		On
7. To stop the generator whenever the automatic change over does not switch it OFF use the STOP soft key not the EMERGENCY	1		OL
8. Always ensure before locking the generator shelter that you inspect it for leakages. Follow steps 1 and finally inspect	1		Done



Title: Generator Start-Up Form

Doc Number: GMJV-KeNHA-BRW-WOM039FM002

Revision:

Form

Doc Type:

Author/Owner: Wellingtone Odali

Reviewed by: Maurice Ademba

Effective Date: January 2022

Review Date: January 2023 Number Pages: Page 2 of 2

Godfrey Walala Approved by:

RESETTING THE GENERATOR AFTER SERVICE ALARMS COME ON

1. Use the programme (PGM) arrow < > soft keys to select the function on the controller screen.		Ou
2. Select COUNTERS screen, the first screen will show engine total hours of running, after pressing the arrow key again, the second COUNTERS screen will show Engine hours to service		Qu
3. If the hours (100hrs) to service request have already been achieved and the alarm lamp for service request and the hazard lamp are ON, call the service provider immediately	/	Ou
4. To enable the generator to run before the service provider is on site, clear the alarms by pressing the test lamp ☼ and the alarm ∃ ◀ soft key buttons together for 2secs till alarm! Clears then press the STOP soft key button to clear the alarm for service request.	1	6 li
5. Press the AUTO button soft key button.	./	ou

Prepared By: (Technician) __ + TLLARY

Checked By: (Duty Manager) Duncan ONGE Sign

Sign OX



Doc Number:

GMJV-KeNHA-BRW-WOM039FM007

Revision : Doc Type :

01

Form

Author/Owner: Wellingtone Odali Reviewed by: Maurice Ademba Effective Date: January 2022

Review Date: January 2023

Number Pages: Page 1 of 1

Number Pages: Page 1 of 1

Approved by: Godfrey Walala

Title: SCALE ANPR, SCALE SIDE VIEW & CCTV CAMERAS CHECK LIST

SCALE ANPR. SCALE SIDE VIEW & CCTV CAMERAS CHECKLIST

Name of Technician

Date or Duration valid

Site Name

HUART	ONYAWDO
16.08:20	22
RONGO.	

CAMERAS CHEKLIST	FREQ	√	Х	Comments
ANPR & Side View photos				
Check with the system administrators at the image server all cameras to ensure they are all ON	D	/		04
If all cameras are OFF check the single phase consumer unit at the weighing room for any tripped MCB	D	~		OK
If the cameras are OFF randomly, check the yellow boxes at the camera pole for a tripped MCB or a faulty blue ginger PSU (check LED)	D	~		Bli
 If blue ginger and/or circuit breaker are faulty after testing the input and output ensure they are replaced (AC circuit breaker input & output=240\/while Blue ginger input AC 240V & output DC 12V) 	98	V		OK ANPR and
5. If 4 above is true test the camera functionality from the server with the system admin	D			Qu SV, Cameras
Inspect cameras' 4 port IP switches in the outdoor housing-Check that its powered, ports LED blinking, cables connected securely	w	/		Or are not
7. Inspect all cameras for physical damage or misalignment	D	V		Ou (ntigrated.
Inspect cameras view relative to master alignment photo. If camera is misaligned after 7 above, realign the camera as required.	D			Qu)
and test the view from the image server again 10. Wipe all camera view window with a clean damp cloth followed by a	D	/		Dh Dh
dry lint free cloth till the window is clean 11. Inspect the lanes next to the cameras for probable danger of	W			
knocking the poles and advise accordingly 12. Check floodlights for proper functionality-ON/OFF status as required- (Night inspection)	D W			OL JUNAYS AUTHORIA
13. Check floodlights for proper alignment	w	_/		OW HIGHWAYS AUTHORITY OW HIGHWAYS AUTHORITY
ссту				Me S ST
Check at the LED monitor for ON or OFF status for all CCTV cameras	D	V		161
If any camera is OFF check the single phase consumer unit at the weigh room for any tripped MCB Check BNC connectors for proper connections at the back of the DVR	D	~		Manager in man 2, 00105 M. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1.
in case 2 above is ON and cameras are still OFF	D	~		Cameras
Check for proper focus of each CCTV camera If any camera is off focus, have a person (system admin) at the	w			p are all one
screen and yourself at the camera to adjust the focus knobs under the Redi view cameras till focus is restored.	W			and somused
Check the playback of the CCTV cameras at the DVR at different dates and time	w			()
7. Inspect the CCTV cameras for physical damage and misalignment 8. If misaligned after 6 above ensure they are correctly aligned as the per	W		*	
the master alignment photo 9. Wipe all camera view window with a clean damp cloth followed by a	W			
dry lint free cloth till the window is clean	W			

NOTES

- 1. Use a lint free cloth to clean Camera lenses and windows
- 2. Use a properly functioning multimeter to measure voltage
- 3. Ensure you have all minimum personal protective safety gear while working at heights



Doc Number:

GMJV-KeNHA-BRW-WOM039FM005

Revision:

Doc Type:

Form

Author/Owner: Wellingtone Odali Reviewed by: Maurice Ademba Effective Date: January 2022

Review Date: January 2023 Number Pages: Page 1 of 1

Approved by: Godfrey Walala

Title: Loggers Checklist

LOGGERS CHECKLIST

Name of Technician	HILLARY OWNANDS
Date or Duration valid	16,08.2022
Site Name	RONGOI

LOGGER CHECK LIST	FREQ	ои/√	OFF/X	COMMENTS
Physical Checks				
1. Check AC MCB on the LHS	D	V		04
2. Battery Charger Status	D		*	7 Batter and Charge Gaulty.
3. Battery charging	D		X	
4. Loops CPU LED	D	/		Ŏ
5. Loops LEDs	D	4		
6. CPU LEDs	D	~		Longos De
7. Classification LEDs	D	V		
8. Check cables-loops and other communication cables	D	~		26 150
9. Functionality checks	2*D	1		5 turctional.
Functional Checks				
Connect to Hyperterminal on Laptop	2*D		X	
2. Press I to check for setup information (date, time, site name)	2*D		X	
3. Press Q to check loop frequencies	2*D		×	Not connected to see
4. Press lane numbers (1,2,3) and check lane vehicle information	2*D		X	pot connected to see hyperterminal.
check the logical reaction of the logger on each lane	2*D		V	
6. Log off by pressing O	2*D		X	TIGHAL HICHWAYS AUTHORITY

- NOTES

 1. While doing the functional test, have a laptop with hyperterminal software installed and a USB to serial converter.
- 2. Ensure the outdoor housing is free of dust before locking
- 3. Ensure housing is properly locked after the procedure

Prepared By: (Technician)

Sign

Manager Rome 12 00000 Hill P.O.BOX 49112

Checked By: (Asst Weighbridge Manager)

Sign