# Inspection Guide 64CSR16 Recreational Water Facilities

#### **Chapter 4 Operating Permit**

- 4.1 Permit needed to operate
- 4.2 Submitting application
- 4.3 Application submitted 15 days
- 4.4 Application accurate
- 4.5 Compliance with provisions
- 4.6 Date of operation
- 4.7 Permit non-transferable
- 4.8 Change of ownership
- 4.9 Suspension of permit
- 4.10 Reinstatement of permit
- 4.11 Permit posted
- 4.12 Permit appeals

#### **Chapter 5 Inspections, Closure**

- 5.1 Inspected 2 times per year
- 5.2 Operator provides access
- 5.3 Inspection report
- 5.4 Closure events
- 5.5 Remain closed until verified

#### **Chapter 6 Design, Construction**

6.1 Meets NSPI1, NSPI2, APSP7

## **Chapter 7 Water Quality Disinfection**

- 7.1a Continuous feed disinfection
- 7.1b No hand feeding except shocking
- 7.1c Disinfection material req.
- 7.1d Chlorine 1-5ppm
- 7.1e Bromine 2-5ppm
- 7.1f Other Disinfection materials req.
- 7.1g Cyanuric Acid 10-100ppm

#### **Chemical Requirements**

- 7.2a Chemical requirements
- 7.2b Chemical req. Bathing beaches
- 7.3 Bacteriological Sample
- 7.3f Bact. Sample Bathing Beach

#### pH and Alkalinity

- 7.4a pH: 7.2 7.8
- 7.4b. Gas chlor. no hand feeding
- 7.4c Total Alkalinity: 60 180ppm

## **Water Clarity**

- 7.5a Clarity
- 7.5b Follow table 64016C

## **Chapter 8 Control Tests & Records**

- 8.1 Approved test kit
- 8.2 DPD method for free chlorine
- 8.3 Maintain records for 1 year
- 8.4 Weekly summary submitted to HD
- 8.5 Test for free chlorine/pH 2x daily
- 8.6 New reagents twice a year
- 8.7 Free chlorine ≤.5ppm, close pool
- 8.8 Free bromine ≤1ppm, close pool

#### **Chapter 9 Supervision of Patrons**

- 9.1 CPO available
- 9.2 Operator can exclude patrons
- 9.3 Required rules
- 9.4 Rule sign posted

## **Chapter 10 Safety Requirements**

- 10.1 Shepard's hook and reach pole
- 10.2 1 rescue tube per lifeguard
- 10.3 No lifeguards 1 unit of equip.
- 10.4 Equipment in good repair
- 10.5 First aid kit
- 10.6 No lifeguards with sores or sick
- 10.7 Lifeguards have access to PPE
- 10.8 Lifeguards certified
- 10.8g If no Lifeguards Warning sign
- 10.9 OSHA bloodborne pathogen plan
- 10.10 Emergency phone
- 10.11 Emergency plan
- 10.12 Drain entrapment avoided
- 10.12a Single drain meets NSPI 1 & 2
- 10.12b Spas shut-off switch & alarm
- 10.13 Comply with 87CSR01 Fire Code
- 10.14 Patron load per NSPI1

## **Chapter 11 Routine Maintenance**

- 11.1 Decks, sidewalks clean
- 11.2a Debris removed from pool
- 11.2b Water surface clean
- 11.2c Drained as necessary for repair
- 11.2d Pump, eq. operates 24 hours
- 11.3 Indoor-ventilation meets 62-199

## **Chapter 12 Bathhouse, Concession**

- 12.1 # of facilities meets 87 04 Code
- 12.2 Bathhouse and facilities clean
- 12.3 Toilet paper at each toilet
- 12.4 Hand cleaner and drying device
- 12.5 Hot and cold running water
- 12.6 Concession meets Food Code
- 12.7 GPH placard in pump room

## **Chapter 13 Compliance**

- 13.1 Facility closed per table 64-16A
- 13.2 Water clarity bathing beach
- 13.3 Bathing beach closer
- 13.4 Written record of closure events