

		West Virginia Department of Health and Human Resources			
		MANUAL OF ENVIRONMENTAL HEALTH PROCEDURES			
Section	Drinking Water	Date	February 25, 1976	Procedure #	DW-1
Subject	Individual Water Supplies			Page	1 of 1

This is a reminder of this department's long standing policy relating to approval of spring or cistern water supplies. Spring and cistern water supplies ARE NOT TO BE APPROVED by the health department without chlorination. This means that a positive feed hypochlorinator must be installed on all such systems.

This policy applies to

1. All such water supplies serving public facilities.
2. Facilities tendering to the public.
3. Tenant occupied property.
4. Water supplies requiring health department approval for mortgage loans and guarantees thereof.

References

History

Attachments