



Fire Safety Log Book

Prepared for use in conjunction with the Fire Risk Assessment

Premises Name	
Premises Address	
Date From	
Date To	
Location of Log Book	
Responsible Person	

This log book uses a recommended format for recording fire safety checks, tests and maintenance. Keeping it complete and up to date helps show compliance with the Regulatory Reform (Fire Safety) Order 2005 (as amended) and supports the fire safety strategy set out in the current Fire Risk Assessment.

Extra copies of any page can be printed when a table is full. Keep this log book where staff can find it, with the Fire Risk Assessment and the latest certificates.

This log book is a record-keeping tool. It does not replace a Fire Risk Assessment or the Responsible Person's legal duties under the Regulatory Reform (Fire Safety) Order 2005 (as amended).

dalmatianfiresafety.co.uk

Version v26-10

Contents

Click or tap an entry to jump to that page.

Check schedule: what to do, and how often.....	3
Section A — Fire Risk Assessment Record.....	4
Section B — Remedial Actions Record.....	5
Section 1 — Daily Checks.....	6
Section 2 — Fire Detection and Warning System Test Record.....	7
Section 3 — Record of False Fire Alarms.....	8
Section 4 — Fire Extinguisher Test Record.....	9
Section 5 — Emergency Escape Lighting Test Record.....	10
Section 6 — Sprinkler / Suppression System Test Record.....	11
Section 7 — Dry / Wet Riser Inspection Record.....	12
Section 8 — Smoke Control / AOV Test Record.....	13
Section 9 — Fire-Fighting / Evacuation Lift Test Record.....	14
Section 10 — Fire Door Check Record.....	15
Section 11 — Signs and Notices Check Record.....	16
Section 12 — Fire Instruction / Training Record.....	17
Section 13 — Fire Drill Record.....	18
Section 14 — Gas and Heating Servicing Record.....	19
Section 15 — Electrical Installation (EICR) Record.....	20
Section 16 — Portable Appliance Testing (PAT) Record.....	21
Section 17 — Contractors and Hot Works Record.....	22
Section 18 — Commercial Kitchen Extraction / Ductwork Record.....	23
Section 19 — EV Charging Point Inspection Record.....	24
Section 20 — Forklift / Battery Charging Equipment Maintenance Record.....	25
Section 21 — Fire Safety Inspector / Fire and Rescue Service Visits.....	26

Check schedule: what to do, and how often

The coloured columns are the checks you and your staff do regularly. Each item shows the section where it is recorded. Items marked 'if fitted' only apply if the premises has that equipment. Your Fire Risk Assessment may set different frequencies for your building: follow it where it does.

	DAILY	WEEKLY	MONTHLY	SIX-MONTHLY	ANNUAL	OTHER INTERVALS / AS NEEDED
You / your staff	Walk-round: exits, escape routes, doors, alarm panel, emergency lights, extinguishers. Sec 1 Fire doors close and aren't wedged open. Sec 10	Test one manual call point and check automatic door releases. Sec 2 Sprinkler weekly checks (if fitted). Sec 6 Smoke control weekly test (if fitted). Sec 8	Extinguishers: visual inspection. Sec 4 Emergency lighting: flick test. Sec 5 Fire doors: self-closers, seals, hinges. Sec 10 Smoke control monthly test (if fitted). Sec 8	Dry / wet riser: visual inspection (if fitted). Sec 7		Fire risk assessment: review usually yearly, and track actions. Sec A, Sec B Log each false alarm when it happens. Sec 3 Signs and notices. Sec 11 Training and drills. Sec 12, Sec 13 Contractors and hot works. Sec 17 Authority visits. Sec 21
Competent contractor				Fire alarm servicing is usually six-monthly: keep the service certificates with this log book.	Extinguisher service. Sec 4 Emergency lighting full-duration test. Sec 5 Sprinkler inspection (if fitted). Sec 6 Riser pressure test (if fitted). Sec 7 Smoke control (if fitted). Sec 8 Fire doors: detailed inspection. Sec 10 Gas and heating service. Sec 14	Lift testing and LOLER examination (if fitted). Sec 9 Kitchen extraction cleaning. Sec 18 EV charge points and forklift charging equipment. Sec 19, Sec 20 EICR: at least every 5 years. Sec 15 PAT testing: set by risk assessment, often yearly. Sec 16

Not sure which guidance applies to your type of workplace? The HM Government fire risk assessment guides cover offices and shops, factories and warehouses, sleeping accommodation, places of assembly, educational and healthcare premises, and more: gov.uk/workplace-fire-safety-your-responsibilities/fire-risk-assessments

Section A — Fire Risk Assessment Record

Check frequency: **REGULAR REVIEW**

Record each fire risk assessment and each review. The assessment should be kept under review and updated regularly (usually every 12 months), and after any significant change such as building works, a change of use or a change of management. Keep the full report with this log book.

Date of Assessment / Review	Assessor / Company	Overall Risk Rating	Next Review Due	Where the Report Is Kept	Name / Signature

Section B — Remedial Actions Record

Check frequency: **AS NEEDED**

Copy each action from the Fire Risk Assessment, and any fault found during your checks, onto this page. Record when it is completed and keep the evidence (invoices, certificates) with this log book.

Ref	Action Required	Source (FRA / Check / Visit)	Priority	Target Date	Person Responsible	Date Completed	Signed Off By

Section 1 — Daily Checks

Check frequency: **DAILY**

Daily checks are part of the normal working day and don't need to be recorded when everything is in order. Use this page only to log any faults found.

Daily checks should confirm: fire exits open immediately and easily; fire doors are clear of obstruction and not wedged open; escape routes are clear; the fire alarm panel shows 'normal'; emergency lighting and exit signs are undamaged; extinguishers are in place, visible and unobstructed; and, where applicable, fire service access routes and hydrants are not blocked by vehicles.

Date	Area Checked	Fault Found (if any)	Action Taken	Name / Signature



Section 2 — Fire Detection and Warning System Test Record

Check frequency: **WEEKLY**

Test a different manual call point each week. Record automatic door releases and any detector faults found.

Date	Call Point Location / Number Tested	Result (Y/N)	Automatic Door Releases OK (Y/N)	Remedial Action Taken	Name / Signature

Section 3 — Record of False Fire Alarms

Check frequency: **AS NEEDED**

Record every false alarm when it happens. Categorise each as: Equipment Fault / Malicious Activation / Good Intent.

Date	Time	Call Point / Detector Location	Category	Action Taken	Name / Signature

Section 4 — Fire Extinguisher Test Record

Check frequency: **MONTHLY** **ANNUAL**

Monthly visual inspection by a nominated person; annual service by a competent engineer. Record both on this sheet.

Date	Location / Number	Inspected or Serviced (Monthly / Annual)	Result (Satisfactory Y/N)	Fault / Action Taken	Name / Signature

Section 5 — Emergency Escape Lighting Test Record

Check frequency: **MONTHLY** **ANNUAL**

Monthly: simulate a supply failure to check all luminaires operate. Annual: full-duration discharge test and check of charging arrangements.

Date	Test Type (Monthly / Annual)	All Luminaires Operating Correctly (Y/N)	Fault / Action Taken	Name / Signature

Section 6 — Sprinkler / Suppression System Test Record

Check frequency: **WEEKLY** **QUARTERLY** **ANNUAL** **IF FITTED**

Only applicable where a sprinkler, mist or other automatic suppression system is installed. Weekly: pressure gauges, water levels, pump start test. Quarterly / annual / three-yearly: competent person inspection and certification.

Date	Test Type (Weekly / Quarterly / Annual)	Pressure / Water Levels OK (Y/N)	Pump / Alarm Test OK (Y/N)	Fault / Action Taken	Name / Signature

Section 7 — Dry / Wet Riser Inspection Record

Check frequency: **SIX-MONTHLY** **ANNUAL** **IF FITTED**

Only applicable where a dry or wet riser is installed. Six-monthly visual inspection; annual pressure test by a competent person.

Date	Riser Location / Number	Inspection Type (6-Monthly / Annual)	Result (Satisfactory Y/N)	Fault / Action Taken	Name / Signature

Section 8 — Smoke Control / AOV Test Record

Check frequency: **WEEKLY** **MONTHLY** **ANNUAL** **IF FITTED**

Only applicable where automatic opening vents or a mechanical smoke control / extraction system is installed. Test in line with the manufacturer's instructions and the current British Standard.

Date	System / Vent Location	Test Type (Weekly / Monthly / Annual)	Result (Satisfactory Y/N)	Fault / Action Taken	Name / Signature

Section 9 — Fire-Fighting / Evacuation Lift Test Record

Check frequency: **IF FITTED**

Only applicable where a fire-fighting lift, evacuation lift or lift with a fire / emergency recall function is installed. Record periodic functional testing and note LOLER thorough examination dates separately.

Date	Lift Location / ID	Function Tested (e.g. Fire Recall, Shutdown Switch)	Result (Satisfactory Y/N)	Fault / Action Taken	Name / Signature

Section 10 — Fire Door Check Record

Check frequency: **DAILY** **MONTHLY** **ANNUAL**

Recommended: daily visual check that doors close fully and are not wedged open; monthly check of self-closers, seals and hinges; annual detailed inspection.

Date	Door Location	Self-Closer OK (Y/N)	Seals / Intumescent Strips OK (Y/N)	Hinges OK (Y/N)	Frame / Leaf Damage (Y/N)	Action Taken	Name / Signature

Section 11 — Signs and Notices Check Record

Check frequency: **AS NEEDED**

Confirm fire action notices, exit signs and fire door signage remain visible, legible and unobstructed. Check at least as often as your fire risk assessment recommends.

Date	Sign / Notice Location	Visible and Legible (Y/N)	Fault / Action Taken	Name / Signature

Section 12 — Fire Instruction / Training Record

Check frequency: **AS NEEDED**

Record induction training, refresher training and role-specific training (e.g. Fire Marshals / Wardens).

Date	Person Receiving Instruction	Nature of Instruction	Duration	Name of Instructor	Signature

Section 13 — Fire Drill Record

Check frequency: **AS NEEDED**

Record each drill, the time taken to evacuate, and any problems found.

Date	Nature of Drill	Persons / Section Taking Part	Evacuation Time	Deficiencies Found and Action Taken	Name / Signature

Section 14 — Gas and Heating Servicing Record

Check frequency: **ANNUAL**

Record gas safety checks and servicing of heating appliances, and the date the next service is due.

Date	Appliance / Location	Type of Service (Gas Safety / General PPM)	Engineer / Company	Result	Next Due Date

Section 15 — Electrical Installation (EICR) Record

Check frequency: **FIVE-YEARLY**

The fixed electrical installation should be inspected and tested (EICR) by a competent electrician at least every five years, or sooner if the last report says so. Keep each certificate with this log book.

Date of Inspection	Scope (Whole Building / Part)	Engineer / Company	Result (Satisfactory / Unsatisfactory)	Certificate Reference	Next Due Date (Within 5 Years)

Section 16 — Portable Appliance Testing (PAT) Record

Check frequency: **RISK-BASED**

Portable appliances should be checked and tested regularly. There is no fixed interval: it depends on the type of equipment and where it is used, and many premises test annually. Set the frequency by risk assessment, and record user checks, visual inspections and formal tests here.

Date	Area / Equipment Tested	Type (User Check / Visual / Formal Test)	Items Tested	Items Failed	Engineer / Company	Next Due Date

Section 17 — Contractors and Hot Works Record

Check frequency: **AS NEEDED**

Record all contractor attendance. Where hot works are carried out, a written permit to work should be completed and the area monitored for at least one hour after completion of the work (longer if your insurer requires it).

Date	Contractor / Company	Nature of Work	Hot Works Permit Issued (Y/N)	Area Monitored 1 hr After (Y/N)	Name / Signature

Section 18 — Commercial Kitchen Extraction / Ductwork Record

Check frequency: **AS NEEDED** **IF FITTED**

Only applicable where commercial catering / cooking facilities are present. Deep clean and inspection of extraction ductwork and canopy filters should follow current TR19 Grease guidance, with frequency based on cooking type and usage hours.

Date	Area Cleaned / Inspected (Canopy, Ductwork, Filters, Fan)	Cleaned by (Company)	Result (Satisfactory Y/N)	Next Due Date	Certificate Reference

Section 19 — EV Charging Point Inspection Record

Check frequency: **AS NEEDED**

Record visual and functional inspections of EV charging points, including RCD / overload protection checks, at the intervals set by the manufacturer or installer.

Date	Charger Location / ID	Visual Inspection OK (Y/N)	Functional Test OK (Y/N)	Fault / Action Taken	Name / Signature

Section 20 — Forklift / Battery Charging Equipment Maintenance Record

Check frequency: **AS NEEDED**

Record inspections and servicing of forklift trucks and battery charging equipment, at the intervals set by the manufacturer.

Date	Equipment / Unit ID	Inspected or Serviced	Result (Satisfactory Y/N)	Fault / Action Taken	Name / Signature

Section 21 — Fire Safety Inspector / Fire and Rescue Service Visits

Check frequency: **AS NEEDED**

Ask the visiting officer to complete this page.

Date	Inspecting Officer (Block Capitals)	Officer's Signature	Comments