PUBLIC HEALTH ENGINEERING DEPARTMENT

Water Quality Test Report

Division Name :- P. H. Division, Sitamarhi

14.10.2026

District Name : Sitamarhi

NAME OF SCHOOL- Front-Age Studies Punaura dham

Sl No.	Testing Date	Block	Panchayat	Location	Source	pH	Turb.	Cond.	TDS	TH	Ca	Mg	Cl	Alk	Nitrate	Fe	Bact	Remarks
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	17	18
1	14.10.2026	Dumra	Nagar nigam	Punaura Dham	Submersible	7.20	1.6	265	172	160	42	24	35	185	0	0.3	(-ve)	Safe For Drinking Water
Desirable Limit *						6.5-8.5	1.0	-	500	200	75	30	250	200	45	0.3	-	
Pesrmissible Limit* in absence source (IS 10500-2012 - 2nd Revision						NR	5.0	-	2000	600	200	100	1000	600	NR	1	-	

Note: (1) Drinking Water Specification First Revision -IS:10500:2012,Edition 2.2(2003-09,12,20)(Reaffirmed1993), (2) BDL = Below Detection Limit, (3)NR = No Relaxation, (4) ND = Not Done.

(a) Throughout any year, 95% of the samples should not contain coliform organisms in 100ml, (b) No sample should contain more than 10 coliform organisms per 100ml,

(b) Coliform organisms should not be detected in 100ml of any two consecutive samples.

Copy forwarded for information to: (i) Consultant Water Quality Cell, PHED, Govt.of Bihar, (ii) Director,Water Quality Cell,PHED,Govt.of Bihar, (iii) SLWTL,PHED,Govt.of Bihar.

16/10/2026

Chemist

Public health Division Sitamarhi

CHEMIST
DIVISION SITAMARHI

16/10/26

Executive Engineer

Public health division, Sitamarhi

EXECUTIVE ENGINEER
P.H. ENGINEERING DIVISION SITAMARHI