

Connection	Register	FunctionCodes1	FunctionCodes2	FunctionCodes3			
	40093	ScFa	INVERTER_POWER_FACTOR_SCALE_FACTOR	read	▼	✓	0
	40094	ul32	INVERTER_WATT_HOURS	read	▼	✓	0
	40096	ScFa	INVERTER_WATT_HOURS_SCALE_FACTOR	read	▼	✓	0
	40099	ul16	INVERTER_DC_VOLTAGE	read	▼	✓	0
	40100	ScFa	INVERTER_DC_VOLTAGE_SCALE_FACTOR	read	▼	✓	0
	40103	sl16	INVERTER_TEMPERATURE	read	▼	✓	0
	40107	ScFa	INVERTER_TEMPERATURE_SCALE_FACTOR	read	▼	✓	0
	40108	ul16	INVERTER_OPERATING_STATE	read	▼	✓	0
	40109	ul16	INVERTER_VENDOR_OPERATING_STATE	read	▼	✓	0
	40114	ul32	INVERTER_VENDOR_EVENT_BITFIELD	read	▼	✓	0
	40124	ul16	NAMEPLATE_DER_TYPE	read	▼	✓	0
	write	40152	ul16	BASIC_SETTINGS_W_MAX	read	▼	0
	write	40155	ul16	BASIC_SETTINGS_V_MAX	read	▼	0
	write	40156	ul16	BASIC_SETTINGS_V_MIN	read	▼	0
	write	40170	ul16	BASIC_SETTINGS_ECP_NOM_HZ	read	▼	0
	write	40171	CoPh	BASIC_SETTINGS_CONN_PHASE	read	▼	PHASE A
		40172	ScFa	BASIC_SETTINGS_W_MAX_SCALE_FACTOR	read	▼	0
		40175	ScFa	BASIC_SETTINGS_V_MIN_MAX	read	▼	0
		40176	ScFa	BASIC_SETTINGS_VA_MAX_SCALE_FACTOR	read	▼	0
		40177	ScFa	BASIC_SETTINGS_VAR_MAX_SCALE_FACTOR	read	▼	0
		40181	ScFa	BASIC_SETTINGS_ECP_NOM_HZ_SCALE_FACTOR	read	▼	0
		40187	ul32	EXTENDED_MESUREMENTS_AC_WATT_HOURS	read	▼	0
	write	40231	ul16	IMMEDIATE_CONNECTION_TIMEOUT	read	▼	0
	write	40232	ul16	IMMEDIATE_CONNECTION_CONTROL	read	▼	0
	write	40233	ul16	IMMEDIATE_POWER_LIMIT	read	▼	0

Info

Write Action

Read Action

Value