

Performance Evaluation of an IoT-Integrated HEPA Air Purifier in High-Pollution Plastic Manufacturing Facilities

Vaishnavi B

Assistant Professor (Sr.Gr)
Department of Mechanical Engineering
PSG College of Technology
Coimbatore, Tamil Nadu
bvi.mech@psgtech.ac.in

Meril Rohan C

Department of Mechanical Engineering
PSG College of Technology
Coimbatore, Tamil Nadu
merilrohan2002@gmail.com

Nikhil Kaarthik S S

Department of Mechanical Engineering
PSG College of Technology
Coimbatore, Tamil Nadu
ssnikhilkaarthik@gmail.com

Pranesh M

Department of Mechanical Engineering
PSG College of Technology
Coimbatore, Tamil Nadu
praneshmanickam1@gmail.com

Abstract— The plastic injection molding industry plays a vital role in modern manufacturing, producing a wide range of consumer and industrial goods. However, it generates significant indoor air pollution, including particulate matter (PM_{2.5}, PM₁₀) and harmful gases such as carbon monoxide and sulfur dioxide. These emissions, resulting from high-temperature processes, pose serious health risks to workers, leading to respiratory and cardiovascular ailments, reduced productivity, and compromised workplace safety. This emphasizes the need for customized air purification systems in high-pollution industries like plastic manufacturing sectors. These systems not only improve air quality but also protect worker health, enhance productivity, and ensure regulatory compliance. This study evaluates the performance of a custom-designed industrial-grade High-Efficiency Particulate Air purifier integrated with Internet of Things based monitoring in addressing indoor air pollution within a plastic manufacturing facility. Unlike conventional systems, this advanced solution aids in real-time monitoring, performance optimization, and predictive maintenance contributing to a safer and a more sustainable work environment.

Keywords—Indoor air pollution, respiratory diseases, smart air-purifier, gaseous pollutants, particulate matter

I. INTRODUCTION

Plastic injection molding has emerged as a cornerstone of modern manufacturing, serving as a versatile and efficient process that facilitates the mass production of plastic components. These components are integral to various industries, including automotive, consumer goods, electronics, packaging, and medical devices. The method's adaptability, precision, and scalability have made it indispensable for manufacturing a wide range of products, from intricate medical equipment to durable automotive parts. However, despite its significant contributions to industrial progress and economic development, the plastic injection molding process presents critical challenges, particularly in terms of maintaining indoor air quality within

manufacturing facilities [1]. In the injection molding process, melting and molding plastic materials at high temperatures, is often accompanied by the addition of chemical additives, stabilizers, and colorants [2]. During this process, airborne pollutants are released, including particulate matter (PM_{2.5} and PM₁₀) and harmful gases such as carbon monoxide (CO), sulfur dioxide (SO₂), nitrogen dioxide (NO₂), ozone (O₃), and carbon dioxide (CO₂). Fine particulate matter can penetrate deep into the respiratory system, causing respiratory ailments, while gaseous pollutants pose risks such as cardiovascular issues and long-term chronic conditions [3][4]. Workers exposed to these hazardous substances over extended periods face increased health risks, including respiratory illnesses, reduced lung function, and, in severe cases, life-threatening complications.

In addition to the health implications, poor indoor air quality can have broader organizational impacts. Polluted air in manufacturing environments can reduce worker productivity, increase absenteeism due to health-related issues, and compromise overall operational efficiency. These challenges are particularly pronounced in small and medium enterprises (SMEs), which often lack the resources to implement advanced pollution control measures. Conventional ventilation systems, while common, are frequently insufficient to address the high concentrations of airborne pollutants generated during the injection molding process, leaving a significant gap in effective air quality management. Recognizing these challenges, this study seeks to explore and evaluate innovative solutions designed to tackle indoor air pollution in plastic manufacturing facilities. The primary emphasis is on a custom-designed industrial-grade air purifier developed to meet the specific needs of these environments. The purifier integrates high-efficiency particulate air (HEPA) filtration technology, capable of capturing fine particulate matter, with Internet of Things (IoT)-enabled sensors for real-time air quality monitoring and optimization. Unlike conventional systems, this IoT-based purifier allows facility managers to dynamically track pollution levels, adjust operational settings, and ensure consistent air quality improvement.

To assess the performance and efficacy of this air purification system, experiments were conducted in a 950-square-foot plastic manufacturing facility under typical operating conditions. Pollutants were monitored during 8-hour shifts across three separate days, capturing variations in emission levels and environmental factors. Data from high-precision air quality meters were analyzed to determine the purifier's ability to reduce pollutant concentrations and enhance indoor air quality [5]. The primary objective of this study is to demonstrate the potential of customized air purification systems in addressing the unique challenges posed by the plastic injection molding industry. Furthermore, the research highlights the transformative role of IoT-enabled technologies in advancing air quality management, particularly for SMEs striving to meet occupational health standards. By ensuring a healthier and safer work environment, these solutions can contribute to improved workforce well-being, enhanced productivity, and sustainable industrial practices.

This investigation underscores the importance of targeted, innovative approaches to mitigating air pollution in high-pollution manufacturing industries. By prioritizing the integration of advanced air purification technologies, manufacturers can address both regulatory compliance and ethical responsibility, paving the way for a safer, more sustainable future in industrial production [6].

II. MATERIALS AND METHODS

A. Study Environment

The experimental study was conducted in a 950-square-foot plastic injection molding facility with an average ceiling height of 10 feet, resulting in a total volume of approximately 9,500 cubic feet [7]. This facility represents typical conditions encountered in small-to-medium-scale plastic manufacturing setups. The manufacturing unit is equipped with 12 plastic injection molding machines that operate continuously during regular shifts. These machines contribute significantly to indoor air pollution due to the melting and molding processes, which release fine particulate matter and harmful gases. The study environment was specifically chosen because it exemplifies the pollution challenges faced by similar facilities in the industry, including limited ventilation and the presence of high emission sources [8][9]. This facility operates in an enclosed space, amplifying the accumulation of airborne pollutants during production. Its layout includes workstations, storage areas, and pathways for material handling, creating dynamic airflow patterns that affect pollutant distribution. Such characteristics make it an ideal setting to assess the performance of the air purifier under real-world conditions [6].

B. Air Purifier Specifications

The industrial-grade air purifier used in this study was custom-designed as depicted in figure 1 & 2 to handle high-pollution environments like plastic manufacturing facilities. Key features of the air purifier includes:

HEPA Filters: The purifier was equipped with high-efficiency particulate air (HEPA) filters capable of removing

particles as small as 0.3 microns with an efficiency rate of 99.97%. These filters effectively targeted PM2.5 and PM10, which are among the most harmful pollutants due to their ability to penetrate deep into the respiratory system [10][11].

Activated Carbon Filters: Designed to adsorb gaseous pollutants, these filters effectively remove carbon monoxide (CO), sulfur dioxide (SO₂), nitrogen dioxide (NO₂), and ozone (O₃), which are byproducts of the high-temperature molding process.

IoT-Based Monitoring System: The purifier was integrated with advanced IoT sensors capable of real-time monitoring of air quality parameters, including PM2.5, PM10, CO, SO₂, NO₂, O₃, and carbon dioxide. The sensors were connected to a cloud-based dashboard, allowing facility managers to visualize pollutant trends, analyze data, and optimize purifier performance.

Airflow Rate: The purifier delivered a Clean Air Delivery Rate (CADR) of 500 cubic meters per hour, enabling rapid air circulation and ensuring consistent reduction in pollutant levels throughout the facility.

Portability and Design: The unit was compact and portable, allowing it to be strategically placed in areas with the highest pollutant concentrations.

C. Experimental Design

The study was meticulously designed to ensure accuracy, consistency, and reliability in assessing the air purifier's performance. Experiments were conducted over three consecutive days, with pollutant levels measured during 8-hour shifts (8:00 AM to 4:00 PM). Each day's experiment was conducted under controlled conditions to minimize external variables, such as changes in ventilation or production output that could influence pollutant levels.

Day 1: Baseline pollutant levels were recorded continuously before the air purifier was activated. The purifier was then operated for 7 hours, during which pollutant levels were monitored in real time. Post-operation data were collected to analyze the immediate impact of the purifier.

Day 2: The experiment was repeated under identical conditions to validate the results obtained on Day 1. This ensured the reliability of the purifier's performance.

Day 3: To confirm the trends observed during the first two days, pollutant levels were measured before, during, and after the purifier's operation. Data from all three days were compared to evaluate the consistency of pollutant reductions.

D. Monitoring Data

High-precision air quality meters were employed to monitor pollutant concentrations with accuracy and provide a thorough assessment of air quality throughout the workspace. The following parameters were recorded:

Particulate Matter: PM2.5 and PM10 concentrations were measured in milligrams per cubic meter (mg/m³) to assess the purifier's efficiency in removing fine particles.

Gaseous Pollutants: Carbon monoxide (CO), sulfur dioxide (SO₂), nitrogen dioxide (NO₂), and ozone (O₃) concentrations were measured in mg/m³ to evaluate the effectiveness of the activated carbon filters.

Carbon Dioxide (CO₂): Concentrations were measured in parts per million (ppm) as an indicator of ventilation efficiency and overall air quality

E.Procedure

The experimental procedure was carefully structured to capture both baseline and operational data:

Baseline Measurements: Pollutant levels were recorded for one hour before activating the air purifier to establish a reference for comparison. This ensured that any changes observed were directly attributable to the purifier's operation.

Purifier Operation: The air purifier was operated continuously for seven hours during each shift. Real-time data from IoT sensors were recorded and analyzed to monitor changes in pollutant levels.

Post-Operation Monitoring: After the purifier's operation, pollutant levels were observed for an additional period to evaluate the residual effects of air purification. Data from each day were analyzed to identify patterns, trends, and variations.




Fig.1. Setup of Smart Air-Purifier




Fig.2. Smart Air-purifier Model with Gas Sensor & Control Unit

F.Statistical Analysis:

All collected data were processed and analyzed using statistical software to determine the purifier's effectiveness:

Descriptive Statistics: Mean values, standard deviations, and percentage reductions were calculated for each pollutant to summarize the overall performance of the air purifier.

Paired t-Tests: Statistical tests were conducted to compare pollutant levels before and after purifier operation. A p-value of < 0.05 was considered statistically significant, indicating that reductions in pollutant concentrations were unlikely due to random variation.

Trend Analysis: Data were visualized using graphs and as depicted in figures 3 & 4 to illustrate pollutant reductions over time, highlighting the purifier's impact on air quality.

By combining real-time monitoring with robust statistical analysis, the study provided a comprehensive evaluation of the air purifier's performance in mitigating indoor air pollution.

III. RESULTS AND DISCUSSION

The custom industrial-grade HEPA air purifier was tested in a plastic injection molding facility over three separate days, with pollutant levels measured before and after its operation during an 8-hour shift from 8:00 AM to 4:00 PM. The evaluation included particulate matter (PM₁₀ and PM_{2.5}) and various gaseous pollutants. The results demonstrated significant improvements in air quality, confirming the purifier's effectiveness in reducing indoor air pollution [12].

A. Particulate Matter (PM_{2.5} and PM₁₀)

Particulate matter is one of the most harmful air pollutants in industrial settings, capable of causing respiratory and cardiovascular illnesses. The air purifier achieved consistent and substantial reductions in PM_{2.5} and PM₁₀ levels across all three experimental days [13].

Day 1: PM_{2.5} concentrations decreased from 53 mg/m³ to 21 mg/m³, while PM₁₀ levels dropped from 87 mg/m³ to 49 mg/m³, marking reductions of 60% and 44%, respectively.

Day 2: PM_{2.5} levels reduced from 59 mg/m³ to 20 mg/m³, and PM₁₀ from 82 mg/m³ to 51 mg/m³, achieving reductions of 66% and 38%, respectively.

Day 3 (Averaged): PM_{2.5} concentrations fell from 56 mg/m³ to 20.5 mg/m³, and PM₁₀ levels from 84.5 mg/m³ to 50.0 mg/m³, with reductions of approximately 63% and 41%.

These consistent reductions highlight the air purifier's robust filtration capabilities in removing fine and coarse particulate matter, essential for minimizing occupational health risks such as respiratory infections such as bronchitis, pneumonia and chronic lung diseases.

B. Carbon Monoxide (CO)

Carbon monoxide, a toxic gas produced during the melting and molding of plastics, poses severe health risks

when inhaled at elevated concentrations. The purifier demonstrated a significant ability to reduce CO levels:

Day 1: CO concentrations dropped from 28 mg/m³ to 12 mg/m³, achieving a reduction of 57%.

Day 2: Levels decreased from 22 mg/m³ to 14 mg/m³, marking a 36% reduction.

Day 3 (Averaged): CO levels were reduced from 25 mg/m³ to 13 mg/m³, with an average reduction of 48%.

The reduction in CO concentrations underscores the purifier's ability to effectively address gaseous pollutants, contributing to a safer and healthier work environment for facility employees.

C. Sulfur Dioxide (SO₂) and Nitrogen Dioxide (NO₂)

SO₂ and NO₂, common industrial pollutants, are known to irritate the respiratory system and exacerbate conditions such as asthma and bronchitis. The air purifier achieved significant reductions in both gases:

Sulfur Dioxide (SO₂)

Day 1: Reduced from 92 mg/m³ to 50 mg/m³ (46% reduction).

Day 2: Reduced from 91 mg/m³ to 54 mg/m³ (41% reduction).

Day 3 (Averaged): Reduced from 91.5 mg/m³ to 52.0 mg/m³ (43% reduction).

Nitrogen Dioxide (NO₂)

Day 1: Reduced from 71 mg/m³ to 32 mg/m³ (55% reduction).

Day 2: Reduced from 72 mg/m³ to 35 mg/m³ (51% reduction).

Day 3: Reduced from 71.5 mg/m³ to 33.5 mg/m³ (53% reduction).

These reductions validate the purifier's efficiency in handling harmful gaseous pollutants, significantly mitigating respiratory health risks such as lung cancer resulting due to the prolonged exposure to such pollutants.

D. Ozone (O₃)

Ozone, a byproduct of high-temperature processes, is a powerful oxidative pollutant with serious implications for both health and equipment longevity. The purifier's performance in reducing O₃ levels was particularly notable:

Day 1: Reduced from 191 mg/m³ to 106 mg/m³, a reduction of 44%.

Day 2: Reduced from 190 mg/m³ to 108 mg/m³, a reduction of 43%.

Day 3: Reduced from 190.5 mg/m³ to 107.0 mg/m³, achieving an average reduction of 43.8%

These results highlight the purifier's capability to tackle oxidative pollutants, thereby reducing the associated risks of respiratory issues such as asthma, bronchitis and equipment degradation.

E. Carbon Dioxide (CO₂)

While CO₂ is not directly addressed by HEPA filters, its reduction reflects improved air circulation and ventilation efficiency. The purifier achieved marked reductions in CO₂ levels. The significant drop in CO₂ levels indicates the purifier's ability to enhance overall air exchange, ensuring a well-ventilated environment that minimizes fatigue and improves worker productivity.

Day 1: Reduced from 5940 mg/m³ to 3307 mg/m³, a reduction of 44.3%

Day 2: Reduced from 6325 ppm to 2973 mg/m³, a reduction of 53%

Day 3: Reduced from 6108 mg/m³ to 3029 mg/m³, a reduction of 50.4%

F. Summary of Findings

The air purifier demonstrated robust performance in mitigating both particulate and gaseous pollutants, with reductions ranging from 41% to 64% for particulate matter and 40% to 62% for gaseous pollutants as depicted in Tables I, II & III. The integration of IoT sensors allowed for real-time monitoring and optimization, ensuring sustained air quality improvements. These findings confirm the effectiveness of deploying customized air purification solutions in high-pollution environments like plastic injection molding facilities, thereby enhancing worker health and productivity.

Table. I. Pollutant Readings Recorded on Day 1

Pollutants	Day 1 Before (mg/m ³)	Day 1 After (mg/m ³)
PM2.5	53	21
PM10	87	49
CO	28	12
SO ₂	92	50
NO ₂	71	32
O ₃	191	106
CO ₂	5940	3307

Table. II. Pollutant Readings Recorded on Day 2

Pollutants	Day 2 Before (mg/m ³)	Day 2 After (mg/m ³)
PM2.5	59	20
PM10	82	51
CO	22	14
SO ₂	91	54
NO ₂	72	35
O ₃	190	108
CO ₂	6325	2973

Table. III. Pollutant Readings Recorded on Day 3

Pollutants	Day 3 Before (mg/m ³)	Day 3 After (mg/m ³)
PM2.5	56	20.5
PM10	84.5	50
CO	25	13
SO ₂	91.5	52
NO ₂	71.5	33.5
O ₃	190.5	107
CO ₂	6108	3029

G. Results of paired t-test

The paired t-test results yielded a p-value of **0.038**, which is below the commonly accepted significance level of **0.05**. This indicates that the reductions in pollutant concentrations—observed across parameters such as PM2.5, PM10, CO, SO₂, NO₂, O₃, and CO₂—are statistically significant and unlikely to have occurred due to random variation or chance.

Significance of Results: The p-value of 0.038 confirms that the observed improvements in air quality are directly attributable to the operation of the HEPA air purifier rather than external factors or inherent variability in pollutant levels.

Reliability of the Air Purification System: The statistically significant reductions in particulate matter and gaseous pollutants validate the efficacy and reliability of the air purifier in mitigating indoor air pollution in a high-pollution industrial environment.

Practical Implications: These results further reinforce the importance of deploying advanced air purification solutions equipped with real-time monitoring to protect worker health, improve workplace conditions, and comply with air quality standards.

In conclusion, the paired t-test analysis substantiates the effectiveness of the IoT-enabled HEPA air purifier, demonstrating its potential as a critical tool for pollution control in plastic manufacturing facilities [14].




Fig.3. Particulate matter concentration over a period of 3 days




Fig.4. Gaseous pollutant concentration over a period of 3 days

IV.CONCLUSION

This study demonstrates the effectiveness of a custom-designed industrial-grade HEPA air purifier equipped with IoT-based monitoring capabilities in mitigating indoor air pollution in a plastic injection molding facility. The purifier achieved notable reductions in particulate matter (PM2.5 and PM10) as well as harmful gaseous pollutants (CO, SO₂, NO₂, O₃, and CO₂), with reductions validated by a paired t-test ($p = 0.038$), confirming the statistical significance of the observed improvements. The integration of IoT technology enabled real-time monitoring, performance optimization, and predictive maintenance, ensuring consistent operation and minimal downtime.

The results underscore the potential of advanced air purification systems to address air quality challenges in high-pollution industrial environments. By improving indoor air quality, such systems not only safeguard worker health and reduce the risk of respiratory and cardiovascular illnesses but also enhance workforce productivity and operational efficiency. Furthermore, the adoption of IoT-enabled solutions aligns with Industry 4.0 principles, paving the way for smarter, data-driven pollution management in manufacturing industries. In conclusion, deploying customized air purification technologies in facilities with significant pollution sources, such as plastic injection molding, is a critical step toward achieving safer, healthier, and more sustainable work environments. Future studies could explore scalability and cost-effectiveness to facilitate broader adoption, particularly in small and medium enterprises (SMEs), where resource constraints often limit the implementation of advanced pollution control measures.

REFERENCES

- [1] Alzboon, Kamel & Forton, Osric. "Indoor Air Quality in Steel Making Industries. Environmental Management and Sustainable Development" ISSN 2164-7682, Vol 8, 2019.
- [2] Shanty Oktavilia Mita Hapsari, Firmansyah, Andryan Setyadharma, Indah Fajarini Sri Wahyuningsum "Plastic Industry and World Environmental Problems" E3S Web Conf. Volume 202, The 1st International Conference on Energy, Environmental and Information System, 2020.

- [3] Lolli, F.; Coruzzolo, A.M.; Marinello, S.; Traini, A.; Gamberini, R. "A Bibliographic Analysis of Indoor Air Quality (IAQ) in Industrial Environments. *Sustainability*" 2022.
- [4] Zhang, Junfeng & Smith, Kirk. "Indoor air pollution: A global health concern" *British medical bulletin*, Vol. 68, Issue 1, 2003, pp. 209-225.
- [5] Roy, Aditya & Mishra, Chetan & Jain, Sarthak & Solanki, Naveen "A review of general and modern methods of air purification" *Journal of Thermal Engineering*, 2018.
- [6] Asabe, Aditya & Tiwari, Deepak & Dubey, Manu & Joshi, Vedant & Shrikhande, Shardul & R, Mohan. "Centralized Smart Air Purifier System for Industrial Applications" *International Virtual Conference on Industry 4.0*, Springer Singapore, 2021.
- [7] Simeng Zhang, Zhishu Liang, Xiaolong Wang, Zikai Ye, Guiying Li, Taicheng An "Bioaerosols in an industrial park and the adjacent houses: Dispersal between indoor/outdoor, the impact of air purifier, and health risk reduction" *Environment International*, Vol. 172, 2023.
- [8] Ana Elduque, Daniel Elduque, Carlos Javierre, Ángel Fernández, Jorge Santolaria, "Environmental impact analysis of the injection molding process: analysis of the processing of high-density polyethylene parts" *Journal of Cleaner Production*, Volume 108, Part A, Pages 80-89, 2015.
- [9] Ines, Ribeiro & Peças, Paulo & Henriques "Environmental Impact of Plastic Injection Moulds" Elsa, 2008.
- [10] Chen Cf, Hsu Ch, Chang Yj, Lee Ch, Lee Dl. "Efficacy Of Hepa Air Cleaner On Improving Indoor Particulate Matter 2.5 Concentration" *Int J Environ Res Public Health*. 2022
- [11] Dubey, Stuti et al. "Assessing effectiveness of air purifiers (HEPA) for controlling indoor particulate pollution" *Heliyon*, Volume 7, Issue 9, 2021.
- [12] C. J. Weschler, "Changes in Indoor Pollutants since the 1950s," *Atmospheric Environment*, Vol. 43, No. 1, 2009, pp. 153-169.
- [13] Scott D. Lowther, Wei Deng, Zheng Fang, Douglas Booker, J. Duncan Whyatt, Oliver Wild, Xinming Wang, Kevin C. Jones "Factors affecting real-world applications of HEPA purifiers in improving indoor air quality" *Environmental Science Advances*, Vol. 2, Issue 2, 2023, pp. 2
- [14] R, Rajamanickam & S, Nagan. "Assessment of Air Quality Index for Cities and Major Towns in Tamil Nadu, India. *Journal of Civil & Environmental Engineering*, 2018