TRANSFER TOWER - 01

15A CLOSE TYPE SPRINKLER HEAD

HBY-DN25

PI POSGA01CP503

TEST VALVE

EL.+38,500

EL.+35,000

EL.+30,500

EL.+27,000

EL.+21,500

EL.+15,500

EL.+8,200

HBY-DN80

HBY-DN100

GX804 GH804 W

GX803 GH803 W

GX802 GH802 W

GX805 GH805 W

GX806 GH806 W

GX807 GH807 W

GX808 GH808 W

GX801 GH801 W

JB

R

CV-01A/B

WATER SPRAY NOZZLE

CV-03A

CV-02A/B

CV-05A/B

COAL SHED "A"

T10206-XG02-P0SGA03-691001(F-8) TO GN904 IN TT-03

POWER SUPPLY AC220V/50HZ

LOCAL FIRE CONTROL PANEL GN902

P1SGA81 BR002 HBY-DN100

AA202 AA101 AA201 AT101

SUPPLIER

OTHERS

TO DRAIN

VH-01
N 2337678.750
E 455595.600
EL. + 8350
HBY-DN200
P=7Kg/cm²

P0SGA01 BR001 HBY-DN150

P0SGA02 BR001 HBY-DN150

P0SGA03 BR001 HBY-DN100

P0SGA04 BR001 HBY-DN150

P0SGA05 BR001 HBY-DN100

P0SGA06 BR001 HBY-DN100

P0SGA07 BR001 HBY-DN150

P0SGA08 BR001 HBY-DN150

FV P0SGA01CE701 PI P0SGA01CP501 PI P0SGA01CP502 PS P0SGA01CE251

FV P0SGA02CE701 PI P0SGA02CP501 PI P0SGA02CP502 PS P0SGA02CE251

FV P0SGA03CE701 PI P0SGA03CP501 PI P0SGA03CP502 PS P0SGA03CE251

PI P0SGA04CP501 PI P0SGA04CP502 PS P0SGA04CE251

FV P0SGA05CE701 PI P0SGA05CP501 PI P0SGA05CP502 PS P0SGA05CE251

FV P0SGA06CE701 PI P0SGA06CP501 PI P0SGA06CP502 PS P0SGA06CE251

FV P0SGA07CE701 PI P0SGA07CP501 PI P0SGA07CP502 PS P0SGA07CE251

FV P0SGA08CE701 PI P0SGA08CP501 PI P0SGA08CP502 PS P0SGA08CE251

AA101 AA102 AA103 AA104 AA105 AA106 AA107 AA108

HBY-DN50 HBY-DN150 HBY-DN100 HBY-DN40

AT101 AT102

YS

DRAIN

P1SGA81 BR001 HBY-DN200 HBY-DN50 BR003 P1SGA81

VALVE HEADER.1 (LOCATED IN TT-01)

FOR COMMENT

NOTES:-

1. THIS DRAWING SHOULD BE USED FOR THE PURPOSE OF FIRE PROTECTION SYSTEM ONLY.
2. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
3. EL+8000(=GL+0.0) BASED ON M.S.L.
 FINISHED FLOOR LEVEL = EL+8.000(GL+200)
4. ALL ELEVATIONS ARE IN mm UNLESS OTHERWISE STATED.
5. COIL VOLTAGE FOR SOLENOID VALVES SHALL BE 24 V. DC.
6. SYMBOL & LEGENDS TO SEE DWG NO.
 T10206-XG02-P0SGA00-691001
7. TRANSFER TOWER TERMINAL POINT TO SEE DWG NO.
 T10206-XG02-P0SGA00-691003
8. PIPE CLASS TO SEE PMS DOC NO.
 HBY : ABOVE GROUND ASTM A53 GR. B
 HXD : UNDER GROUND HDPE
9. EQUIPMENT NUMBERING PROCEDURE(KKS) TO SEE DOC NO.
 T10206-DA01-P0ZEN-02002
 DE DELUGE SYSTEM.
 AL WET TYPE SPRINKLER
 WS WATER SPRAY SYSTEM

THIS DRAWING IS THE PROPERTY OF DOOSAN HEAVY INDUSTRIES & CONSTRUCTION CO., LTD. IT IS NOT TO BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE COMPANY.

Rev.	Date	Prepared	Checked	Approved	Details of Revision
A	10.05.2012	GFENG	Y.I.MIN	J.S.PARK	FOR COMMENT

Owner: AES-VCM MONG DUONG POWER COMPANY LIMITED

Consultant: POWER ENGINEERING CONSULTING JOINT STOCK COMPANY 2

Contractor: Doosan Heavy Industries & Construction Co., Ltd.

Project: MONG DUONG II 2x560MW(NET) COAL FIRED POWER PROJECT

Orig-Pc T10206 PC XG02 Type SGA Contents Code P0

	Date	Name
Drawn	10.05.2012	GFENG
Checked	10.05.2012	Y.I.MIN
Approved	10.05.2012	J.S.PARK
Dept.		

Scale N/S

Title: COAL HANDLING SYSTEM FIRE PROTECTION SYSTEM TRANSFER TOWER NO.1 P & I DIAGRAM

Doosan Heavy Industries & Construction Co., Ltd. Dept. Unid

Reg. No 691001 Rev. A Version

Drawing No. T10206-XG02-P0SGA01-691001 Page-No. 1/1

A0 (841 x 1189mm)