












SYMBOL	DESCRIPTION
	MAIN PROCESS FLOW PIPING ABOVE GROUND : HBY UNDERGROUND : HXD
	CONCENTRIC REDUCER ABOVE GROUND : HBY UNDERGROUND : HXD
	ECCENTRIC REDUCER ABOVE GROUND : HBY UNDERGROUND : HXD
	WELD CAP ASTM A234 WPB ABOVE GROUND : HBY
	SCREWED CAP SCREW ASTM A53 B
	HOSE CONNECTION, BRASS
	QUICK DISCONNECT, BRASS
	BLIND FLANGE ASTM A182 RF
	BURIED PIPE UNDERGROUND : HXD
	PIPING BY OTHERS
	GATE VALVE NORMAL OPEN CAST STEEL ANSI 150LB RF
	GATE VALVE NORMAL OPEN CAST STEEL ANSI 150LB RF
	GLOBE VALVE NORMAL OPEN CAST STEEL ANSI 3000# SW
	BALL VALVE BRASS & CAST STEEL
	BUTTERFLY VALVE ANSI 150LB EPDM
	HIGH FLEXIBLE HOSE
	HORIZONTAL CENTRIFUGAL PUMP TOWER SPRAY PUMP 60M3/HR
	WATER HOSE REEL TRIPPER CAR SPRAY

SYMBOL	DESCRIPTION
 (AA201~)	CHECK VALVE SWING & WAFER TYPE ANSI 150LB
 (AT101~)	Y-TYPE STRAINER 40MESH ASTM A82 150LB (FOR TRANSFER POINT)
 (AA201~)	FLEXIBLE CONNECTION PUMP SUCTION ANSI 150LB
 (POGHD71AA081~)	PRESSURE REDUCING VALVE (FOR TRANSFER POINT)
 (POGHD71CE701~)	SOLENOID VALVE DC24V (NORMAL CLOSE)
 (AZ101~)	MONITOR GUN (FOR COAL PILE SPRAY)
 (BZ101~)	SPRAY NOZZLE (FOR TRANSFER POINT)
 (AT101~)	TEMPORARY STARTUP STRAINER(FOR SPRAY PUMP)
 (POGHD38P001~)	ORIFICE PLATE (FOR SPRAY PUMP)
 (AA101~)	DRAIN VALVE (BALL VALVE)
 (POGHD50CE251~)	PRESSURE SWITCH (FOR SPRAY PUMP)
 (POGHD68CP251~)	PRESSURE GAUGE
 (POGHD71AA081~)	PRESSURE REDUCING VALVE
 (POGHD71CE701~)	SOLENOID VALVE DC24

SYMBOL	DESCRIPTION
	PIPE CLASS CHANGE ABOVE GROUND : HBY UNDERGROUND : HXD
	BUILDING PENETRATION
	SUPPLIER INTERFACE
	PLC CONTROL FOR DUST SUPPRESSION SYSTEM
	PUMP CONTROL STATION (FOR SPRAY PUMP)
	FLOW CONTROL VALVE ENCLOSURE (FOR TRANSFER POINT)
	ELECTRIC SIGNAL
	COMMUNICATION CABLE
	ASCENDING WIRING
	DESCENDING WIRING
	THROUGH WIRING
	SYSTEM CODE
	EQUIPMENT UNIT CODE
	PIPE
	NOMINAL DIAMETER
	a : TYPE OF WIRE & CABLE b : SIZE OF WIRE & CABLE c : CORE OF WIRE & CABLE d : SIZE OF CONDUIT

FOR CONSTRUCTION

THIS DRAWING IS THE PROPERTY OF DOOSAN HEAVY INDUSTRIES & CONSTRUCTION CO., LTD.
IT IS NOT TO BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE COMPANY.

	26.07.2012	GFGF	Y.LAM	J.S.PARK	FOR CONSTRUCTION
	24.05.2012	GFGF	Y.LAM	J.S.PARK	FOR COMMENT
Rev.	Date	Prepared	Checked	Approved	Details of Revision

Owner AES-VCM MONG DUONG POWER COMPANY LIMITED

Consultant POWER ENGINEERING CONSULTING JOINT STOCK COMPANY 2

Contractor Doosan Heavy Industries & Construction Co., Ltd.

Project	MONG DUONG II 2x560MW(NET) COAL FIRED POWER PROJECT				Originals T10206
					PC XG02
	Date	Name	Scale	N/S	Type EAO
Drawn	25.04.2012	GFGF	Title		Contents Code P0
Checked	25.04.2012	Y.LIM			
Approved	25.04.2012	J.S.PARK			
COAL HANDLING SYSTEM DUST SUPPRESSION SYSTEM SYMBOL & LEGEND					
Dept.	Doosan Heavy Industries & Construction Etn. Ltd.			Dept.	No. 871001
	Unit			Rev.	0 Version
Drawing No.	T10206-XG02-P0RA000-871001				Page-No. 1 / 1