COAL SHED - A

COAL SHED - B

COAL PILE SPRAY SYSTEM P & ID NO. T10206-XG02-P0EA00-671003 (N-8)

COAL PILE SPRAY SYSTEM P & ID NO. T10206-XG02-P0EA00-671003 (N-12)

COAL PILE SPRAY SYSTEM P & ID NO. T10206-XG02-P0EA00-671003 (N-6)

COAL PILE SPRAY SYSTEM P & ID NO. T10206-XG02-P0EA00-671003 (N-3)

POGHD80 BR001 HBY-DN65

POGHD81 BR001 HBY-DN65

POGHD83 BR001 HBY-DN65

POGHD82 BR001 HBY-DN65

POGHD71 BR001 HBY-DN32

TT-01

FV POGHD72CE701

FV POGHD72CE702

12 LPM DIS. CV-01A DN20

12 LPM DIS. CV-01B DN20

AA103 AA104

PRV POGHD72AA081

YS AT101

POGHD51

BR005

HBY-DN20 AA102

DN25 AA101

DN25 AA105

FC-01

FV POGHD72CE705

FV POGHD72CE703

FV POGHD72CE704

12 LPM LOAD CV-03A DN20

12 LPM LOAD CV-02A DN20

12 LPM LOAD CV-02B DN20

AA109 AA110

PRV POGHD72AA082

YS AT101

AA107 HBY-DN20

AA108

DN25 AA106

DN25 AA111

FC-02

FV POGHD72CE706

FV POGHD72CE707

PRV POGHD72AA083

12 LPM LOAD CV-05A DN20

12 LPM LOAD CV-05B DN20

AA114 AA115

YS AT101

AA113 HBY-DN20

DN25 AA112

DN25 AA116

POGHD72 BR001 HBY-DN50

AA101

FC-03

TP-10

FV POGHD71CE701

FV POGHD71CE702

PRV POGHD71AA081

12 LPM LOAD CV-01A DN20

12 LPM LOAD CV-01B DN20

AA103

YS AT101

AA101 HBY-DN20

AA102

FC-07

TT-03

FV POGHD73CE703

FV POGHD73CE701

FV POGHD73CE702

12 LPM DIS. CV-04A DN20

12 LPM LOAD CV-05A DN20

12 LPM LOAD CV-05B DN20

AA103 AA104 AA105

PRV POGHD73AA081

YS AT101

HBY-DN20 AA102

DN25 AA101

DN25 AA106

POGHD73 BR001 HBY-DN65

FC-05

DN65

TT-04

FV POGHD74CE701

FV POGHD74CE703

FV POGHD74CE702

DN25 AA101

12 LPM DIS. CV-04B DN20

12 LPM LOAD CV-05A DN20

12 LPM LOAD CV-05B DN20

AA103 AA104 AA105

PRV POGHD74AA081

YS AT101

HBY-DN80 BR001 POGHD74

HBY-DN20 AA102

DN25 AA106

DN25 AA107

POGHD75 BR001 HBY-DN50

FC-06

DN100

HXD HBY U/G A/G

TT-02

DN25

DN25

FV POGHD75CE701

FV POGHD75CE703

FV POGHD75CE702

PRV POGHD75AA081

YS AT101

HBY-DN20 AA104

DN20 DIS. CV-02A 12 LPM

DN20 DIS. CV-02B 12 LPM

DN20 LOAD CV-03B 12 LPM

AA101 AA102 AA103

FC-04

DN25 AA105

DN25 AA106

DN25 AA107

POGHD70 BR001 HXD-DN150

U/G HXD

A/G HBY

POWER SUPPLY FROM CHP MAIN PANEL AC220V/50HZ (FOR UPS & GENERAL)

RIO PANEL FOR DUST SUPPRESSION (LOCATED IN CHB)

CHB

FE POGHD50CF251

PS POGHD50CE252

AA103 DN15

PI POGHD68CP252

AA104

F0 POGHD38BP002

AA204 AA105 HBY-DN32

POGHD69 BR001 HBY-DN100

AA104 AA203

M POGHD68 BR002 AT101 HBY-DN150 AA106

COALPILE SPRAY PUMP PUMP(AP102)

AA202

POGHD69 BR003 HBY-DN150

F0 POGHD38BP001

AA202 AA102 HBY-DN32

PI POGHD68CP251

AA101

POGHD69 BR002 HBY-DN100

AA101 AA201

M POGHD68 BR003 AT101 AA103 HBY-DN150

COALPILE SPRAY PUMP PUMP(AP101)

COAL PILE SPRAY PUMP (100% x 2SET) Q=60m³/hr x 100m

MOTOR CONTROL PANEL (LOCATED IN PUMP ROOM) POWER SUPPLY

FIRE WATERS, SERVICE WATER PUMP HOUSE

CHS SUPPLIER

POGHD68 BR001 HBY-DN32

POGHD10 BR004 HBY-DN200

SERVICE WATER DISTRIBUTION SYSTEM P&ID T-10206-XG02-P0GHD-110001 (J-11)

POGHD10 BR008 HBY-DN250

SERVICE WATER DISTRIBUTION SYSTEM P&ID T-10206-XG02-P0GHD-110001 (J-11)

HBY-DN200 BR001 POGHD68

DPSI

TERMINAL POINT FROM STORAGE TANK

APPLICATION POINTS DETAIL

LOCATION	FC NO.	APPLICATION POINT	Q'TY	FLOW RATE
TT-01	FC-01	DIS. CV-01A	4	12.0/5.0
		DIS. CV-01B	4	12.0/5.0
	FC-02	LOAD CV-03A	4	12.0/5.0
		LOAD CV-02A	4	12.0/5.0
		LOAD CV-02B	4	12.0/5.0
	FC-03	LOAD CV-05A	4	12.0/5.0
		LOAD CV-05B	4	12.0/5.0
TT-02	FC-04	DIS. CV-02A	4	12.0/5.0
		DIS. CV-02B	4	12.0/5.0
		LOAD CV-03B	4	12.0/5.0
TT-03	FC-05	DIS. CV-04A	4	12.0/5.0
		LOAD CV-05A	4	12.0/5.0
		LOAD CV-05B	4	12.0/5.0
TT-04	FC-06	DIS. CV-04B	4	12.0/5.0
		LOAD CV-05A	4	12.0/5.0
		LOAD CV-05B	4	12.0/5.0
TERMINAL POINT-10	FC-07	LOAD CV-01A	4	12.0/5.0
		LOAD CV-01B	4	12.0/5.0

TOTAL NO. OF NOZZLE : 72 EA
TOTAL FLOW RATE : 216LPM

NOTES:-

1. THIS DRAWING SHOULD BE USED FOR THE PURPOSE OF DUST SUPPRESSION SYSTEM ONLY.
2. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE STATED.
3. EL+8000(=GL+0.0) BASED ON M.S.L.
 FINISHED FLOOR LEVEL = EL+8.000(GL+200)
4. ALL ELEVATIONS ARE IN mm UNLESS OTHERWISE STATED.
5. COIL VOLTAGE FOR SOLENOID VALVES SHALL BE 24 V. DC.
6. SYMBOL & LEGENDS TO SEE DWG NO. T10206-XG02-P0EA000-671001
7. TERMINAL POINT TO SEE DWG NO. T10206-XH01-P0EA000-671001
8. PIPE CLASS TO SEE PMS DOC NO.
 HBY : ABOVE GROUND ASTM A53 GR. B
 HXD : UNDER GROUND HDPE
9. EQUIPMENT NUMBERING PROCEDURE(KKS) TO SEE DOC NO. T10206-DA01-P0ZEN-02002
 LOAD : LOAD POINT
 DIS. : DISCHARG POINT

FOR CONSTRUCTION

THIS DRAWING IS THE PROPERTY OF DOOSAN HEAVY INDUSTRIES & CONSTRUCTION CO., LTD. IT IS NOT TO BE COPIED OR USED IN ANY WAY DETRIMENTAL TO THE COMPANY.

Rev.	Date	Prepared	Checked	Approved	Details of Revision
3	04.10.2013	GFENG	Y.I.MIN	J.S.PARK	FOR CONSTRUCTION
2	13.05.2013	GFENG	Y.I.MIN	J.S.PARK	FOR CONSTRUCTION
1	20.12.2012	GFENG	Y.I.MIN	J.S.PARK	FOR CONSTRUCTION
A	26.07.2012	GFENG	Y.I.MIN	J.S.PARK	FOR CONSTRUCTION
0	24.05.2012	GFENG	Y.I.MIN	J.S.PARK	FOR COMMENT

Owner: AES-VCM MONG DUONG POWER COMPANY LIMITED

Consultant: POWER ENGINEERING CONSULTING JOINT STOCK COMPANY 2

Contractor: Doosan Heavy Industries & Construction Co., Ltd.

Project: MONG DUONG II 2x560MW(NET) COAL FIRED POWER PROJECT

Orig-Prj: T10206
PC: XG02
Type: EAO
Contents Code: P0
Reg. No: 671002

	Date	Name	Scale	N/S
Drawn	25.04.2012	GFENG		
Checked	25.04.2012	Y.I.MIN		
Approved	25.04.2012	J.S.PARK		
Dept.				

Title: COAL HANDLING SYSTEM DUST SUPPRESSION SYSTEM TOWER SPRAY P&ID INCL. SERVICE WATER FOR WASH DOWN SYSTEM

Doosan Heavy Industries & Construction Co., Ltd. — Dept. — Unid — Rev. 3 — Version

Drawing No. T10206-XG02-P0EA000-671002 — Page-No. 1/1

A0 (841 x 1189mm)