

SHIFT HANDOVER LOG

Log Reference : SHL-2026-0121
Date : 21?22 January 2026
Shift : Night Shift (22:00 ? 06:00)
Outgoing Shift : C Shift ? Suresh Kumar (Operator-III, Senior)
Incoming Shift : A Shift ? Ravi Deshmukh (Operator-II)
Shift Supervisor: Rajiv Sharma

EQUIPMENT STATUS SUMMARY

Equipment Tag	Status	Notes
GB-14	? CRITICAL	22% LEL at 23:15 IST. RISING. Was 7% at 22:00.
		HOT WORK SUSPENDED 23:15. Rajiv Sharma paged.
		Portable detector deployed by Anil Mehta 02:30.
		HX-11 flange #7 seepage confirmed source.
		Area ventilated. Reading now 2% LEL (05:30).
		WO-4892 raised (CRITICAL priority).
PM-07	RUNNING	Normal. Bearing temp 71°C.
HX-11	? ISOLATED	Flange #7 gasket failure. Emergency isolation 05:00.
		Production impact: Feed pump bypass activated.
		WO-4892 covers HX-11 flange #7 repair.
PV-08	HOT WORK	Plasma cutting (HWP-2026-018). SUSPENDED 23:15.
		Do NOT resume until WO-4892 cleared and GB-14 recalibrated.
CV-22	RUNNING	Normal.
CR-03	PARKED	Not used this shift.

INCIDENT SUMMARY

THIS IS THE THIRD TIME THIS HAS HAPPENED IN BAY 4 ? GB-14 high reading with hot work active.

Previous events (per Rajiv Sharma):

- March 2019: 27% LEL, near-miss, NMR-2019-047
- August 2024: 18% LEL, WO-4471

Rajiv Sharma has escalated to Mohan Rao (Plant Manager) and Kavita Desai (HSE Manager) at 23:45. Formal incident investigation (RCA-2026-007) opened.

Suresh Kumar's observation: "I recognised the reading pattern ? it was the same as 2024. I suspended hot work immediately and called Rajiv without waiting for 25% threshold. Previous training said 25% but I acted at 15% because of the prior incidents."
[Note: Suresh Kumar's early action likely prevented a repeat of the 2019 near-miss.]

OPEN ACTIONS FOR INCOMING SHIFT

- CRITICAL: Do not resume any hot work in Bay 4 until written clearance from Kavita Desai.
- HX-11 bypass: Monitor bypass valve CV-11B closely. Flow target 180 m³/hr (vs. normal 240).
- WO-4892 active ? Anil Mehta will be on-site from 07:00 for repairs.
- RCA-2026-007 kick-off meeting: 09:00, Conference Room B. All supervisors to attend.

SIGNATURES

Outgoing Operator : Suresh Kumar	Signature: ____	Time: 06:10
Incoming Operator : Ravi Deshmukh	Signature: ____	Time: 06:10
Shift Supervisor : Rajiv Sharma	Signature: ____	Time: 06:15

CROSS-REFERENCE: WO-4892, HWP-2026-018, NMR-2019-047, WO-4471, RCA-2026-007