

SHIFT HANDOVER LOG

Log Reference : SHL-2024-0819
Date : 19 August 2024
Shift : Night Shift (22:00 ? 06:00)
Outgoing Shift : A Shift ? Suresh Kumar (Operator-II), Lead
Incoming Shift : B Shift ? Vijay Patil (Operator-II), Lead
Shift Supervisor: Rajiv Sharma

EQUIPMENT STATUS SUMMARY

Equipment Tag	Status	Notes
GB-14	? ALERT	Reading 18% LEL at 05:55 IST. Was 6% LEL at 22:00.
		Rising trend over 8 hours. Hot work suspended.
		Rajiv Sharma notified at 06:15. WO raised (pending no.)
PM-07	RUNNING	Vibration within limits. Bearing temp: 68°C (limit 85°C)
HX-11	RUNNING	Outlet temp: 142°C. Note: slight odour near south flange.
		Not confirmed as leak. Monitor closely next shift.
PV-08	SHUTDOWN	Planned maintenance. Hot work permit HWP-2024-339 active.
		HOT WORK SUSPENDED due to GB-14 alarm at 06:15.
CV-22	RUNNING	No issues.
CR-03	AVAILABLE	Last used 14:00. No issues.

HOT WORK STATUS

Permit No. : HWP-2024-339
Work Type : Pipe welding ? PV-08 support bracket (Bay 4)
Issued By : Rajiv Sharma at 21:45 on 18 August 2024
Status : SUSPENDED at 06:15, 19 August 2024
Reason : GB-14 reading exceeded 15% LEL notification threshold.
Gas reading at permit issuance (21:45): 4% LEL.
Gas reading at suspension (06:15): 18% LEL.
Action : Work order being raised for GB-14 investigation. Bay 4 hot work not to resume until GB-14 is investigated and cleared by HSE.
Incoming shift supervisor to liaise with Anil Mehta (I&E).

PRODUCTION NOTES

- Furnace #2 running at 87% capacity. No issues.
- Cooling water system: normal. Flow 240 m³/hr.
- Raw material: Iron ore batch from Raipur delivered 02:00. Stockpile updated.
- Quality: Heat No. VS-2024-1621 dispatched 04:30. Certificate attached.

OPEN ACTIONS FOR INCOMING SHIFT

1. PRIORITY: Coordinate with Anil Mehta re: GB-14 investigation (WO pending). Do NOT resume hot work in Bay 4 until written clearance from HSE officer.
2. Monitor HX-11 south flange for odour / seepage. Inform Rajiv Sharma if worsens.
3. PM-07 bearing temperature trending up from 62°C (07:00 yesterday) to 68°C. Log hourly readings. Escalate if >75°C.

SIGNATURES

Outgoing Operator : Suresh Kumar Signature: _____ Time: 06:25
Incoming Operator : Vijay Patil Signature: _____ Time: 06:25
Shift Supervisor : Rajiv Sharma Signature: _____ Time: 06:30

CROSS-REFERENCE: HWP-2024-339, WO-4471 (raised after this log), NMR-2019-047