

From,

Fire Station officer,  
Sirsa,

To,

Deputy Commissioner,  
Sirsa.

Subject:- Memo No. FS/2020/3/0 Dated 19.10.2020  
Renewal of Fire NOC from the fire safety point of view for Group- B Educational Building M/s Shah Satnam Ji Girls School at Near Shah Satnam Ji Dera Sacha Sauda Village Shahpur Begu, Distt. Sirsa (Hry.)

With reference to transaction ID 171022023000108 Dated 28-09-2020 on the subject cited above.

School Principal has submitted through transaction ID 171022023000108 dated 28-09-2020 the subject cited above the case for Renewal of Fire NOC from the fire safety point of view of M/s Shah Satnam Ji Girls School at Near Shah Satnam Ji Dera Sacha Sauda Village Shahpur Begu, Distt. Sirsa (Hry.) In this regard physically inspection on dated 15-10-2020 has been carried out by Fire Station Officer Sirsa. Inspection photographs taken on spot enclosed. Fire safety arrangements have been made as per the provision of N.B.C. of India 2005 & Revised 2016 part- iv Fire & Life Safety. Approval of fire fighting scheme has already being sanctioned by DULB Haryana Panchkula vide memo no. DFS/FA./2017/650/46780 Dated 16-05-2017 and Last Renewal Fire NOC issued by Your Good office vide memo no. 4300/PLA Dated 20-08-2019 and online vide memo no. FS/2019/27 Dated 27-09-2019. You are competent authority to deal with such cases as per Director General, Fire Service, Haryana, Panchkula vide Endst. No. DFS/FA/2020/11478-578 Dated 19-02-2020 to Renewal of Fire NOC as per N.B.C. of India 2005 & Revised 2016 part- iv Fire & Life Safety. Fire safety arrangements as per N.B.C. are given as under:-

Total Area :- 5 Acre or (20240.00 SQM)

Basement Detail :- NIL.

Tower No/Name	Floor Detail	Ground Coverage Area (Existing + Proposed)	Over all Height	Stair Case	
				As per NBC Required	Provided
Block-A	Ground +2 <sup>nd</sup> Floor	4330.81 Sq.mtr	1135 Meter	04 No Exit	04 No. Stair 01 no. Ramp

Sr. No.	Norms As Per NBC, 2016	Required as per NBC	Provided	Remarks
1.	Fire Extinguishers	Required	Provided	OK
2.	Hose Reel	Required	Provided	OK
3.	Wet Riser	No	No	--
4.	Down Corner	Required	Provided	OK
5.	Internal Hydrant	Required	Provided	OK
6.	Automatic Sprinkler System	No	No	--
7.	MCP (Manual Call Point)	No	No	--
8.	Automatic Detection & Alarm System	No	No	--
9.	Terrance Tank	Required	10,000 X 2	OK
10.	Terrance Pump	Required	450 LPM + 450 LPM	OK
11.	UG Water Tank	No	No	--
12.	UG Fire Pump	No	No	--
13.	Means of Escape	Required	Provided	OK
14.	Sinage	Required	Provided	OK

The case forwarding for necessary permission may kindly be granted for the "Renewal of Fire NOC" of M/s Shah Satnam Ji Girls School at Near Shah Satnam Ji Dera Sacha Sauda Village Shahpur Begu, Distt. Sirsa (Hry.)

*Delhi Singh*  
Dalbir Singh,  
FSO, Sirsa.