

Inspection Report: INS-007

Machine: Pump P102

Inspection Date: 2026-06-24

Inspector: Arun Prakash

Readings:

Temperature: 47 C

Pressure: 13 PSI

Vibration: Within normal limits

Lubrication: Adequate

Alignment: Verified

Overall Condition: Satisfactory

Recommendations: Continue standard monitoring schedule.