

RFP - Fire Resistant Cable 35sqmm - Tunnel Project

Due Date: 06-Feb-2026

Scope of Supply:

- Quantity: 50000 meters

Technical Specifications:

- Conductor Size: 35sqmm
- Voltage Grade: 0.6kV
- Fire Resistant: Yes (as required)
- Standard: IS 7098 or equivalent

Tests Required: Type Test, Routine Test, Site Acceptance Test