

ROOM / CAPACITY SCHEDULE

Northern Nevada proposed data center / Northern Nevada data center / proposed level 01

CONCEPT REVIEW / SP01

ROOM / FUNCTION	m²	ACCESS	DESKS A/S/T	LEARN	MEET	DINE	BEDS	USE
R01 / Conventional hall	223.0	UNESTABLISHED	?/?/?	?	?	?	?	?
R02 / Electrical / UPS	157.9	UNESTABLISHED	?/?/?	?	?	?	?	?
R03 / Network A	27.9	UNESTABLISHED	?/?/?	?	?	?	?	?
R04 / Receiving / quarantine	74.3	UNESTABLISHED	?/?/?	?	?	?	?	?
R05 / AI hall	167.2	UNESTABLISHED	?/?/?	?	?	?	?	?
R06 / Mechanical / CDU	111.5	UNESTABLISHED	?/?/?	?	?	?	?	?
R07 / NOC / incident	65.0	UNESTABLISHED	?/?/?	?	?	?	?	?
R08 / Spares / media	51.1	UNESTABLISHED	?/?/?	?	?	?	?	?
R09 / Lobby / mantrap	32.5	UNESTABLISHED	?/?/?	?	?	?	?	?
R10 / Key room	23.2	UNESTABLISHED	?/?/?	?	?	?	?	?
R11 / Network B	27.9	UNESTABLISHED	?/?/?	?	?	?	?	?

SOURCE STATUS
PROPOSED DESIGN NOT CONSTRUCTED

GEOMETRY
program envelope

HEIGHT BASIS
SP-HEIGHT-RUN-001: six-metre visual study only; accepted runtime source does not establish building height.

DESIGN BOUNDARY
Modelled study. Not surveyed, as-built, engineered or code-certified.

DIMENSIONS / METRES
36.58 × 30.48 m
Height 6.00 m + parapet 0.80 m

Gross 1114.8 m² • room/program area 961.5 m² • planned peak unknown
A/S/T = assigned/shared/touchdown desks; USE = special-use capacity. ? = not supplied; 0 = explicit zero. Capacity categories are not employee headcount.