

Runtime Control and Evidence Matrix — Reno / Boise / Northern Nevada

Document ID: SH-RT-CONTROL-001

Version: 1.0.0

Prepared: 2026-09-11

Owner: Enterprise Technology Services with Legal, Finance, Procurement and Facilities

Authority: Owner-authorized PR119 runtime mandate, pending repository acceptance

Structured companion: enterprise/services/source/runtime_sites_2026-09-11.json;
runtime_capital_plan_2026-09-11.json

Purpose: implementation specification for the Common Controls Framework. This file defines design/evidence requirements; it does not assert operating effectiveness.

Domain	Reno primary	Boise recovery	Owned Northern Nevada	Evidence / test
Asset ownership	Sable-owned equipment	Sable-owned equipment	Sable-owned facility + equipment	asset register, serials, custody, finance reconciliation
Physical perimeter	provider building + Sable cage	provider building + Sable cage	Sable-operated perimeter	access design, CCTV, visitor logs, alarm tests
Cage/data-hall access	named least privilege	separate named least privilege	named least privilege	quarterly access review; terminated-user population reconciliation
Provider master access	restricted/logged	restricted/logged	N/A except contractors	provider-access log review
Power	dual A/B, UPS/generator	dual A/B, UPS/generator	engineered redundant paths	SLA reports; load/maintenance tests; excursion population
Cooling	high-density/liquid-ready	recovery-density capable	mixed air + liquid-first AI zone	environmental trends, alarms, maintenance
Carrier diversity	two physical routes	independent Boise routes	dual property entrances	route diagrams, LOAs, failure tests
Network boundary	Sable-controlled edge	independent recovery edge	Sable-controlled edge	config baselines, change logs, scans
Identity/PAM	Sable controlled	independent break-glass	Sable controlled	JML population, PAM logs, quarterly certification
Keys/HSM	Sable controlled	independent recoverable copy	dedicated key boundary	key inventory, ceremonies, recovery test
Data classification	resource-level	same classification	same	entitlement decision logs

Domain	Reno primary	Boise recovery	Owned Northern Nevada	Evidence / test
Backup	immutable protected copies	recovery copy	primary + immutable	backup jobs, restore tests, completeness reconciliation
Recovery	fail to Boise	operate/failback	eventually primary; Boise remains independent	timed RTO/RPO exercise
Logging	security/admin/application	independent availability	full owned-site telemetry	log source inventory, gap detection, retention tests
Vulnerability/configuration	Sable systems	Sable systems	systems + facility controllers	scan/config evidence; remediation
Incident response	provider + Sable coordination	provider + Sable coordination	Sable site + vendors	exercises, tickets, notification timestamps
Change management	facility changes notified; Sable changes approved	same	Sable facility/IT change control	sampled changes and emergency changes
Supplier assurance	annual provider review	independent provider review	critical maintenance/carrier/vendor review	SOC reports, contracts, CUECs, vendor risk review
Environmental/fire	provider evidence	provider evidence	Sable inspection/testing	inspection certificates, alarms, maintenance
Media handling	Sable custody	Sable custody	Sable custody	chain of custody, destruction certificates
Capacity	monthly kW/rack/network	recovery capacity	installed vs ultimate capacity	95th percentile trends, forecast, expansion gates
Finance	colo OPEX + assets	colo OPEX + recovery assets	land/CIP/PP&E + OPEX	GL reconciliation, asset register, approvals

Control-state taxonomy

Track control-definition status (draft/approved/effective/suspended/retired), implementation state, design assessment, operating assessment, evidence origin and test period separately. Current runtime design uses DRAFT, DESIGN_ONLY, NOT_ASSESSED, NOT_ASSERTED, and SYNTHETIC_REFERENCE respectively. A synthetic test cannot promote production operating effectiveness.

Evidence population integrity

For access logs, incidents, changes, maintenance, backups, alerts, and provider tickets, evidence extraction records must preserve source system, period, timezone, query/filter, pagination/export limits, record count, transformations, reconciliation, hash/provenance, and reviewer. Targeted high-risk selections remain nonprojectable unless a separate representative method is defined.

Runtime-specific acceptance tests

1. Under a provider-approved qualified-person procedure, test loss of power feed A and record protected-load behavior. Tenant staff must not operate live facility switchgear.

2. Repeat the provider-approved qualified-person procedure for feed B with rollback and safety controls.
3. Demonstrate generator/UPS transfer evidence at provider/owned layer as applicable.
4. Fail primary carrier and demonstrate alternate route.
5. Recover keys without Reno identity/KMS dependency.
6. Restore protected data in Boise and reconcile integrity/completeness.
7. Start minimum Alexandria/identity/DNS/logging stack in Boise.
8. Demonstrate failback with transaction/data reconciliation.
9. Test cage/owned-site emergency access and access revocation.
10. Test provider/contractor remote-hands authorization and chain of custody.
11. Validate logging continues during primary service disruption.
12. Exercise provider exit/equipment removal procedure at tabletop level before production and physically during migration where feasible.

SOC readiness

SOC 1/SOC 2 readiness requires the provider assurance report, CUEC mapping, Sable Harbor implementation evidence, complete populations, documented test procedures, exceptions/remediation, reviewer sign-off, and explicit period coverage. Provider reports do not establish Sable Harbor operating effectiveness. The CCF remains the native control architecture; external-framework mappings are overlays.