



PHOTOCELL DETECTS SUNSET AND SUNRISE

TRANSFORMER NOTE:

USE A MACHINE TOOL VARIETY ONLY. 100 VA IS RECOMMENDED. IF A SMALLER SIZED TRANSFORMER IS USED, ADJUST THE FUSE PROTECTION ACCORDINGLY. (see fuse note)

OUTPUT NOTE:

THE CONTROL OUTPUTS ARE RATED AT 1 AMP EACH MAXIMUM. DO NOT EXCEED THIS OR DAMAGE MAY RESULT. DO NOT EXCEED 1 AMP FOR ANY SINGLE OUTPUT OR 4 AMPS TOTAL FOR ALL OUTPUTS. (2 AMPS TOTAL IF A 50 VA TRANSFORMER IS IN USE)

FUSE NOTE:

IMPORTANT: DO NOT EXCEED 4 AMPS FOR THE FUSE RATING WHEN USING A 100 VA TRANSFORMER OR 2 AMPS WHEN USING A 50 VA TRANSFORMER. USE A SLOW BLOW VARIETY.

DIP SWITCH CONFIGURATION

MAXIMUM NUMBER OF STATIONS ALLOWED ON AT ONE TIME

#1 OFF	#2 OFF	#3 OFF	4 STATIONS
#1 ON	#2 OFF	#3 OFF	1 STATION
#1 OFF	#2 ON	#3 OFF	2 STATIONS
#1 ON	#2 ON	#3 OFF	6 STATIONS
#1 OFF	#2 OFF	#3 ON	3 STATIONS
#1 ON	#2 OFF	#3 ON	5 STATIONS
#1 OFF	#2 ON	#3 ON	7 STATIONS
#1 ON	#2 ON	#3 ON	8 STATIONS

IRRIGATION REPETITIONS

#4 OFF	#5 OFF	0 TIMES
#4 OFF	#5 ON	2 TIMES
#4 ON	#5 OFF	1 TIME
#4 ON	#5 ON	4 TIMES

IRRIGATION WAIT TIME BETWEEN REPETITIONS

#6 OFF	#7 OFF	1 MINUTE
#6 OFF	#7 ON	3 MINUTES
#6 ON	#7 OFF	5 MINUTES
#6 ON	#7 ON	10 MINUTES

REPETITIONS

#8 OFF	FAHRENHEIT
#8 ON	CENTIGRADE

WATER PLUS

MICRO GROW GREENHOUSE SYSTEMS, INC.

42065 Zevo Dr., Unit B-1
Temecula, CA 92590

Phone 951.296.3340 Fax 951.296.3350



Project

ASPIRATED WATER PLUS SYSTEM

Drawn by

SB

Date

04/29/04

Distributor

MICRO GROW

Order ID

N/A