station_v0_bogota: algorithm x metric summary
(green = better within column, accounting for metric direction)

	EVs served	Energy charged (kWh)	Transformer overload (kW x 15-min steps; / 4 = kWh) (lower better)	Avg. user satisfaction	Gross margin (COP/day)*
AFAP	13	2e+02	14	1	1.2e+05
Round Robin	13	2e+02	0	1	1.2e+05
TD3 (seed 100)	13	1.8e+02	5	0.98	1.1e+05
TD3 (seed 101)	13	1.8e+02	4.5	0.98	1.1e+05
TD3 (seed 102)	13	1.9e+02	4.7	0.98	1.1e+05
Random (control)	13	2e+02	3.3	1	1.2e+05
TD3-TrackingOnly (seed 100)	13	1.9e+02	11	0.99	1.1e+05
TD3-TrackingOnly (seed 101)	13	1.8e+02	9.3	0.98	1.1e+05
TD3-TrackingOnly (seed 102)	13	1.9e+02	4.6	0.99	1.1e+05
MPC (tracking)	13	2e+02	0	1	1.2e+05
MPC (energy-max)	13	2e+02	6.2e-06	1	1.2e+05
TD3 extended, primary (seed 100)	13	2e+02	9.2	1	nan
TD3 extended, primary (seed 101)	13	2e+02	7.7	1	nan
TD3 extended, primary (seed 102)	13	2e+02	3.6	1	nan
TD3 extended, last (seed 100)	13	2e+02	8.6	1	nan
TD3 extended, last (seed 101)	13	2e+02	11	1	nan
TD3 extended, last (seed 102)	13	2e+02	4.5	1	nan
TD3 new run @60k (seed 100)	13	1.8e+02	6	0.98	nan
TD3 new run @60k (seed 101)	13	1.6e+02	7	0.96	nan
TD3 new run @60k (seed 102)	13	1.9e+02	5.2	0.99	nan