


CONTROLLED COPY

REV.NO.	CHANGE DETAILS	DATE	PREPARED	APPD.
1.0	INITIAL RELEASE	25.06.22	DLRaju	YS
1.1	DRAWING LENGTHS UPDATED	06.06.23	DLRaju	YS



NOTE:

- ① — 6 Sq.mm Copper Cable(RED) for 110V DC Positive(Qty:1.70mtrs)
② — 6 Sq.mm Copper Cable(BLACK) for 110V DC Negative(Qty:3.00mtrs)
③ — 10 Sq.mm Copper Cable(YELLOW-GREEN) for EARTH(Qty:650mm)

MCB1 to MCB6 — 16A DC
MCB7 & MCB8 — 10A DC
SPD1 to SPD3 — 500ST
FUSE1 to FUSE8 — 10A HRC

PROJECT:
KAVACH
ASSEMBLY:
PDU BOX

SCALE:
NTS
SIZE:
A3
SHEET:
1 OF 1

EFFECTIVE FROM:

ALL DIMENSIONS ARE IN mm

HBL

< 6@Dck Yf'GmghYa g'@hX"
PÓŠÄÜÖSD

TITLE:
PÄÜPÜ' ÄÜÜY' ÜY Ü' ÖÖVÜÖW' WÖQ

Sl.No.	Drawing No.	Item Description	Material Spec.	Qty.	Remarks
			NAME	SIGN.	DATE
		DRAWN	DLRaju		
		CHECKED	JP		
		APPROVED	YS		
		DRAWING NO.	516490451		REV. 1.1
		PART NO.	6000051277		

TOLERANCE NOT SPECIFIED SHALL BE AS PER IS : 2102 - 1993.
THIS DRAWING IS THE PROPERTY OF HBL POWER SYSTEMS LIMITED AND MUST NOT BE COPIED, REPRODUCED, TRANSMITTED OR DISCLOSED TO ANY THIRD PARTY WITHOUT THE WRITTEN CONSENT OF THE COMPANY.