AquaMonitor Pro

Smart Water Quality Monitoring System — Daily Report

Generated: 28/10/2026, 2:23:19 pm

Account Plan: FREE

Water Quality Evaluation — Daily Summary

Real-time sensor telemetry and Water Quality Index (WQI) compliance monitoring.

EXECUTIVE COMPLIANCE SUMMARY

Total Monitored Stations: 11 | Safe Stations: 9 | Caution: 0 | Critical Alert: 2

Station	Location	pH	Turb(NTU)	Temp(°C)	DO(mg/L)	TDS(ppm)	WQI	Status
Kaveri	Karnataka	7.2	14	25	8.0	160	**100**	Safe
Yamuna	Delhi	7.1	58	18	6.2	564	**70**	Safe
Godavari	Nashik, Maharashtr	7.3	55	28	7.8	320	**90**	Safe
Saraswati	Kurukshetra, Harya	9.2	100	26	3.4	850	**25**	Alert
Narmada	Jabalpur, Madhya P	7.0	18	24	8.5	180	**100**	Safe
Ganga	Varanasi, Uttar Pr	7.4	28	22	7.9	210	**95**	Safe
Damodar	Dhanbad, Jharkhand	5.0	85	27	1.0	800	**45**	Alert
Banas	Tonk, Rajasthan	7.2	32	23	7.2	290	**85**	Safe
Brahmaputra	Guwahati, Assam	7.1	22	21	8.8	170	**100**	Safe
Ravi River	Ludhiana, Punjab	7.3	26	20	8.1	240	**88**	Safe
Beas River	Manali, Himachal P	8.1	25	15	9.2	190	**80**	Safe

Water Quality Index (WQI) Methodology

The Water Quality Index is computed based on weighted arithmetic index guidelines formulated by WHO and BIS (IS 10500:2012). Parameters are scored against permissible drinking limits: pH (6.5-8.5), Turbidity (<50 NTU), Dissolved Oxygen (>5.0 mg/L), and TDS (<500 ppm). Stations scoring 70-100 are Safe; 50-69 require Caution; scores below 50 indicate Unsafe / Alert conditions.