NHSRCL

# CHECKLIST FOR BEARING INSTLLATION

(Prior to and After Erection of Girder)

MAHSR-L&T/PKG C4/QAQC/ CF/ 79

Rev. No. 01

| | |
|---|---|
| Project | : Mumbai Ahmedabad High Speed Rail (Package No. MAHSR –C-4) |
| Client | : National High Speed Rail Corporation Limited (NHSRCL) |
| Engineer | : TCAP Consortium |
| Contractor | : Larsen & Toubro Ltd |

| | | | |
|---|---|---|---|
| Location/Chainage | : CH 211 | RFI No | : 0000220949 |
| Structure ID | : P17-P18 | Date of Installation | : 21-11-24 |
| Bearing Manufacturer | : Mageba. | Dimension of Bearing | : 710x660x98 mm |

| Span ID | Bearing ID / Bearing No. | | | | Bearing ID / Bearing No. | | | |
|---|---|---|---|---|---|---|---|---|
| | Mumbai End | | Mumbai End | | Ahmedabad End | | Ahmedabad End | |
| | B01 (EOM) East Outer | B02 (EIM) East Inner | B03 (WIM) West Inner | B04 (WOM) West Outer | B05 (EOA) East Outer | B06 (EIA) East Inner | B07 (WIA) West Inner | B08 (WOA) West Outer |
| 211 P17-P18 | 66483 | 66044 | 66300 | 66030 | 65884 | 66168 | 61314 | 62137 |

| S.No. | Description of Activity | Yes | No | N/A | Remarks |
|---|---|---|---|---|---|
| **A. Inspection of Pedestal for Bearings Installation** | | | | | |
| 1 | The bearing pedestal is wiped with cloth and surface is free from loose material, laitance etc.,. | ✓ | | | |
| 2 | Surface of pedestal, flatness checked using Digital Inclinometer and are within tolerence as per approved drawing (1 in 300) | ✓ | | | Please refer Sl. No.6 |
| 3 | No visible damage observed in the bearing like cracking or peeling etc | ✓ | | | |
| 4 | Size of Bearings are as per drawing. Test results for bearing available. | ✓ | | | |
| 5 | Average Compressive Strength of Bearing Pedestal Grout = 87.8 (211 P17 & 211 P18) Mpa (Results attached). | | | | |
| 6 | Final bearing position is surveyed and is as per drawing. | | | | |

| Description | Tolerance in mm | Observed Values | Remarks |
|---|---|---|---|
| Elevation | -10 to 0 | -3 to 0 ✓ | Survey report attached. |
| Center to Center Distance across span | -5 to +5 | ±2 ✓ | |
| Degree of Flatness- Along Span | 1/300 or less | <1/300 ✓ | |
| Degree of Flatness-Across Span | 1/300 or less | <1/300 ✓ | |
| Position | -10 to +10 | ±4 ✓ | |

| S.No. | Description of Activity | Yes | No | N/A | Remarks |
|---|---|---|---|---|---|
| **B. Inspection of Bearings & Bearing Pedestal after Girder Erection** | | | | | |
| 7 | Final Coordinates of the Girder checked and is as per the drawing | ✓ | | | Survey report attached. |
| 8 | No cracks / deformation observed in the bearing & bearing pedestal after the Girder Erection | ✓ | | | |
| 9 | Contact between the girder & bearing is intact & no gaps found. Contact area >95% considering upstand adjustment & hogging. | | ✓ | | Checked with Filler gauge |

**REMARKS :** Any Gap Generated in Bearing after lowering of Girder shall be Resolved by L&T On it's Own Risk & cost.

| | L&T Execution | L&T Quality | For Engineer / Engineers Representative |
|---|---|---|---|
| **Name:** | P. Surya Shivaji Reddy | Prince Kumar | PIYUSH KUMAR |
| **Sign:** | P S Reddy | Prince | Piyush Kumar |
| **Date:** | 21-11-24. | 21-11-24 | 21/11/2024 |

Note: i) Presence of Bearing Manufacturer's representative for first few girder installation.

ii) If degree of flatness is not within the limit, self adjusting epoxy adhesive shall be used for correction.

Anuraj TCAP PKG4

DYCRE Kaushal Kumar Kaushik