

F	<u>THERMAL INSULATION</u>			Remarks
#REF!	Supply and installation of External Thermal insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on ducts as per the specifications.			Comply
#REF!	13 mm thick insulation for supply air ducts in return air path.	sq.m	6163	
#REF!	19 mm thick insulation for return air ducts.	sq.m	576	
#REF!	25 mm thick insulation for supply duct (not in RA path).	sq.m	RO	
#REF!	25 mm thick insulation for supply & return air ducts exposed to weather.	sq.m	RO	
75	25 mm thick insulation for ducts exposed to atmosphere with UV protection of thickness minimum 7 mm Supply, installation, testing and commissioning of 25 mm thick closed cell nitrile rubber thermal insulation for exposed ducting along with factory laminated glass cloth of 7 mil thickness with UV protection.	sq.m	3443	
76	Supply, installation testing and commissioning of acoustic insulation. Material shall be nitrile rubber with 140-180 Kg/m ³ density and all accessories as per specification.			Complies for density 180 - 220 Kg/m3
76.1	15 mm thick	sq.m	2664	
77	Supply and installation of acoustic lining of walls of mechanical plant room, AHU rooms, Fan rooms, etc. covered with open cell Nitrile rubber with density 140 - 180 kg/m3 as per the approved shop drawings & specifications. All longitudinal and transfer joint shall be covered with 22-gauge 50 mm wide GI strip with screws	Nos.	RO	
77.1	15 mm thick acoustic lining with Nitrile Rubber	Sq.m.	9351	Complies for density 180 - 220 Kg/m3
78	Supply, installation of acoustic enclosure for Axial flow fans. The outer panel shall be made of galvanized preplasticised sheet of 24 gage thick and internally lined with 50 mm thick fibreglass having 64 Kg / cum density and covered with tissue and 28 gauge perforated aluminium inside as shown in drawings. The panels shall be duly bolted, joints provided with gaskets and suitably braced.	Nos.	RO	
79	Supplying, installing and testing of 19 mm thick insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on chilled water and condensate drain piping and fittings like valves, flanges union, etc. as per the approved shop drawings and specifications.			
79.1	25 mm dia pipes	RM	1507	
79.2	20 mm dia pipes	RM	1246	
79.3	15 mm dia pipes	RM	RO	
79.4	50 mm dia condensate drain pipes.	RM	522	
79.5	25 mm dia condensate drain pipes.	RM	260	Comply
80	Supply, installation and testing of 25 mm thick insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications.			

80.1	100 mm dia pipes	RM	345
80.2	80 mm dia pipes	RM	902
80.3	65 mm dia pipes	RM	201
80.4	50 mm dia pipes	RM	1946
80.5	40 mm dia pipes	RM	792
80.6	32 mm dia pipes	RM	1320
81	Supply, installation and testing of 32 mm thick insulation (Nitrile Rubber) with 7mil thick factory laminated fibreglass cloth protective coating on chilled water pipes and fittings like valves, flanges and unions, etc. as per approved shop drawings and specifications.		
81.1	400 mm dia pipes	RM	53
81.2	300 mm dia pipes	RM	45
81.3	250 mm dia pipes	RM	450
81.4	200 mm dia pipes	RM	386
81.5	150 mm dia pipes	RM	74
81.6	125 mm dia pipes	RM	273
81.7	600 mm dia pipes	RM	36
81.8	500 mm dia pipes	RM	200
81.9	450 mm dia pipes	RM	113
81.10	350 mm dia pipes	RM	41
82	Supply, installation, testing & commissioning of 32mm thick insulation with aluminium cladding and UV treatment over pipes exposed to sun & Plant room piping to be consider with Aluminium cladding.		
82.1	300 mm dia pipes	RM	16
82.2	250 mm dia pipes	RM	140
82.3	200 mm dia pipes	RM	168
82.4	150 mm dia pipes	RM	176
82.5	600 mm dia pipes	RM	30
82.6	500 mm dia pipes	RM	47

Comply

Comply with
Nitrile rubber