

CLIENT : GREW ENERGY PRIVATE LIMITED

PROJECT : PROPOSED EXPANSION OF PV CELL MANUFACTURING UNIT AT NARMADAPURAM, MP

CONSULTANT : VMS ENGINEERING & DESIGN SERVICES (P) LTD.

DOCUMENT NAME : TECHNICAL DATA SHEET GENERAL FOR HVAC WORKS

REVISION NO. : R0

DATE : 14-03-2026



No.	Description	Bid Requirement	Bidder's Response	compliance
11	DUCT THERMAL INSUALTION			
11.1	INSULATION MATERIALS	REFER BOQ		
11.1.1	EQUIPMENT	NITRILE RUBBER OF CLASS "O" HAVING THERMAL CONDUCTIVITY <0.036W/Mk		complies
11.1.2	AIR-CONDITIONING DUCT	NITRILE RUBBER		complies
11.1.3	INSULATION ADHESIVES	REFER BOQ		noted
11.1.4	VAPOUR BARRIERS	REFER BOQ		noted
11.2	FINISHING MATERIALS			
11.2.1	EQUIPMENT	NA		
11.2.2	AIR-CONDITIONING DUCT	NITRILE RUBBER OF CLASS "O"		complies
11.2.3	IS ANY INSULATION MATERIAL CORROSIVE TO CARBON STEEL OR ALLOY STEEL SURFACE IN CONTACT	YES / NO		
11.2.4	INSULATION THICKNESSES FOR ALL INSULATION MATERIALS SELECTED, IN THE FORMAT SIMILAR TO THAT IN DATA SHEET A, TO BE ENCLOSED.	WHETHER ENCLOSED		
12	ACCOUSTIC INSULATION FOR DUCT-10 mm THICK			
12.01	INSULATION MATERIALS			
12.02	EQUIPMENT	10 mm thick class 1 rating Open cell nitrile rubber elastomeric insulation		complies
12.03	DENSITY	140 - 180 kg / m ³		complies for 180-220 kg/m3
12.04	THERMAL CONDUCTIVITY	0.047W/m K @ 20 degC as per DIN EN 12667.		complies
L)	CHW insulation nitrile rubber			
1	Make	VTs		
2	Material of insulation	Class "O" elastomeric nitrile rubber with 24G AL Cladding		complies
4	Application	Chilled water piping insulation		
5	Thickness mm	As per BOQ		noted
6	Thermal conductivity w/(m.k)	0.037		complies
7	Density kg/m3	45 - 55		complies for density of 40-60 kg/m3
8	Surface finish	24 G Aluminium Cladding		complies
9	Measurement standard	Pipe dia & centre line		
10	Adhesive	equivalent as per manufacturer recommendation.		noted