

3	NITRILE RUBBER INSULATION		
	Insulation material shall be Class "O" type fire propagation with closed cell elastomeric nitrile rubber having factory laminated aluminum foil with high water vapour diffusion and low thermal conductivity. Material shall be elastomeric foam based on synthetic rubber conforming to BS 476part 6 for fire propagation test and Class 1 as per BS 476 part 7 for surface spread of flame test. Aluminium tape shall be applied on all transpose & longitudinal joints. All insulation joints (including Flange joints) to be sealed with 4" width 1mm Thk Self Adhesive tape.		
	Density of Material shall be between 45±5 Kg/m3. Thermal conductivity shall not exceed 0.035 W/m/K at mean temperature of 0°C. Moisture diffusion resistance factor should be minimum 60000 Thickness of the insulation will be as specified for the individual application. Adhesive used for setting the insulation will be non-flammable, vapour proof adhesive, low VOC as per the manufacturer recommendation. Supply of Adhesive will be in scope of HVAC contractor. Insulation material shall be FM approved.		
	Installation procedure shall be as per the manufacturer guidelines.		
3.01	09 mm thick	Sq.mtr	UR
3.02	13 mm thick	Sq.mtr	UR
3.03	19 mm thick	Sq.mtr	8400
3.04	25 mm thick	Sq.mtr	UR
3.05	32 mm thick	Sq.mtr	8400

Complied
(Aerocell Alu EN)

