

1.0	Insulated Chilled Water Piping	Total qty		Remark
	Supply, fabrication, assembling, laying, testing and balancing of chilled water piping using Mild Steel Heavy Duty "C" Class Pipes as per IS 1239 Part A & B & IS 3589 with all heavy duty fittings such as bends, elbows, tees etc. and complete with vibration isolators, hangers, full round PU supports as per specifications. The chilled water piping on terrace and outside of the HVAC Plant room shall be suitably supported for proper head room clearance. This supporting arrangement shall be included in the respective pipe sizes and no additional measurements / costs shall be considered.			Complied
	Chilled water piping insulation, complete with bends, elbows, tees, duly insulated with 50mm / 40/ 32/ 25/19mm thk, Closed Cell Foam with min.density 60kg/m3 and thermal conductivity - 0.035 w/m.k Insulation pipe sections stuck with special adhesive and finished with vapour barrier and covered with glass cloth & final finished with the AF 5590 Lag Coating for protection against Mechanical damage, Fungal growth, Flame spread, Water permeance and Ultra Violet radiation. Necessary Certificates to the effect to be produced by the vendor from the Coating Manufacturer. complete as per specifications.			
1.1	200 NB[6 mm thk. as per IS 3589] with 100mm thk insulation	72	RMT	
1.2	150 NB[thk. as per IS 1239 - heavy duty] with 100mm thk insulation	200	RMT	
1.3	125 NB[thk. as per IS 1239 - heavy duty] with 75mm thk insulation	18	RMT	
1.4	100 NB[thk. as per IS 1239 - heavy duty] with 75mm thk insulation	10	RMT	
1.5	80 NB[thk. as per IS 1239 - heavy duty] with 75mm thk insulation	-	RMT	
1.6	65 NB[thk. as per IS 1239 - heavy duty] with 75mm thk insulation	144	RMT	
1.7	50 NB[thk. as per IS 1239 - heavy duty] with 50mm thk insulation	120	RMT	
1.8	40 NB[thk. as per IS 1239 - heavy duty] with 50mm thk insulation	72	RMT	
1.9	32 NB[thk. as per IS 1239 - heavy duty] with 50mm thk insulation	48	RMT	
1.10	25 NB[thk. as per IS 1239 - medium duty] with 40mm thk insulation	48	RMT	
1.11	19 NB[thk. as per IS 1239 - medium duty] with 40mm thk insulation	576	RMT	
1.12	15 NB[thk. as per IS 1239 - medium duty] with 40mm thk insulation	-	RMT	
1.13	12.5 NB[thk. as per IS 1239- medium duty] with 40mm thk insulation	-	RMT	
D	INSULATION			
1.0	Thermal Insulation of Ducts			
	Supply, fabrication & Installation of thermal insulation on GI ducts complete with Closed Cell Foam with minimum density of 40 Kg/m3 with minimum R Value 4.1/inch & thermal conductivity 0.035 w/mok confirming to Class 'O' & the inner side stuck to the outer facia of the GI ducts with recommended / Proprietary Synthetic adhesive bonding (SR998 or equivalent) & installed as per manufacturers recommendation.The insulation joints shall be sealed with 3" wide Black Tape.			Complied
1.1	9 mm thick Insulation	-	Sq.M.	

1.2	13 mm thick Insulation	2,210	Sq.M.	
1.3	16 mm thick Insulation	-	Sq.M.	
1.4	19 mm thick Insulation	-	Sq.M.	
1.5	25 mm thick Insulation	-	Sq.M.	
2.0	Acoustic Lining of Ducts			
	10 mm thick acoustic insulation with Armasound foam / Thermal conductivity 0.045 W/m deg.K / density 140~180 kg/m3, Stuck to AHU room walls with manufacturer recommended adhesive 520 bonding	160	Sq.M.	Complied with Deviation We have K value 0.04726 at 20C mean Temperature
3.0	Acoustic Insulation of Trap doors			
	Supply, fabrication and installation of Acoustic insulation on walls and Trap doors as specified and shown on the drawing complete with:			Complied with Deviation We have K value 0.04726 at 20C mean Temperature
	25 mm thick acoustic insulation with Armasound foam / Thermal conductivity 0.045 W/m deg.K / density 140~180 kg/m3, Class1, stuck to AHU room walls with manufacturer recommended adhesive 520 bonding.	100	Sq.M.	
4.0	Underdeck Insulation			
	Supply, Installation & testing of Preinsulated aluminium embossed sandwich panel of 30 mm thick, 80 micron embossed aluminium foil on both sides, having density of 45 Kg/M3 with preinsulated PUF Panel /Polyisocyanurate (PIR) Panel . Fire Class "O" BS 476 Part 6 & 7, Class "A" ASTM E84. stuck with approved adhesive compound to the underside of top roof slab surface and joints sealed with special adhesive.	480	Sq.M.	We have INPANEL® PIR Board Which is Fire Class O, both side laminated with FSK